

Radon Resistant New Construction (RRNC) Energy Calculations:



625 Robert St N
PO BOX 64975
St. Paul, MN 55164-0975
Phone: (651) 201-4601
Fax: (651) 201-4606
www.health.state.mn.us

Average RRNC Fan*	20 Watts	X	24 hrs	=	480 watt-hours/day
	480 watt-hours/day	X	7 days/wk	=	3360 watt-hours/wk
	3360 watt-hours/wk	÷	1000 watts/kilowatt	=	3.36 kwh/wk
	3.36 kwh/wk	X	\$0.07 /kwh	=	
	\$0.24 /wk	X	4.25 wk/mo	=	
	\$1.02 /mo	X	12 mo/yr	=	

Average Mitigation Fan*	100 Watts	X	24 hrs	=	2400 watt-hours/day
	2400 watt-hours/day	X	7 days/wk	=	16800 watt-hours/wk
	16800 watt-hours/wk	÷	1000 watts/kilowatt	=	16.8 kwh/wk
	16.8 kwh/wk	X	\$0.07 /kwh	=	
	\$1.15 /wk	X	4.25 wk/mo	=	
	\$4.87 /mo	X	12 mo/yr	=	

Average TV with Power OFF	10 Watts	X	24 hrs	=	240 watt-hours/day
	240 watt-hours/day	X	7 days/wk	=	1680 watt-hours/wk
	1680 watt-hours/wk	÷	1000 watts/kilowatt	=	1.68 kwh/wk
	1.68 kwh/wk	X	\$0.07 /kwh	=	
	\$0.11 /wk	X	4.25 wk/mo	=	
	\$0.49 /mo	X	12 mo/yr	=	

Average Computer Left ON	135 Watts	X	24 hrs	=	3240 watt-hours/day
	3240 watt-hours/day	X	7 days/wk	=	22680 watt-hours/wk
	22680 watt-hours/wk	÷	1000 watts/kilowatt	=	22.68 kwh/wk
	22.68 kwh/wk	X	\$0.07 /kwh	=	
	\$1.55 /wk	X	4.25 wk/mo	=	
	\$6.57 /mo	X	12 mo/yr	=	

* The difference in fan size is due to the gravel required in the RRNC building practices.