MINNESOTA MDH DEPARTMENT OF HEALTH

MONTH: _____ YEAR: _____

FACILITY NAME: _____

POOL: SWIM SPA WADE ACTIVITY LAP ZERO-DEPTH PLUNGE RIVER THERAPY

	SUCTION OUTLET(s)	DISINFECTANT Cl (Br x 2)		pH (7.2- 8.0)	Flow Rate Min= _____	ORP - HRR (> 700)	Temperature (Max =104F)	Alkalinity (>50ppm)	Cyanuric Acid (<30,<100)	Pressure (psi)	Comments: Manual Chem Feed, Breakdowns, Injuries, Accidents, CPOs Initials
DATE		Free (1-5)	Combined <+0.5								
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											