

Intentional event (attempted or actual break-in at well/storage/trtmt plant; possible or actual contamination incident):

*Call local law enforcement () and MDH (651-201-5386).

*Call State Duty Officer (1-800-422-0798) and say,

'[] water system has had an attempted/actual break-in.' or

'[] water system has had a possible/actual contamination incident.'

Unintentional event (possible or actual contamination incident; significant chemical overfeed):

*Call MDH (651-201-5386) and State Duty Officer (1-800-422-0798) and say,

'[] water system has had a possible/actual unintentional contamination incident.'

or '[] water system has had a significant chemical overfeed.'

Chlorine storage leak: Leave area and evacuate nearby population if needed.

Make ALL the following calls ASAP (appx 15 minutes):

*Call local HazMat response team ().

*Call local law enforcement ().

*Call State Duty Officer (1-800-422-0798) and say,

'[] water system has had a chlorine storage leak.' Officer contacts MN Dept of Ag

*Call National Response Center (1-800-424-8802) and MDH (651-201-5386).

Event that may affect, or is affecting, functioning of your water system
(including natural disaster or significant low-pressure incident):

*Call MDH (651-201-5386) and State Duty Officer (1-800-422-0798) and say,

'[] water system has had a [disaster]/significant low pressure incident.'

and/or '[] water system is requesting assistance from MNWARN.'

MDH District Engineer: