

DEPARTMENT OF HEALTH AND HUMAN SERVICES

CENTERS FOR MEDICARE & MEDICAID SERVICES

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: 0YV1

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00191

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245587		3. NAME AND ADDRESS OF FACILITY (L3) EBENEZER CARE CENTER (L4) 2545 PORTLAND AVENUE SOUTH (L5) MINNEAPOLIS, MN (L6) 55404		4. TYPE OF ACTION: <u>7</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint	
2.STATE VENDOR OR MEDICAID NO. (L2) 810542100		5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>03</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE	
6. DATE OF SURVEY 04/12/2013 (L34)		8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other		FISCAL YEAR ENDING DATE: (L35) 06/30	
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) :		10.THE FACILITY IS CERTIFIED AS: X A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements <u> </u> 2. Technical Personnel <u> </u> 6. Scope of Services Limit Compliance Based On: <u> </u> 3. 24 Hour RN <u> </u> 7. Medical Director <u> </u> 1. Acceptable POC <u> </u> 4. 7-Day RN (Rural SNF) X 8. Patient Room Size <u> </u> 5. Life Safety Code <u> </u> 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: A,8 (L12)			
12.Total Facility Beds 138 (L18)		13.Total Certified Beds 138 (L17)		14. LTC CERTIFIED BED BREAKDOWN 18 SNF 18/19 SNF 19 SNF ICF IID 34 104 (L37) (L38) (L39) (L42) (L43)	
		15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)			

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

See Attached Remarks

17. SURVEYOR SIGNATURE <u>Gloria Derfus, Unit Supervisor</u>		Date : 04/28/2013 (L19)		18. STATE SURVEY AGENCY APPROVAL <u>Shellae Dietrich, Program Specialist</u>		Date: 04/28/2013 (L20)	
---	--	--------------------------------	--	---	--	-------------------------------	--

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY X 1. Facility is Eligible to Participate <u> </u> 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : <u> </u>	
22. ORIGINAL DATE OF PARTICIPATION 06/01/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		24. LTC AGREEMENT ENDING DATE (L25)	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)		26. TERMINATION ACTION: (L30) VOLUNTARY 00 INVOLUNTARY 01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement 03-Risk of Involuntary Termination OTHER 04-Other Reason for Withdrawal 07-Provider Status Change 00-Active	
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 00320 (L28) (L31)		30. REMARKS Posted 5/3/13 ML	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE 04/04/2013 (L33)		DETERMINATION APPROVAL	

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: 0YV1

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00191

C&T REMARKS - CMS 1539 FORM

STATE AGENCY REMARKS

CCN# 24-5587

At the time of the standard survey completed March 1, 2013, the facility was not in substantial compliance and the most serious deficiencies were found to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections are required. The facility was given an opportunity to correct before remedies were imposed.

On April 12, 2013, the Minnesota Department of Health completed a Post Certification Revisit (PCR) and on April 5, 2013, the Minnesota Department of Public Safety completed a PCR by review of the plan of correction and determined that the facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to the standard survey, completed on March 1, 2013, effective March 27, 2013. Therefore, the remedies outlined in our letter dated March 18, 2013, will not be imposed.

See attached CMS-2567B forms for the results of the April 12, 2013 and April 5, 2013 revisits.

The facility is requesting approval from the Department of Health for the following room size waiver:

- F458 - 483.70(d)(1)(ii) Resident Room Waiver.



Protecting, Maintaining and Improving the Health of Minnesotans

CCN# 24-5587

April 28, 2013

Mr. Joel Prevost, Administrator
Ebenezer Care Center
2545 Portland Avenue South
Minneapolis, Minnesota 55404

Dear Mr. Prevost:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective March 27, 2013 the above facility is certified for:

34 Skilled Nursing Facility/Nursing Facility Beds

104 Nursing Facility II Beds

Your facility's Medicare approved area consists of all 34 skilled nursing facility beds.

Your request for waiver of F458 has been approved based on the submitted documentation.

If you are not in compliance with the above requirements at the time of your next survey, you will be required to submit a Plan of Correction for this deficiency or renew your request for waiver in order to continue your participation in the Medicare Program.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.


Ebenezer Care Center

April 28, 2013

Page 2

Please contact me if you have any questions.

Sincerely,

A handwritten signature in cursive script that reads "Shellae Dietrich".

Shellae Dietrich, Program Specialist

Program Assurance Unit

Licensing and Certification Program

Division of Compliance Monitoring

Minnesota Department of Health

P.O. Box 64900

St. Paul, MN 55164-0900

Telephone #: (651) 201-4106 Fax #: (651) 215-9697

cc: Licensing and Certification File



Protecting, Maintaining and Improving the Health of Minnesotans

April 28, 2013

Mr. Joel Prevost, Administrator
Ebenezer Care Center
2545 Portland Avenue South
Minneapolis, Minnesota 55404

RE: Project Number S5587022 and H5587035

Dear Mr. Prevost:

On March 18, 2013, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on March 1, 2013 that included an investigation of complaint number H5587035. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On April 12, 2013, the Minnesota Department of Health completed a Post Certification Revisit (PCR) and on April 5, 2013 the Minnesota Department of Public Safety completed a PCR by review of your plan of correction to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on March 1, 2013. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of March 27, 2013. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on March 1, 2013, effective March 27, 2013 and therefore remedies outlined in our letter to you dated March 18, 2013, will not be imposed.

Your request for a continuing waiver involving the deficiency cited under F458 at the time of the March 1, 2013 standard survey has been forwarded to CMS for their review and determination. Your facility's compliance is based on pending CMS approval of your request for waiver.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Enclosed is a copy of the Post Certification Revisit Form, (CMS-2567B) from this visit.

Feel free to contact me if you have questions.

Ebenezer Care Center

April 28, 2013

Page 2

Sincerely,

A handwritten signature in dark ink that reads "Shellae Dietrich". The script is cursive and fluid.

Shellae Dietrich, Program Specialist

Licensing and Certification Program

Division of Compliance Monitoring

Telephone: (651) 201-4106 Fax: (651) 215-9697

Enclosure

cc: Licensing and Certification File

5587r113.rtf

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245587	(Y2) Multiple Construction A. Building B. Wing	(Y3) Date of Revisit 4/12/2013
Name of Facility EBENEZER CARE CENTER		Street Address, City, State, Zip Code 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix F0253 Reg. # 483.15(h)(2) LSC	Correction Completed 03/27/2013	ID Prefix F0274 Reg. # 483.20(b)(2)(ii) LSC	Correction Completed 03/15/2013	ID Prefix F0325 Reg. # 483.25(i) LSC	Correction Completed 03/21/2013
ID Prefix F0329 Reg. # 483.25(l) LSC	Correction Completed 03/21/2013	ID Prefix F0356 Reg. # 483.30(e) LSC	Correction Completed 03/01/2013	ID Prefix F0431 Reg. # 483.60(b), (d), (e) LSC	Correction Completed 03/21/2013
ID Prefix F0465 Reg. # 483.70(h) LSC	Correction Completed 03/27/2013	ID Prefix Reg. # LSC	Correction Completed	ID Prefix Reg. # LSC	Correction Completed
ID Prefix Reg. # LSC	Correction Completed	ID Prefix Reg. # LSC	Correction Completed	ID Prefix Reg. # LSC	Correction Completed
ID Prefix Reg. # LSC	Correction Completed	ID Prefix Reg. # LSC	Correction Completed	ID Prefix Reg. # LSC	Correction Completed

Reviewed By State Agency	Reviewed By GD/sd	Date: 04/28/13	Signature of Surveyor: 18623	Date: 04/12/13		
Reviewed By CMS RO	Reviewed By	Date:	Signature of Surveyor:	Date:		
Followup to Survey Completed on: 3/1/2013		Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? <table border="0"> <tr> <td>YES</td> <td>NO</td> </tr> </table>			YES	NO
YES	NO					

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245587	(Y2) Multiple Construction A. Building B. Wing 01 - MAIN BUILDING 01	(Y3) Date of Revisit 4/5/2013
Name of Facility EBENEZER CARE CENTER		Street Address, City, State, Zip Code 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix _____ Reg. # NFPA 101 LSC K0012	Correction Completed 03/07/2013	ID Prefix _____ Reg. # NFPA 101 LSC K0038	Correction Completed 03/07/2013	ID Prefix _____ Reg. # NFPA 101 LSC K0040	Correction Completed 03/07/2013
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

Reviewed By _____ State Agency	Reviewed By PS/sd	Date: 0428/13	Signature of Surveyor: 28120	Date: 04/05/13
Reviewed By _____ CMS RO	Reviewed By	Date:	Signature of Surveyor:	Date:
Followup to Survey Completed on: 2/27/2013		Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? YES NO		

DEPARTMENT OF HEALTH AND HUMAN SERVICES

CENTERS FOR MEDICARE & MEDICAID SERVICES

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: 0YV1

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00191

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245587		3. NAME AND ADDRESS OF FACILITY (L3) EBENEZER CARE CENTER (L4) 2545 PORTLAND AVENUE SOUTH (L5) MINNEAPOLIS, MN (L6) 55404		4. TYPE OF ACTION: <u>2</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint	
2. STATE VENDOR OR MEDICAID NO. (L2) 810542100		5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>03</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE	
6. DATE OF SURVEY 03/01/2013 (L34)		8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other		FISCAL YEAR ENDING DATE: (L35) 06/30	
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) :		10. THE FACILITY IS CERTIFIED AS: A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements <u> </u> 2. Technical Personnel <u> </u> 6. Scope of Services Limit Compliance Based On: <u> </u> 3. 24 Hour RN <u> </u> 7. Medical Director <u> </u> 1. Acceptable POC <u> </u> 4. 7-Day RN (Rural SNF) <u>X</u> 8. Patient Room Size <u> </u> 5. Life Safety Code <u> </u> 9. Beds/Room			
12. Total Facility Beds 138 (L18)		X B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: B,8 (L12)			
13. Total Certified Beds 138 (L17)					
14. LTC CERTIFIED BED BREAKDOWN 18 SNF 18/19 SNF 19 SNF ICF IID 34 104 (L37) (L38) (L39) (L42) (L43)				15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)	

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

See Attached Remarks

17. SURVEYOR SIGNATURE <u>Sandra Nelson, HFE NE II</u> (L19)		Date : 04/02/2013		18. STATE SURVEY AGENCY APPROVAL <u>Shellae Dietrich, Program Specialist</u> (L20)		Date: 04/03/2013	
--	--	--------------------------	--	--	--	-------------------------	--

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY <u> </u> 1. Facility is Eligible to Participate <u> </u> 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT: <u> </u>		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : <u> </u>	
22. ORIGINAL DATE OF PARTICIPATION 06/01/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		24. LTC AGREEMENT ENDING DATE (L25)	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)		26. TERMINATION ACTION: (L30) <u>VOLUNTARY</u> <u>00</u> <u>INVOLUNTARY</u> 01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement 03-Risk of Involuntary Termination <u>OTHER</u> 04-Other Reason for Withdrawal 07-Provider Status Change 00-Active	
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 00320 (L28) (L31)		30. REMARKS Posted 04/04/2013 CO. 0YV1 Health Waiver F458 PDF_CMS 04/04/2013 CO.	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE (L33)		DETERMINATION APPROVAL	

FSES PDF_CMS 04/04/2013 CO.

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: 0YV1

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00191

C&T REMARKS - CMS 1539 FORM

STATE AGENCY REMARKS

CCN# 24-5587

At the time of the standard survey completed March 1, 2013, the facility was not in substantial compliance and the most serious deficiencies were found to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required. The facility has been given an opportunity to correct before remedies are imposed. See attached CMS-2567 for survey results.

See attached Fire Safety Evaluation System (FSES) dated March 7, 2013 for Life Safety Code results.

The facility is requesting approval from the Department of Health for the following room size waiver:

- F458 - 483.70(d)(1)(ii) Resident Room Waiver

Post Certification Revisit to follow.



Protecting, Maintaining and Improving the Health of Minnesotans

Certified Mail # 7011 2000 0002 5148 3934

March 18, 2013

Mr. Joel Prevost, Administrator
Ebenezer Care Center
2545 Portland Avenue South
Minneapolis, Minnesota 55404

RE: Project Number S5587022 and H5587035

Dear Mr. Prevost:

On March 1, 2013, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs. In addition, at the time of the March 1, 2013 standard survey the Minnesota Department of Health completed an investigation of complaint number H5587035.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed. In addition, at the time of the March 1, 2013 standard survey the Minnesota Department of Health completed an investigation of complaint number H5587035 that was found to be substantiated.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Gloria Derfus
Minnesota Department of Health
P.O. Box 64900
St. Paul, Minnesota 55164-0900

Telephone: (651) 201-3792

Fax: (651) 201-3790

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by April 10, 2013, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by April 10, 2013 the following remedy will be imposed:

- Per instance civil money penalties. (42 CFR 488.430 through 488.444)

PLAN OF CORRECTION (PoC)

A PoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your PoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Include signature of provider and date.

If an acceptable PoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable PoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's PoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the PoC must meet the criteria listed in the plan of correction section above. You will be notified by the

Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your PoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable PoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved PoC, unless it is determined that either correction actually occurred between the latest correction date on the PoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the PoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by June 1, 2013 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal

regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by September 1, 2013 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Division of Compliance Monitoring
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting a PoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Patrick Sheehan, Supervisor
Health Care Fire Inspections
State Fire Marshal Division
444 Cedar Street, Suite 145
St. Paul, Minnesota 55101-5145


Ebenezer Care Center
March 18, 2013
Page 6

Telephone: (651) 201-7205

Fax: (651) 215-0541

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads "Shellae Dietrich". The script is cursive and fluid.

Shellae Dietrich, Program Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Telephone: (651) 201-4106 Fax: (651) 215-9697

Enclosure

cc: Licensing and Certification File

5587s13.rtf

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 000	INITIAL COMMENTS The facility's plan of correction (POC) will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. Upon receipt of an acceptable POC an on-site revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A standard recertification survey and complaint investigation were conducted. Complaint H5587035 was substantiated and deficiencies were issued at F325 and F465.	F 000	Submission of this credible allegation of compliance is not a legal admission that a deficiency exist or that the statement of deficiency was correctly cited, and is also not to be construed as an admission against the interest of the facility, its administrator or any employees, agents or other individuals who draft or may be discussed in this credible allegation of compliance. In addition, preparation and submission of this credible allegation of compliance does not constitute and admission or agreement of any kind by this facility of the truth of any facts alleged or the correctness of any conclusions set forth in this allegation by the survey agency	
F 253 SS=E	483.15(h)(2) HOUSEKEEPING & MAINTENANCE SERVICES The facility must provide housekeeping and maintenance services necessary to maintain a sanitary, orderly, and comfortable interior. This REQUIREMENT is not met as evidenced by: Based on observation, interview and document review, the facility failed to ensure resident rooms and wheelchairs were kept clean and in good repair for 6 of 40 residents (R93, R108, R69, R38, R71, R6) reviewed in the stage one sample. Findings include: Observations during the initial tour on 2/25/13, at 12:30 p.m. during the resident and family interviews on 2/25/13 and 2/26/13, and during the	F 253	R93's new wheel chair arm rest was ordered at the time of the health survey and has been replaced. R108's bathroom was cleaned and specimen containers were removed and disposed of on 2/28/13	

Accepted by [Signature] 4-1-13

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
	Administrator	3/27/13

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that her safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.


DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 253	Continued From page 1 environmental tour on 2/28/13, at 11.00 a.m. with the administrator and housekeeping supervisor (HS) revealed the following: R93's wheel chair arm rest was in disrepair. The black "Buddy" arm rest cover was cut, exposing a two inch by three inch area of yellow foam creating an uncleanable surface. The administrator stated the arm rest cover "needed to be changed." R108's bathroom had two white graduated containers used urine specimen collection that were stained with yellow streaks and were on the floor by the toilet. One of the containers was partially in a plastic bag. R69's bathroom also contained a white graduated container laying on the floor by the toilet. The sink was peeling away for the wall, creating a one inch gap in between the wall and sink. R38's bathroom doorway had small gouges and peeling paint on the lower part creating an uncleanable surface, and the bathroom also had a white graduated container on the floor by the toilet. R71's room baseboard had peeling and scuffed white paint exposing the dark wood all around the room. The bathroom pedestal covered with light brown vinyl was ripped and peeling away, exposing the dark black base. The HS stated a work order had been received, and repairs were in progress. The HS did not provide the work order for review. R6's room had the vinyl missing on a one foot by	F 253	R69's bathroom was cleaned and specimen container was disposed of on 2/28/13. R69's bathroom sink was repaired on 2/28/13 R38's bathroom was cleaned and specimen container was disposed of on 2/28/13. R38's bathroom doorway was cleaned and painted and repaired 3/27/13 R71's room baseboard was repaired and painted on 3/1/13 The bathroom pedestal vinyl was repaired on 2/26 R6's floor vinyl was replaced on 3/13/13 Painting requests are included in the work order system for better tracking purposes effective 3/10/13 Environmental audits are conducted weekly with oversight of the Administrator. All audits are reported to the quality assurance committee and will continue for 3 months or until on-going compliance is achieved.	3/27/13



DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 253	Continued From page 2 three foot area under the heater. The administrator explained the heater was recently changed, and staff were planning to change the vinyl floor. All the above issues were viewed and confirmed by the administrator and HS during the environmental tour. The administrator explained the facility's staff used a work order system to communicate environmental concerns with the maintenance department. The HS stated the facility did not have a tracking system to identify and repair paint chips. The director of nursing (DON) was interviewed on 2/28/13, at 12:20 p.m. and stated the white graduated containers were used to collect urine specimens, and should have been disposed of after use. On 2/28/13, at 3:15 p.m. the administrator explained the maintenance staff completed random audits to identify environmental concerns; however, maintenance staff relied on the staff working on the floor to communicate issues using the work order forms. Painting needs were not identified on tracking forms, rather were verbally communicated to a vendor. The Specimen Collection policy dated 4/10, provided by the DON directed staff to "Dispose of the disposable equipment appropriately." The Maintenance Work Orders policy dated 3/10, indicated, "Work orders for the Maintained Department must be completed and submitted via the maintenance hard copy form."	F 253	RECEIVED APR 1 - 2013 COMPLIANCE MONITORING DIVISION LICENSE AND CERTIFICATION	
F 274	483.20(b)(2)(ii) COMPREHENSIVE ASSESS	F 274		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2545 PORTLAND AVENUE SOUTH

MINNEAPOLIS, MN 55404

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 274 SS=D	Continued From page 3 AFTER SIGNIFICANT CHANGE A facility must conduct a comprehensive assessment of a resident within 14 days after the facility determines, or should have determined, that there has been a significant change in the resident's physical or mental condition. (For purpose of this section, a significant change means a major decline or improvement in the resident's status that will not normally resolve itself without further intervention by staff or by implementing standard disease-related clinical interventions, that has an impact on more than one area of the resident's health status, and requires interdisciplinary review or revision of the care plan, or both.) This REQUIREMENT is not met as evidenced by: Based on interview and document review, the facility failed to complete a significant change in status Minimum Data Set (MDS) assessment for 2 of 3 residents (R156, R39) in the sample who experienced a significant decline. Findings include: R156's diagnoses included knee effusion and paranoid schizophrenia (mental illness). The admission MDS dated 11/8/12, identified R156 required supervision with transfers, to walk in corridor, and with locomotion off the unit. In addition, R156 required limited assistance with dressing and toilet use. The Care Area Assessment (CAA) also dated 11/8/12, identified R156 had self-care and balance deficits. R156 had an unsteady gait secondary to right knee	F 274	The facility will ensure significant changes are reflected in the status on MDS assessments for residents as required. A significant change was completed for R156 on 3/15 A significant change was started on 3/4 for R39. The significant change was not completed due to R39's discharge on 3/11/13. MDS coordinators were educated on the RAI manual guidelines regarding significant changes on 3/4/13. A new process for identifying and completing significant changes was implemented on 3/4/13. The process requires all possible significant changes are reviewed by the interdisciplinary team for approval. Audits of significant changes are conducted by the Administrator and will continue for 3 months or until ongoing compliance is achieved. Results of the audits are reported to the quality assurance committee.	3/15/13

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 274	Continued From page 4 effusion and required staff supervision to ambulate with a wheeled walker to and from all destinations. Progress notes dated 11/16/12, titled Situation/System/Change indicated R156 was "alert to baseline, weak, unable to ambulate with walker." Staff offered assistance with activities of daily living, and the physician/nurse practitioner (NP) were to be updated. A urinalysis/urine culture (UA/UC had been ordered and staff was to encourage hydration. In addition, the progress notes dated 11/16/12, indicated R156 had urinated all over the room and required a two-person assist for transfers. A progress note revealed R156 attempted to self-transfer from the wheelchair to bed in the room and fell on 11/18/12, at 10:05 a.m. The following day a UA/UC and physical therapy (PT) was ordered, however, care conference summary notes dated 11/20/12, indicated R156 refused to participate in PT, therefore was being discharged from both PT and also occupational therapy (OT). On 11/22/12, an order was received for Amoxicillin 500 milligrams (mg) orally twice daily for five days for a urinary tract infection (UTI). The progress note read, "Resident had increased weakness and decreased functional ability for the last few days. Has had episode of increased confusion. UA completed 11/20/12." Once week later a note date 11/28/12, indicated R156 was more alert and cooperative with staff. A PT progress note dated 1/3/13, indicated R156 was "Seen x 32 sessions in PT and made excellent progress since the start of care. PT	F 274		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 274	Continued From page 5 ended 1/4/13. Goal dates for PT was 1/18/13. Patient able to tolerate NuStep x 15 minutes at level 9. Patient ambulates 300-450 feet with rolling walker [RW] on even surfaces requiring supervision. Patient is able to complete transfers requiring supervision." Review of the physician/NP progress note dated 1/21/13, indicated R156 appeared stable with Tylenol and knee brace for knee pain. A quarterly MDS dated 2/5/13, identified R156 required extensive assistance with transfers, to walk in corridor, with locomotion off the unit, with dressing and toilet use. A registered nurse (RN)-E on 2/28/13, was interviewed at 10:45 a.m. and explained that R156 was admitted on 11/1/12 for rehabilitation and was refusing care. In addition, R156 preferred the door closed in his room and did not respond to staff when they knocked on his door. R156 walked independently, refused cares and PT. RN-E stated staff made several attempts to re-approach R156. As a result, R156 started to attend therapy sessions. During an interview on 2/28/13, at 11:52 a.m. RN-B stated R156, "got better and declined and regained some." The RN said R156 needed assistance three times within the assessment period on admission, therefore was coded extensive assistance in the quarterly MDS dated 2/5/13. RN-B stated the variances in the admission MDS dated 11/8/12 and quarterly MDS dated 2/5/13 were not considered a significant change in the ADLs because it reflected only one area of the assessment. RN-B stated significant	F 274		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 274	Continued From page 6 changes were an overall decline that required the interdisciplinary team to come together to revise the care plan. According to RN-B, R156 needed extensive assist upon admission therefore the interdisciplinary team did not have to come together to revise the care plan. "The team would have come together if two or more areas in the MDS assessment would have indicated R156 required extensive assistance." RN-B stated R156 met the following criteria on the admission MDS: Assistance with transfers was captured three times during admission therefore R156's MDS was coded supervision. Dressing was not captured during the admission MDS. Toilet use was captured a two on admission and the toileting component was coded as higher. The staff did not write progress notes to support the findings in the MDS assessments. In addition, RN-B indicated a flow sheet and the Resident Assessment Instrument (RAI) manual were used to assess every resident for significant changes. On 2/28/13, at 3:46 p.m. RN-B verified the interdisciplinary team did not write progress notes for significant changes. R39's diagnoses included diagnoses contributing to and resulting in fracture and immobility including osteoarthritis, femur fracture, degeneration intervertebral disc, morbid obesity, lumbosacral spondylosis, and paraplegia. A review of the NP progress note dated 2/12/13, indicated R39 had a fall on 1/7/13 with admission to the hospital for a left proximal femoral fracture. R39 returned to the facility on 1/11/13.	F 274		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 274	Continued From page 7 The admission MDS dated 11/29/12, identified R39 required extensive assist of one for transfers, was able to walk in the room with set-up, required extensive assist of one for toilet use, was occasionally incontinent of bladder and was continent of bowel. The MDS also identified R39 as having a PHQ9 (interview used to identify possible depression) of zero. The quarterly MDS dated 2/11/13, identified R39 required extensive assist of two for transfers, extensive assist of one to ambulate in the room, required extensive assist of two for toilet use, was frequently incontinent of both bowel and bladder. The MDS also identified a PHQ9 score of 11, an indicator of possible depression. A review of the Significant Change Tracking form (undated) identified a decline in mood, transferring and incontinence. When interviewed on 2/28/13, at 3:10 p.m. registered nurse (RN)-B and RN-C verified the coding on the quarterly MDS was correct. RN-B stated the interdisciplinary team would review a resident for a significant change MDS and this had not been done for R39 following the femur fracture as the MDS was "off cycle." A policy and procedure for a significant change MDS was requested, RN-B indicated the facility used the Resident Assessment Instrument (RAI) manual to determine a significant change. The RAI manual directed, "A SCSA [significant change status assessment] is appropriate if there are either two or more areas of decline or two or more areas of improvement."	F 274		
F 325	483.25(i) MAINTAIN NUTRITION STATUS	F 325		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 325 SS=D	Continued From page 8 UNLESS UNAVOIDABLE Based on a resident's comprehensive assessment, the facility must ensure that a resident - (1) Maintains acceptable parameters of nutritional status, such as body weight and protein levels, unless the resident's clinical condition demonstrates that this is not possible; and (2) Receives a therapeutic diet when there is a nutritional problem. This REQUIREMENT is not met as evidenced by: Based on interview and document review, the facility failed to ensure a therapeutic diet was provided for 1 of 3 residents (R165) in the sample who were reviewed for nutritional status. Findings include: R165's diet was not followed as ordered by the physician. R165 was admitted to the facility on 12/21/12 and discharged to another facility on 12/24/12. R165's diagnoses included dysphagia (difficulty swallowing), cerebral vascular accident (CVA), celiac disease, and small bowel obstruction. A review of the Pre-Admission Clinical Worksheet dated 12/21/12, revealed R165 had allergies listed as gluten and milk and communication status was noted as "anticipate needs." The Discharge Orders and Instructions for Patient/Family form dated 12/21/12, included an	F 325	The facility will ensure that a resident maintains acceptable parameters of nutritional status, such as body weight and protein levels unless the resident's clinical condition demonstrates that this is not possible; and receives a therapeutic diet when there is a nutritional problem. R165 discharged from the facility on 12/24/13. A new nursing foodservice communication diet order form was created and implemented on 2/28/13. All nurses were educated about the use of the new communication form by 3/21/13. The director of nursing will oversee regular audits conducted for 3 months or until ongoing compliance is achieved. Audit results will be reviewed by Quality assurance committee.	3/21/13

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 325	Continued From page 9 allergy to gluten, and a diet of dysphagia level 1 with honey thickened consistency. The Ebenezer Nursing Admission form started on 12/21/12, included an allergy to gluten. A Nursing-Foodservice Communication/Diet Order Form dated 12/21/12, included a diet texture of pureed, dysphagia level 1 with liquid consistency of honey. The communication form lacked information on R165's gluten allergy and need for lactose free foods. A progress note dated 12/22/12, indicated "daughter question the food that her mother was not getting." A progress note dated 12/23/12, indicated "is sometimes able to make needs known to staff." A progress note dated 12/23/12, at 1:59 p.m. indicated R165 vomited undigested food. According to a complaint report received 2/3/13, R165 received French toast (with gluten) for breakfast, regular green beans (not pureed), thickened milk (not lactose free) and pie (not pureed) with lunch on 12/23/12. The dietitian and dietary service director (DSD) were interviewed on 2/28/13, at 11:11 a.m. The dietitian stated regular green beans would not be served with a pureed diet, and if information regarding lactose/gluten was provided to the kitchen staff, the items would be automatically removed from the tray card. The dietitian further indicated the tray card for R165 was not entered into the tray card system until 12/25/12 (the day after R165 discharged). The dietitian and the DSD reported that the nurses would have told the kitchen verbally what tray to provide for R165.	F 325		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 325	Continued From page 10 A registered nurse (RN)-D was interviewed on 2/28/13, at 11:41 a.m. and stated he would have given the diet order form directly to the kitchen staff so the kitchen staff would know what diet to give R165 for the weekend. RN-D stated he remembered R165's daughter talking to him about R165's diet on 12/22/12. RN-D indicated he told R165's daughter he would "look into it," but did not get a chance to get back to R165's chart.	F 325		
F 329 SS=D	483.25(l) DRUG REGIMEN IS FREE FROM UNNECESSARY DRUGS Each resident's drug regimen must be free from unnecessary drugs. An unnecessary drug is any drug when used in excessive dose (including duplicate therapy); or for excessive duration; or without adequate monitoring; or without adequate indications for its use; or in the presence of adverse consequences which indicate the dose should be reduced or discontinued; or any combinations of the reasons above. Based on a comprehensive assessment of a resident, the facility must ensure that residents who have not used antipsychotic drugs are not given these drugs unless antipsychotic drug therapy is necessary to treat a specific condition as diagnosed and documented in the clinical record; and residents who use antipsychotic drugs receive gradual dose reductions, and behavioral interventions, unless clinically contraindicated, in an effort to discontinue these	F 329	The facility will ensure that each resident's drug regimen is free from unnecessary drugs. A review of R39's drug regimen was completed on 2/27/13. R39's physician was notified of the transcription error on 2/27/13. A dose reduction of Xanax was carried out for R39 on 2/27/13. All nurses were educated about the process of transcribing orders by 3/21/13. All pharmacy consults were audited by nurse management dating back to 1/2/13. Audits will be overseen by the director of nursing and will continue for 3 months or until ongoing compliance is achieved. All audits will be reported to the quality assurance committee.	3/21/13

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 329	Continued From page 11 drugs. This REQUIREMENT is not met as evidenced by: Based on interview and document review, the facility failed to ensure 1 of 3 residents (R39) reviewed for benzodiazepine (anti-anxiety) use was free from unnecessary medications. Findings include: R39's diagnoses included personality disorder, major depressive disorder and generalized anxiety disorder. The psychotropic medication care plan dated 11/25/12, indicated R39 was at risk for adverse side effects related to the use of anti-anxiety medication with a goal of R39 will take medication as ordered. An intervention of "Administer anti-anxiety medications per MD [physician] order" was included on the care plan dated 11/25/12. The consulting pharmacist wrote A Note To Attending Physician/Prescriber dated 12/7/12, noting R39 was "taking several medications with the potential to increase her risk for falls" which included Xanax (anti-anxiety). A nurse practitioner (NP) progress note dated 12/11/12, indicated R39 was taking "several medications with potential to increase risk of falls" which included Xanax. A subsequent NP note dated 1/15/13, indicated "There has been some concern that the patient's benzodiazepine use	F 329		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 329	Continued From page 12 could have increased likelihood of fall. Staff at hospital thought they were reducing alprazolam [Xanax] from 4 times a day to 3 times a day." The NP note dated 1/15/13, further indicated the alprazolam would be reduced to 0.25 milligrams (mg) twice a day and that the resident would be monitored. A Note To Attending Physician/Prescriber written by the consulting pharmacist and dated 2/6/13, showed "Resident has an order for Xanax 0.25 mg BID [twice a day] for anxiety. This was reduced on 1/15/13. If resident has tolerated this dose reduction, please consider tapering further." The Physician/Prescriber Response dated 2/12/13, indicated agreement with the recommendation and included new orders to decrease Xanax to 0.25 mg daily. Review of the 2/13 Medication Administration Record (MAR) a.m. on 2/27/13, revealed R39 received Xanax 0.25 mg two times daily from 2/12/13 to 2/26/13. When interviewed on 2/27/13, at 9:41 a.m. a registered nurse (RN)-C verified the order should have been but was not transcribed to reduce R39's Xanax, and therefore, R39 continued to receive the medication twice daily versus daily as ordered by the NP. During interview on 2/28/13, at 1:34 p.m. the director of nursing stated all physician orders should be transcribed within 24 hours of the order being received. A review of the Transcription of Physician Orders policy and procedure revised 6/2012, directed "Completion of transcription of orders, including initial transcription and 2nd check will be	F 329		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 329	Continued From page 13	F 329		
F 356 SS=C	completed within 24 hours of receiving order. " 483.30(e) POSTED NURSE STAFFING INFORMATION The facility must post the following information on a daily basis: - o Facility name. - o The current date. - o The total number and the actual hours worked by the following categories of licensed and unlicensed nursing staff directly responsible for resident care per shift: - Registered nurses. - Licensed practical nurses or licensed vocational nurses (as defined under State law). - Certified nurse aides. - o Resident census. The facility must post the nurse staffing data specified above on a daily basis at the beginning of each shift. Data must be posted as follows: - o Clear and readable format. - o In a prominent place readily accessible to residents and visitors. The facility must, upon oral or written request, make nurse staffing data available to the public for review at a cost not to exceed the community standard. The facility must maintain the posted daily nurse staffing data for a minimum of 18 months, or as required by State law, whichever is greater. This REQUIREMENT is not met as evidenced by: Based on observation, interview and document	F 356 The facility will post: the facility name, the current date, the total number and the actual hours worked by the following categories of licensed and unlicensed nursing staff directly responsible for resident care per shift: Registered nurses, licensed practical nurses or licensed vocational nurses, certified nurse aides, resident census. The facility will ensure that the posting is in a prominent place readily accessible to residents and visitors. On 2/28/13 the posting for Daily Nurses Hours was formatted to include the total number of hours worked for each category of licensed and unlicensed staff directly responsible for resident care. The posting was relocated to a wheelchair accessible height. The staffing coordinator responsible for posting this information was educated on 2/28/13. Weekly audits are conducted by the Director of Nursing. Audits will continue until ongoing compliance is achieved and reviewed by the quality assurance committee.	3/1/13	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 356	Continued From page 14 review, the facility failed to accurately post the required nurse staffing information each shift on a daily basis, as required. This practice had the potential to affect all 123 residents, family members, and visitors in the facility. Findings include: On 2/25/13, at 12:10 p.m. a form identified as Daily Nursing Hours was posted in the entry way at eye level height of a standing person. The posted nurse staff information was completed for the entire 24 hour period, was not in a readable format and was not posted in a readily accessible location for residents who sat in a wheelchair. Review of the forms provided by the facility titled Daily Nursing Hours dated 2/25/13 and 2/26/13, revealed the facility identified the date, facility census, shift, category of staff, hours from start to end, and the staffing total. The form did not identify what the various numbers written behind the categories represented, and did not include the total number of hours worked for each category of licensed and unlicensed staff directly responsible for resident care. On 2/28/13, at 1:20 p.m. the staffing coordinator (SC) confirmed the posted nursing staff information indicated the number of staff working, but did not indicate the total number of hours worked for each category of licensed and unlicensed staff directly responsible for resident care. The SC also confirmed the form was "posted too high" and that residents sitting in a wheelchair "would not be able to read it." The SC explained he had been hired in the past three months and said he learned how to complete the	F 356		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE
**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 356	Continued From page 15	F 356		
F 431 SS=D	form from his predecessor. The facility did not have a policy regarding the Daily Nursing Hours posting. 483.60(b), (d), (e) DRUG RECORDS, LABEL/STORE DRUGS & BIOLOGICALS The facility must employ or obtain the services of a licensed pharmacist who establishes a system of records of receipt and disposition of all controlled drugs in sufficient detail to enable an accurate reconciliation; and determines that drug records are in order and that an account of all controlled drugs is maintained and periodically reconciled. Drugs and biologicals used in the facility must be labeled in accordance with currently accepted professional principles, and include the appropriate accessory and cautionary instructions, and the expiration date when applicable. In accordance with State and Federal laws, the facility must store all drugs and biologicals in locked compartments under proper temperature controls, and permit only authorized personnel to have access to the keys. The facility must provide separately locked, permanently affixed compartments for storage of controlled drugs listed in Schedule II of the Comprehensive Drug Abuse Prevention and Control Act of 1976 and other drugs subject to abuse, except when the facility uses single unit package drug distribution systems in which the quantity stored is minimal and a missing dose can be readily detected.	F 431 The facility will ensure that medications with shortened use dates are properly dated after opening. On 2/25/13, per to pharmacy recommendation, LPN-A dated R54's Lantus insulin as opened on 2/1/13 which was the date of pharmacy delivery. On 2/25/13 per pharmacy recommendation, RN-A dated R32's Lantus insulin as opened on 2/12/13 which was the date of pharmacy delivery. On 2/25/13 per pharmacy recommendation, RN-A dated R32's Novolog insulin as opened on 2/16/13 which was the date of pharmacy delivery. All nurses were educated by 3/21/13 of the requirement to date shortened us medications upon opening. Weekly audits are overseen by the Director of nursing and will be reported to the quality assurance committee for 3 months or until ongoing compliance is achieved.	3/21/13	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 431	Continued From page 16 This REQUIREMENT is not met as evidenced by: Based on observation, interview and document review, the facility failed to ensure medications with shortened use dates were properly dated after opening in 2 of 6 medication carts, potentially affecting 2 of 20 residents (R54, R32) who received insulin for diabetes. Findings include: The facility's medication storage system was observed on the second floor on 2/25/13, at 1:25 p.m. in the presence of the licensed practical nurse (LPN)-A. A Lantus insulin pen was in use for R54, but was undated as to when it was opened, and had a pharmacy delivery date of 2/1/13. When interviewed LPN-A stated the Lantus insulin "was good for 28 days" and it should have been dated when opened. The third floor medication carts were inspected on 2/25/13, at 1:43 p.m. in the presence of the registered nurse (RN)-A. A Lantus insulin pen was in use for R32, with a pharmacy delivery date of 2/12/13, which was again unlabeled with the open date. In addition, a Novolog insulin pen was in use for R32, with a pharmacy delivery date of 2/16/13, which was also undated when opened. RN-A confirmed both insulin pens were undated, and explained that every insulin pen and vial needed to be dated when first used to determine the expiration date, since they were good for 28 days after opening. All three insulin pens had a label from the	F 431		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 431	Continued From page 17 pharmacy that read, "date opened/exp [expiration] date/initial." During interview on 2/28/13, at 2:15 p.m. the director of nursing (DON) stated the staff were trained and were expected to write the date on the insulin pens when they were initially used. The DON also explained, if staff forgot to date the insulin pen when opened, they were to use the delivery date as the open date. The consultant pharmacist (CP) was interviewed on 2/28/13, at 2:18 p.m. The CP stated the Novolog and Lantus insulin pens expired 28 days after opening, so the date when opened was required. The CP further explained the facility transitioned from insulin vials to pens in the past month, and staff had been trained accordingly. The manufacturer's recommendation in the Lantus package insert indicated in-use/opened insulin had to be discarded after 28 days. The Novolog package insert for storage indicated open vials and opened Novolog flex pen were to be kept at room temperature "for up to 28 days."	F 431		
F 458 SS=B	483.70(d)(1)(ii) BEDROOMS MEASURE AT LEAST 80 SQ FT/RESIDENT Bedrooms must measure at least 80 square feet per resident in multiple resident bedrooms, and at least 100 square feet in single resident rooms. This REQUIREMENT is not met as evidenced	F 458	Facility requests a waiver (attached)	3/27/13

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 458	Continued From page 18 by: Based on observation and interview, the facility failed to ensure 4 of 120 single resident rooms, measured at least 100 square feet, affecting 2 of 4 residents who occupied those rooms at the time of the survey. Findings include: The following rooms did not provide 100 square feet per resident: 1) Room 226 provided 95.62 square feet; 2) Room 228 provided 90.64 square feet; 3) Room 328 provided 96.30 square feet; and 4) Room 326 provided 90.64 square feet. The resident in private room 228s a private room. R9 was interviewed on 2/25/13, at 4:39 p.m. and stated the room size was fine, and did not pose issues related to personal items in the room. R104 resided in room 226 which was a private room, and confirmed in an interview on 2/27/13, at 8:30 a.m. had no problems with the room. None of the residents occupying the rooms offered complaints, and no problems were observed related to the delivery of care related to the size of the rooms. Rooms 328 and 326 were unoccupied by residents during the survey. The residents were all able to move about their rooms and had access to lounges and other common areas within the building. Waiting lists were an option for residents who desired a larger room. The rooms had enough space to accommodate not only the required furniture and	F 458		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 458	Continued From page 19 equipment, but also personal belongings. Neither evacuation issues or infection control issues were noted due to the smaller room sizes.	F 458		
F 465 SS=E	483.70(h) SAFE/FUNCTIONAL/SANITARY/COMFORTABL E ENVIRON The facility must provide a safe, functional, sanitary, and comfortable environment for residents, staff and the public. This REQUIREMENT is not met as evidenced by: Based on observation, interview and document review, the facility failed to ensure common areas were maintained in good order, and to ensure hallways were kept free of clutter. This had the potential to affect 70 of 123 residents who resided in the facility. Findings include: Observations during the initial tour on 2/25/13, at 12:30 p.m. and during the environmental tour on 2/28/13, at 11.00 a.m. with the administrator and housekeeping supervisor (HS), as well as resident and family interviews on 2/25/13 and 2/26/13, revealed the following concerns: During the initial tour of first floor on 2/25/13, at 1:45 p.m. the short hallway was observed to be cluttered on the first floor on the north end. Stored on the right side of the hallway was a storage cart, two chairs, a lift, a treatment cart, and a trash cart, and on the left side was a medication cart. Residents in wheelchairs were not observed using the short hallway, however,	F 465	The facility will provide a safe, functional, sanitary, and comfortable environment for residents, staff and the public. All staff were educated by 3/21/13 about the requirement to keep all carts and equipment to one side of the hall while in use to allow a clutter free environment. The wall between the sink and first stall in the unisex bathroom on 1 st floor was repaired and painted on 3/5/13. Corner guards were placed to prevent further damage. The hopper in the first floor soiled utility room was cleaned and repaired on 3/1/13 The hopper in the second floor soiled utility room was cleaned and repaired on 3/1/13 The six window seals on second floor north were painted on 2/28/13 The second stall in the common bathroom on 2nd floor was painted on 3/5/13 The doorway of the unisex bathroom on 3 rd floor was repaired and painted on 3/5/13	3/27/13

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 465	Continued From page 20 did utilize the long hall where items were not stored on both sides of the hall. Again on 2/26/13, at 9:05 a.m. the one north hallway was observed to be cluttered. A large, round gray garbage can, a medication cart, a treatment cart and a vital sign machine on a stand were all stored on the odd side of the hallway north of the nurses' station. A housekeeping cart was on the even side of the hallway across from the treatment cart. A triangular table was observed in the northeast corner of the hallway outside of room 109. The hallway north of the nurses' station was approximately 40 feet long. On 2/28/13, at 8:54 a.m. a medication cart, a treatment cart and a housekeeping cart were observed on the odd side of the hallway. The triangular table in the northeast corner of the hallway had been removed. A unisex bathroom with two stalls on the first floor used by four residents. The wall between the sink and the first stall was damaged, with paint and wall particles scraped off. Per the administrator, the damage was caused by wheelchairs and walkers. The first floor soiled utility room had a hopper with a dark reddish/black deposit and caulk missing on the base. The second floor soiled utility room also had a hopper with caulk peeling away and with dark matter deposited around the base. The second floor north hallway had six window seals with white paint chips, exposing the dark	F 465	The third floor south bathroom floor was cleaned and repaired 3/27/13. Painting needs are now included in the work-order system effective 3/10/13. Environmental audits are conducted weekly with oversight of the Administrator. All audits are reported to the quality assurance committee and will continue for 3 months or until on-going compliance is achieved.	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 465	Continued From page 21 wood. The second floor south common bathroom with two stalls used by 25 residents on the unit had paint chipping off the wall in the second stall. The third floor south unisex bathroom used by approximately 18 residents had the doorway paint chipped and scuffed on the left side. The third floor south bathroom shower floor was stained with red and black stains. The shower room was used by 24 residents. The HS stated the stain was a rust stain and the facility staff had tried to scrub it away. The administrator stated the floor in the shower room needed replacing. All of the above issues were viewed and confirmed by the administrator and HS during the environmental tour. The administrator explained the facility's staff used a work order system to communicate environmental concerns with the maintenance department. The HS stated staff cleaned the commonly used bathrooms twice daily, and concerns noted were reported to HS. The HS further explained the facility did not have a tracking system to identify issues with paint damage. When interviewed about resident safety regarding narrow and cluttered hallways, the administrator stated hallways should have been kept free of clutter, and "only the items in use at the time should be kept in the hallways, and only on one side." The administrator reported the deputy state fire marshal also expressed concern with excessive items in the hallway on the first floor. On 2/28/13, at 3:15 p.m. the administrator	F 465		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/01/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 2545 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 465	Continued From page 22 explained the maintenance staff completed random audits to identify environmental concerns; however, maintenance staff relied on the staff working on the floor to communicate issues using the work order forms. Painting needs were not identified on tracking forms, rather were verbally communicated to a vendor. The Maintenance Work Orders policy dated 3/10, indicated "Work orders for the Maintained Department must be completed and submitted via the maintenance hard copy form." The Hallway Designation for Temporary Equipment policy dated 12/03, provided by the administrator for review indicated all items in the hallway should have allowed for a safe pathway. Equipment in the hallways, including Hoyer lifts, precautions carts, medication carts, wheelchairs, and walkers had to be "actively in use." The policy also indicated, "When not in use equipment is stored in designated locations," and team leaders were responsible for compliance to assure hallways remained "uncluttered at all times."	F 465		

Ebenezer Care Center
2545 Portland Avenue
Minneapolis, MN 55404
Tel 612-879-2262
Fax 612-879-2316

March 2013

Ms. Gloria Derfus
Minnesota Department of Health
P.O. Box 64900
St. Paul, MN 55164-0900

RE: Request for Room Size Waiver for SNFs and NFs

Ebenezer Care Center requests a waiver for the following item noted during our recent annual survey:

Item Number	Justification...
F458	Residents that live in these rooms are able to move about and have access to lounges and other common areas within the building. Also at the time of admission, or any other time, the resident may be placed on a waiting list to be moved to a larger room, if they are not pleased. These rooms have enough space to accommodate not only the required furniture and equipment but also personal belongings. Care provided to the residents in these rooms has not been compromised due to room size. The residents in these rooms are able to evacuate in case of an emergency and their health and safety is not jeopardized. Also, there are no infection control problems due to the space.

Sincerely,



Joel Prevost
Administrator

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

F5587021

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/27/2013
---	---	--	---

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X6) COMPLETION DATE
K 000	INITIAL COMMENTS FIRE SAFETY THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE. UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION. A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety. At the time of this survey, Ebenezer Care Center (Building 1) was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care. PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES TO: Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR By email to:	K 000	RECEIVED MAR 28 2013 MINN. DEPT. OF PUBLIC SAFETY STATE FIRE MARSHAL DIVISION POC ok w/ FSES for K12, K38 + K40 FR 4-2-13	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X8) DATE

A deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that her safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/27/2013
---	---	--	---

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 Barbara.Lundberg@state.mn.us and Marian.Whitney@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. Ebenezer Care Center is a 3-story building with a full basement. The building was constructed at 3 different times. The original building was constructed in 1919 and was determined to be of Type III(200) construction. In 1924, an addition was constructed to the North side of the building that was determined to be of Type III(200) construction. In 1928, another addition was constructed to the South side of the building that was determined to be of Type III(200) construction. Because the original building and the 2 additions to this building are all of the same construction type, even though the Type III(200) construction type does not meet the code for existing buildings, this building was surveyed as one building, but the entire facility was surveyed as two buildings under two booklets. The building has a complete fire sprinkler system throughout. The facility has a complete fire alarm	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/27/2013
---	--	--	--

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

**2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404**

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 system with smoke detection in the corridors and spaces open to the corridor, that is monitored for automatic fire department notification. The facility has a licensed capacity of 138 beds and had a census of 123 at the time of the survey.	K 000		
K 012 SS=F	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD Building construction type and height meets one of the following. 19.1.6.2, 19.1.6.3, 19.1.6.4, 19.3.5.1 This STANDARD is not met as evidenced by: Based on observation and interview, this building does not meet the requirement for construction type and height. This deficient practice could affect all residents. Findings include: On facility tour between 9:30 AM and 12:00 PM on 02/27/2013, observation revealed that this 3-story, wood frame facility of Type III(200) construction does not meet the minimum construction requirements for a building of this height. This deficient practice was verified by the administrator at the time of the inspection. Note: This deficiency need not be corrected if an FSES can establish that the facility has an overall level of fire safety equivalent to that required by	K 012	The facility achieved a passing FSES on 3/7/13	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/27/2013
---	---	--	---

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2545 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 012	Continued From page 3 the Life Safety Code.	K 012		
K 038 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD Exit access is arranged so that exits are readily accessible at all times in accordance with section 7.1. 19.2.1 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to provide means of egress in accordance with the following requirements of 2000 NFPA 101, Section 7.2.1.5.4. The deficient practice could affect all residents: Findings include: On facility tour between 9:00 AM and 12:00 PM on 02/27/2013, observation revealed that the south stairway doors on the second and third floors swing against the path of egress travel. These deficient practices were verified by the administrator at the time of the inspection. Note: This deficiency need not be corrected if an FSES can establish that the facility has an overall level of fire safety equivalent to that required by the Life Safety Code.	K 038	The facility achieved a passing FSES on 3/7/13	
K 040 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD Exit access doors and exit doors used by health care occupants are of the swinging type and are at least 32 inches in clear width. 19.2.3.5	K 040	The facility achieved a passing FSES on 3/7/13	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/27/2013
---	---	--	---

NAME OF PROVIDER OR SUPPLIER

EBENEZER CARE CENTER

STREET ADDRESS, CITY, STATE, ZIP CODE

2546 PORTLAND AVENUE SOUTH
MINNEAPOLIS, MN 55404

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X6) COMPLETION DATE
K 040	Continued From page 4 This STANDARD is not met as evidenced by: Based on observation and interview, the resident room doors do not meet the 32-inch clear width requirement. This deficient practice could affect all residents. Findings include: On facility tour between 9:30 AM and 12:00 PM on 02/27/2013, observation revealed that the doors in the 1919 construction year building were found to be only 29-30 inches in clear width. This does not meet the 32-inch requirement for existing exit access doors. This deficient practice was verified by the administrator at the time of the inspection. Note: This deficiency need not be corrected if an FSES can establish that the fire has an overall level of fire safety equivalent to that required by the Life Safety Code.	K 040		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/18/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245587	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - BLDG TWO B. WING _____		(X3) DATE SURVEY COMPLETED 02/27/2013
NAME OF PROVIDER OR SUPPLIER EBENEZER CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 2845 PORTLAND AVENUE SOUTH MINNEAPOLIS, MN 55404		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS FIRE SAFETY A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety. At the time of this survey, Ebenezer Care Center Building 2 was found in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care. Ebenezer Care Center Building 2 is a 3-story building with a full basement. The building was constructed in 1952 and was determined to be of Type I (332) construction. The building is fully fire sprinklered throughout. The facility has a complete fire alarm system with smoke detection in the corridors and spaces open to the corridor, that is monitored for automatic fire department notification. The facility has a licensed capacity of 138 beds and had a census of 123 at the time of the survey. The requirement at 42 CFR, Subpart 483.70(a) is MET.	K 000	4-2-13		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that the safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

REPORT OF CONSULTANT FSES FINDINGS

**Ebenezer Care Center
2545 Portland Avenue South
Minneapolis, MN 55404**

Provider No. 245587

Date of Survey: March 07, 2013

Prepared by:
Robert L. Imholte, President
Fire Safety Resources, LLC
16768 County Road 160
Cold Spring, MN 56320
320-685-8559
RImholteFiresafe@aol.com

FIRE SAFETY EVALUATION

Name of Facility: Ebenezer Care Center
Address: 2545 Portland Avenue South, Minneapolis, MN 55404
Phone: 612-879-2262
Licensed capacity: 138
Census at time of survey: 120

Evaluator: Robert L. Imholte, President, *Fire Safety Resources, LLC*

What follows is a report on the findings of a fire safety evaluation of the above-named facility that was conducted during an on-site visit to the facility between 0930 hours and 1345 hours on 03/07/13. This evaluation was conducted in accordance with the Fire Safety Evaluation System (FSES) specified in Chapter 4 of NFPA 101A(01), *Guide to Alternative Approaches to Life Safety*. Based on this evaluation, Ebenezer Care Center has achieved a passing score on the FSES.

In addition to the 03/07/13 walkthrough of the facility, the findings outlined herein are based on information provided by Mr. Joel Prevost, Administrator, and a review of the draft Statement of Deficiencies from a fire/life safety recertification survey conducted on 02/27/13.

Initial Comments:

A review of the Statement of Deficiencies from a fire/life safety recertification survey conducted on 12/20/11 revealed that Ebenezer Care Center was surveyed as two buildings: Building 01 – Main Building (consisting of the 1919 original building and 1924 and 1928 additions) and Building 02 – 1952 addition. Buildings 01 and 02 are separated by construction having a fire resistance rating of at least 2 hours. Because the deficiencies that triggered the FSES were cited in Building 01 (Main Building), this FSES covers that building only.

At the east end of the building's South Wing the nursing home is connected to a business occupancy called the Annex. At the west end of the basement level of the North Wing there is a connection to an adjacent apartment building. Because neither the Annex nor the apartment building is used for purposes of housing, treatment or customary access by the facility's residents and because both are separated from the nursing home by 2-hour-rated fire barriers, those buildings were not included in this evaluation.

Building 01 (Main Building) was determined to be of Type III(200) construction based on the following:

- a. The original (Center) building was constructed in 1919 as a 3-story building with an attic and basement. This portion of the facility, constructed of masonry exterior bearing walls and wood floor/ceiling and roof assemblies was assigned a Type III(200) construction type in accordance with NFPA 220(99), Sec. 3-3 and Table 3-1 (while the floor/ceiling assemblies on the upper levels are protected by gypsum wallboard/plaster on wire mesh, the basement ceiling is of exposed wood joist construction).
- b. In 1924 a 3-story addition with an attic and basement was constructed to the north. Building construction was determined to be identical to that of the original (Center) building and was, therefore, assigned a construction type of Type III(200). In 1992 a new elevator, housed in a noncombustible shaft, was added to the north side of this wing.
- c. In 1928 a 3-story addition with an attic and basement was constructed to the south. Again, building construction was determined to be identical to that of the original (Center) building and assigned a construction type of Type III(200).

Because the original building and additions were constructed prior to 03/11/03, Ebenezer Care Center Building 01 (Main Building) is considered an existing building for federal certification purposes. The building was, therefore, treated as such for assigning values on the FSES worksheets.

With the exception of Table 8, which applies to all zones, this narrative will address each of the eleven (11) zones separately.

All Levels – TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET

In accordance with NFPA 101A(01), Sec. 4.7, Step 8, only one copy of this table is required to be filled out for each building. For convenience, however, this table was filled out on the worksheets for all zones evaluated. All items in Table 8 could be checked 'Met' with the exception of Items B and L, which were checked 'Not Applicable'. Because Ebenezer Care Center is an existing facility (Item B) and does not meet the definition of a high rise (Item L), these two items do not apply in this case. The remaining items were identified as 'Met' based on the following:

- Building utilities and heating and air conditioning systems appeared to be in conformance with applicable requirements.
 - No incinerator or space heaters were found.
 - The facility's evacuation plan and fire drill records were reviewed and appeared to be in order.
 - The facility's smoking regulations were reviewed and appeared to be in order. Ebenezer Care Center is a smoke-free building.
 - Based on review of documentation, draperies, cubicle curtains, upholstered furniture, mattresses and decorations were found to be in accordance with NFPA 101(00), Sec. 19.7.5.
 - Portable fire extinguishers, EXIT signage and emergency lighting appeared to be provided in accordance with applicable requirements.
-

Zone 1 – Basement Level Center/North:

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

1. Resident Mobility (M) [Value assigned = 3.2]: While there are no sleeping rooms in this zone, some residents in the zone may need assistance with evacuation.
2. Patient Density (D) [Value assigned = 1.0]: This level is used primarily for staff services, utilities and facility storage, but the corridor space from the north elevator to the 1952 addition (Building 02) located to the east is used on a regular basis during the day by facility residents to access the Beauty Shop and Adult Day Program located in the 1952 addition. It was reported that there are a maximum of four (4) residents in this zone at any one time.
3. Zone Location (L) [Value assigned = 1.6]: This zone is located below grade level.
4. Ratio of Patients to Attendants (T) [Value assigned = 1.0]: It was reported that there is one (1) staff person for each two (2) residents present in this zone.
5. Patient Average Age (A) [Value assigned = 1.2]: Residents using this zone average over 65 years of age.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -4]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that the exposed wood in the ceiling in the corridors and spaces open to the corridor was treated with Flame Control No. 40-40A Fire Retardant Intumescent Paint to achieve a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: -3]:
No documentation was provided proving that the exposed wood in the ceiling in some of the rooms separated from the corridor had a flame spread rating of better than Class C.

2. Interior Finish (Corridors and Exits) [Score: +3]:

Ceiling finish was found to be plaster. Wall finish was found to be brick.

3. Interior Finish (Rooms) [Score: +3]:

Wall and ceiling finish was found to be combination of gypsum and plaster.

4. Corridor Partitions/Walls [Score: +2]:

For purposes of this FSES, this zone was treated as a suite in accordance with NFPA 101(00), Sec. 19.2.5. Based on building information provided at the time of the survey, this suite is approximately 4,256 ft² in size and is separated from the corridor in the adjacent 1919 original building by a 2-hour-rated fire barrier.

5. Doors to Corridor [Score: +2]:

Again, for purposes of this FSES, this zone was treated as a suite in accordance with NFPA 101(00), Sec. 19.2.5. The door opening into the corridor in the adjacent 1919 original building was found to be a 90-minute fire-rated assembly.

6. Zone Dimensions [Score: 0]:

This score was assigned per instruction in Footnote *b* to this Table. According to building information provided, this zone measures approximately 112 feet in length and, based on actual measurements, has dead-ends in the hallway measuring approximately 30 feet in length at the east end and approximately 60 feet in length at the west end. Parameter 10, Emergency Movement Routes, is assigned a score of -8.

7. Vertical Openings [Score: 0]:

Openings into the stair enclosure in this zone were found to be protected with 90-minute fire-rated self-closing door assemblies. The loading doors into the soiled linen chute on the upper floors as well as the door into the chute termination room in this zone were also found to be 90-minute fire-rated self-closing door assemblies. The clearance under the bottom of the newly installed 90-minute fire-rated self-closing door assembly into the attic at the top of the stair enclosure serving this zone was found to exceed the $\frac{3}{4}$ -inch clearance allowed by NFPA 80(99), Sec. 1-11.4 and Table 1-11.4. This condition provides enclosure protection of less than 1 hour.

8. Hazardous Areas [Score: 0]:

No hazardous area deficiencies were found in this zone.

9. Smoke Control [Score: 0]:

A fire/smoke barrier serves this zone.

10. Emergency Movement Routes [Score: -8]:

This score was assigned for the following reasons:

- The two exits from this zone are not remotely located from each other as required by NFPA 101(00), Sections 7.5.1.3 and 7.5.1.4.
- Because of utility piping (e.g. steam and water pipes) running across the corridor, headroom at multiple locations was found to be only 73 - 75 inches instead of the 80 inches required by NFPA 101(00), Sec. 7.1.5.

11. Manual Fire Alarm [Score: +2]:

There is a manual fire alarm pull station near the exit stair enclosure serving this zone. The fire alarm system is monitored by Armor Security.

12. Smoke Detection and Alarm [Score: +3]:

This score was assigned per instruction in Footnote *g* to this Table. System-connected smoke detectors were found in the hallway and the zone is protected with quick-response sprinklers. Per the instruction in NFPA 101A(01), Sec. 4.6.12.1, however, this parameter was required to be scored as "None".

13. Automatic Sprinklers [Score: +10]:

The entire facility is protected by a supervised, wet-pipe automatic sprinkler system consisting of quick-response sprinklers.

10. Emergency Movement Routes [Score: -8]:

This score was assigned for the following reasons:

- The corridor doors on this level were found to measure only 29-30 inches in clear width. As a result, they could not be credited as an egress route [see NFPA 101A(01), Sec. 4.6.10.3.2].
- The second means of egress from the Dining Room was found to be through the adjoining Conservatory, as allowed by NFPA 101(00), Sec. 7.5.1.7, but the door from the Conservatory to the egress corridor swings against egress travel. Since the Dining room serves an occupant load of more than 50, this does not meet the requirements of NFPA 101(00), Sec. 7.2.1.4.2.

11. Manual Fire Alarm [Score: +2]:

A manual fire alarm pull station was found along the path of travel to the main exit from this level. The fire alarm system is monitored by Armor Security.

12. Smoke Detection and Alarm [Score: +3]:

This score was assigned per instruction in Footnote *g* to this Table. System-connected smoke detectors were found in the egress corridors and the zone is protected with quick-response sprinklers.

13. Automatic Sprinklers [Score: +10]:

The entire facility is protected by a supervised, wet-pipe automatic sprinkler system consisting of quick-response sprinklers.

Zone 4 – First Floor North

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

1. Resident Mobility (*M*) [Value assigned = 3.2]: It was reported that some residents in the zone may need assistance with evacuation.
2. Patient Density (*D*) [Value assigned = 2.0]: There is bed capacity for up to eighteen (18) residents in this zone. The zone also contains the facility chapel, which is available for use by all residents.
3. Zone Location (*L*) [Value assigned = 1.1]: This zone is less than one-half floor height above grade.
4. Ratio of Patients to Attendants (*T*) [Value assigned = 1.5]: It was reported that there are two staff persons attending this zone on the night shift. One staff person is assigned to make rounds of the remainder of the First Floor every 2 hours.
5. Patient Average Age (*A*) [Value assigned = 1.2]: Residents using this zone average over 65 years of age.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -2]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in corridors and exits carry a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in rooms carry a Class A (25 or less) flame spread rating.
4. Corridor Partitions/Walls [Score: +2]:
Corridor walls are constructed of a mixture of gypsum and plaster on both sides of wood studs. The Chapel was treated as a space open to the corridor as allowed by NFPA 101(00), Sec. 19.3.6.1, Exception No. 1 – it is protected by automatic fire sprinklers and automatic smoke detection.
5. Doors to Corridor [Score: +1]:
Corridor doors were found to be of 1-5/8-inch-thick solid wood construction.

Zone 5 – First Floor South

TABLE 1. OCCUPANY RISK PARAMETER FACTORS

1. Resident Mobility (*M*) [Value assigned = 1.6]: It was reported that all residents housed in this zone are capable of removing themselves from danger exclusively by their own efforts, but the rate of travel for approximately half of the residents is slowed due to mobility impairments. For this reason it was felt that these residents do not meet the definition of "Mobile".
2. Patient Density (*D*) [Value assigned = 1.5]: There is bed capacity for up to twelve (12) residents in this zone.
3. Zone Location (*L*) [Value assigned = 1.1]: This zone is less than one-half floor height above grade
4. Ratio of Patients to Attendants (*T*) [Value assigned = 4.0]: There are no staff immediately available to this zone on the night shift. It was reported that one of the two staff persons attending the North Wing makes rounds in this zone every 2 hours.
5. Patient Average Age (*A*) [Value assigned = 1.2]: Residents using this zone average over 65 years of age.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -2]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in corridors and exits carry a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in rooms carry a Class A (25 or less) flame spread rating.
4. Corridor Partitions/Walls [Score: 0]:
Corridor walls are constructed of a mixture of gypsum and plaster on both sides of wood studs. A 32" x 46" wired glass vision panel in a wood frame was found in the corridor wall at the physical therapy space. As a result, the corridor walls were graded as "<½ hour".
5. Doors to Corridor [Score: +1]:
Corridor doors were found to be of 1-5/8-inch-thick solid wood construction.
6. Zone Dimensions [Score: 0]:
This score was assigned per instruction in Footnote *b* to this Table. According to building information provided, this zone measures approximately 126 feet in length. Due to the lack of complying means of egress out of this level, a dead-end condition is created. Parameter 10, Emergency Movement Routes, was assigned a score of -8.
7. Vertical Openings [Score: 0]:
Openings into the stair enclosures, soiled linen chute and chute termination room in this zone were found to be protected with 90-minute fire-rated self-closing door assemblies. The clearance under the bottom of the newly installed 90-minute fire-rated self-closing door assembly into the attic at the top of the stair enclosure serving this zone was found to exceed the ¾-inch clearance allowed by NFPA 80(99), Sec. 1-11.4 and Table 1-11.4. This condition provides enclosure protection of less than 1 hour.
8. Hazardous Areas [Score: 0]:
Hazardous areas were found to be sprinkler protected as required by NFPA 101A(01), Sec. 4.6.8.2 and smoke-separated as required by NFPA 101(00), Sec. 19.3.2.1.
9. Smoke Control [Score: 0]:
There is a 2-hour-rated fire separation between this zone and the adjacent 1924 building.

7. Vertical Openings [Score: 0]:
This score was assigned per instruction in Footnote *e* to this Table. The stair enclosure in this zone is enclosed with construction providing a minimum 2-hour fire resistance, but Parameter 1, Construction Type, was marked "200".
 8. Hazardous Areas [Score: 0]:
Hazardous areas were found to be sprinkler protected as required by NFPA 101A(01), Sec. 4.6.8.2 and smoke-separated as required by NFPA 101(00), Sec. 19.3.2.1.
 9. Smoke Control [Score: 0]:
There are 2-hour-rated fire separations at both ends of this zone, which separate this zone from the adjacent 1924 and 1928 buildings.
 10. Emergency Movement Routes [Score: -8]:
The corridor doors on this level were found to measure only 29-30 inches in clear width. As a result, they could not be credited as an egress route [see NFPA 101A(01), Sec. 4.6.10.3.2].
 11. Manual Fire Alarm [Score: +2]:
Manual fire alarm pull stations were found along the path of travel from this zone and at the nurses' station serving the zone, which meets the intent of Exception No. 1 to NFPA 101(00), Sec. 19.3.4.2. The fire alarm system is monitored by Armor Security.
 12. Smoke Detection and Alarm [Score: +3]:
This score was assigned per instruction in Footnote *g* to this Table. System-connected smoke detectors were found in the egress corridors and the zone is protected with quick-response sprinklers.
 13. Automatic Sprinklers [Score: +10]:
The entire facility is protected by a supervised, wet-pipe automatic sprinkler system consisting of quick-response sprinklers.
-

Zone 7 – Second Floor North

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

1. Resident Mobility (*M*) [Value assigned = 3.2]: It was reported that some residents in the zone may need assistance with evacuation.
2. Patient Density (*D*) [Value assigned = 1.5]: There is bed capacity for up to fifteen (15) residents in this zone.
3. Zone Location (*L*) [Value assigned = 1.2]: This zone is one floor height above First Floor.
4. Ratio of Patients to Attendants (*T*) [Value assigned = 1.5]: It was reported that there is at least one (1) staff person assigned to this zone on the night shift resulting in a ratio of one (1) staff for over ten (10) residents.
5. Patient Average Age (*A*) [Value assigned = 1.2]: Residents using this zone average over 65 years of age.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -4]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in corridors and exits carry a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in rooms carry a Class A (25 or less) flame spread rating.

Zone 8 – Second Floor South

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

1. Resident Mobility (*M*) [Value assigned = 3.2]: It was reported that some residents in the zone may need assistance with evacuation.
2. Patient Density (*D*) [Value assigned = 1.5]: There is bed capacity for up to fifteen (15) residents in this zone.
3. Zone Location (*L*) [Value assigned = 1.2]: This zone is one floor height above First Floor.
4. Ratio of Patients to Attendants (*T*) [Value assigned = 1.5]: It was reported that there is at least one (1) staff person assigned to this zone on the night shift resulting in a ratio of one (1) staff for over ten (10) residents.
5. Patient Average Age (*A*) [Value assigned = 1.2]: Residents using this zone average over 65 years of age.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -4]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in corridors and exits carry a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in rooms carry a Class A (25 or less) flame spread rating.
4. Corridor Partitions/Walls [Score: +2]:
Corridor walls are constructed of a mixture of gypsum and plaster on both sides of wood studs. The dining/lounge area is open to the corridor as allowed by the exceptions to NFPA 101(00), Sec. 19.3.6.1.
5. Doors to Corridor [Score: +1]:
Corridor doors were found to be of 1-5/8-inch-thick solid wood construction.
6. Zone Dimensions [Score: 0]:
This score was assigned per instruction in Footnote *b* to this Table. According to building information provided, this zone measures approximately 126 feet in length and, based on actual measurement, was found to have a dead-end of approximately 45 feet in length at the east end of the corridor. Parameter 10, Emergency Movement Routes, was assigned a score of -8.
7. Vertical Openings [Score: 0]:
Openings into the stair enclosures, soiled linen chute and chute termination room in this zone were found to be protected with 90-minute fire-rated self-closing door assemblies. The clearance under the bottom of the newly installed 90-minute fire-rated self-closing door assembly into the attic at the top of the stair enclosure serving this zone was found to exceed the ¾-inch clearance allowed by NFPA 80(99), Sec. 1-11.4 and Table 1-11.4. This condition provides enclosure protection of less than 1 hour.
8. Hazardous Areas [Score: 0]:
Hazardous areas were found to be sprinkler protected as required by NFPA 101A(01), Sec. 4.6.8.2 and smoke-separated as required by NFPA 101(00), Sec. 19.3.2.1.
9. Smoke Control [Score: 0]:
There is a 2-hour-rated fire separation between this zone and the adjacent 1919 building.
10. Emergency Movement Routes [Score: -8]:
This score was assigned for the following reasons:
 - The corridor doors in this zone were found to measure only 29-30 inches in clear width. As a result, they could not be credited as an egress route [see NFPA 101A(01), Sec. 4.6.10.3.2].
 - The doors into the exit stair enclosures serving this zone swing against egress travel, which does not meet the requirements of NFPA 101(00), Sec. 7.2.1.4.3.

8. Hazardous Areas [Score: 0]:
Hazardous areas were found to be sprinkler protected as required by NFPA 101A(01), Sec. 4.6.8.2 and smoke-separated as required by NFPA 101(00), Sec. 19.3.2.1.
 9. Smoke Control [Score: 0]:
There are 2-hour-rated fire separations at both ends of this zone, which separate this zone from the adjacent 1924 and 1928 buildings.
 10. Emergency Movement Routes [Score: -8]:
The corridor doors on this level were found to measure only 29-30 inches in clear width. As a result, they could not be credited as an egress route [see NFPA 101A(01), Sec. 4.6.10.3.2].
 11. Manual Fire Alarm [Score: +2]:
Manual fire alarm pull stations were found along the path of travel and at the nurses' station serving the zone, which meets the intent of Exception No. 1 to NFPA 101(00), Sec. 19.3.4.2. The fire alarm system is monitored by Armor Security.
 12. Smoke Detection and Alarm [Score: +3]:
This score was assigned per instruction in Footnote g to this Table. System-connected smoke detectors were found in the egress corridors and the zone is protected with quick-response sprinklers.
 13. Automatic Sprinklers [Score: +10]:
The entire facility is protected by a supervised, wet-pipe automatic sprinkler system consisting of quick-response sprinklers.
-

Zone 10 – Third Floor North

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

1. Resident Mobility (*M*) [Value assigned = 3.2]: It was reported that some residents in the zone may need assistance with evacuation.
2. Patient Density (*D*) [Value assigned = 1.5]: There is bed capacity for up to fifteen (15) residents in this zone.
3. Zone Location (*L*) [Value assigned = 1.2]: This zone is two floor heights above First Floor.
4. Ratio of Patients to Attendants (*T*) [Value assigned = 1.5]: It was reported that there is at least one (1) staff person assigned to this zone on the night shift resulting in a ratio of one (1) staff for over ten (10) residents.
5. Patient Average Age (*A*) [Value assigned = 1.2]: Residents using this zone average over 65 years of age.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -9]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in corridors and exits carry a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in rooms carry a Class A (25 or less) flame spread rating.
4. Corridor Partitions/Walls [Score: +2]:
Corridor walls are constructed of a mixture of gypsum and plaster on both sides of wood studs.
5. Doors to Corridor [Score: +1]:
Corridor doors were found to be of 1-5/8-inch-thick solid wood construction.

TABLE 4. SAFETY PARAMETERS and SAFETY PARAMETER VALUES

1. Construction [Score: -9]:
The building was assigned a Type III(200) construction type.
2. Interior Finish (Corridors and Exits) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in corridors and exits carry a Class A (25 or less) flame spread rating.
3. Interior Finish (Rooms) [Score: +3]:
Documentation was provided certifying that interior wall and ceiling finishes (i.e. vinyl wall coverings and acoustical ceiling tile) in rooms carry a Class A (25 or less) flame spread rating.
4. Corridor Partitions/Walls [Score: +2]:
Corridor walls are constructed of a mixture of gypsum and plaster on both sides of wood studs. The dining/lounge area is open to the corridor as allowed by the exceptions to NFPA 101(00), Sec. 19.3.6.1.
5. Doors to Corridor [Score: +1]:
Corridor doors were found to be of 1-5/8-inch-thick solid wood construction.
6. Zone Dimensions [Score: 0]:
This score was assigned per Instruction in Footnote *b* to this Table. According to building information provided, this zone measures approximately 126 feet in length and, based on actual measurement, was found to have a dead-end of approximately 40 feet in length at the east end of the corridor. Parameter 10, Emergency Movement Routes, was assigned a score of -8.
7. Vertical Openings [Score: 0]:
Openings into the stair enclosures, soiled linen chute and chute termination room in this zone were found to be protected with 90-minute fire-rated self-closing door assemblies. The clearance under the bottom of the newly installed 90-minute fire-rated self-closing door assembly into the attic at the top of the stair enclosure serving this zone was found to exceed the 3/4-inch clearance allowed by NFPA 80(99), Sec. 1-11.4 and Table 1-11.4. This condition provides enclosure protection of less than 1 hour.
8. Hazardous Areas [Score: 0]:
Hazardous areas were found to be sprinkler protected as required by NFPA 101A(01), Sec. 4.6.8.2 and smoke-separated as required by NFPA 101(00), Sec. 19.3.2.1.
9. Smoke Control [Score: 0]:
There is a 2-hour-rated fire separation between this zone and the adjacent 1919 building.
10. Emergency Movement Routes [Score: -8]:
This score was assigned for the following reasons:
 - The corridor doors in this zone were found to measure only 29-30 inches in clear width. As a result, they could not be credited as an egress route [see NFPA 101A(01), Sec. 4.6.10.3.2].
 - The doors into the exit stair enclosures serving this zone swing against egress travel, which does not meet the requirements of NFPA 101(00), Sec. 7.2.1.4.3.
11. Manual Fire Alarm [Score: +2]:
There is a manual fire alarm pull station at the nurses' station, which meets the intent of Exception No. 1 to NFPA 101(00), Sec. 19.3.4.2. The fire alarm system is monitored by Armor Security.
12. Smoke Detection and Alarm [Score: +3]:
This score was assigned per instruction in Footnote *g* to this Table. System-connected smoke detectors were found in the egress corridors and the zone is protected with quick-response sprinklers.
13. Automatic Sprinklers [Score: +10]:
The entire facility is protected by a supervised, wet-pipe automatic sprinkler system consisting of quick-response sprinklers.

ZONE 1 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>BASEMENT - CENTER/NORTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	<u>1.0</u>	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	<u>1.6</u>
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>≥10</u> 1	<u>One or More</u> None
	Risk Factor	<u>1.0</u>	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK	M	D	L	T	A	F
	<u>3.2</u>	<u>1.0</u>	<u>1.6</u>	<u>1.0</u>	<u>1.2</u>	<u>6.1</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<u>6.1</u>	<u>6.1</u>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<u>6.1</u>	<u>3.7</u>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. Vinko</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point-value.

TABLE 4.								
Safety Parameters		Safety Parameters Values						
1. Construction		Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone		000	111	200	211 + 2HH	000	111	222, 332, 433
First		-2	0	-2	0	0	2	2
Second		-7	-2	(-4)	-2	-2	2	4
Third		-9	-7	-9	-7	-7	2	4
4th and Above		-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)		Class C -5(0) ^f	Class B 0(3) ^f	Class A (3)				
3. Interior Finish (Rooms)		Class C (-3(0)) ^f	Class B 1(3) ^f	Class A 3				
4. Corridor Partitions/Walls		None or Incomplete -10(0) ^a	<1/2 hour 0	≥1/2 to <1 hour 1(0) ^a	≥1 hour (2)(0) ^a			
5. Doors to Corridor		No Door -10	<20 min FPR 0	≥20 min FPR (1)(0) ^d	≥20 min FPR and Auto Clos. 2(0) ^d			
6. Zone Dimensions		Dead End			No Dead Ends >30 ft and Zone Length Is			
		>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft	
		-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	(0)	1	
7. Vertical Openings		Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.				
				<1 hr	≥1 hr to <2 hr	≥2 hr		
		-14	-10	(0)	2(0) ^e	3(0) ^e		
8. Hazardous Areas		Double Deficiency		Single Deficiency		No Deficiencies		
		In Zone	Outside Zone	In Zone	In Adjacent Zone			
		-11	-5	-6	-2	(0)		
9. Smoke Control		No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone				
		-5(0) ^c	(0)	3				
10. Emergency Movement Routes		<2 Routes	Multiple Routes					
			Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)		
		-8	(-2)	0	1	5		
11. Manual Fire Alarm		No Manual Fire Alarm		Manual Fire Alarm				
				W/O F.D. Conn.	W/F.D. Conn			
		-4		1	(2)			
12. Smoke Detection and Alarm		None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone		
		0(3) ^g	2(3) ^g	3(3) ^g	4	5		
13. Automatic Sprinklers		None	Corridor and Habit. Space	Entire Building				
		0	8	(10)				

- NOTE:** ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

- ^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

- ^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

- ^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-4	-4		-4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	-3			-3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-2	-2
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 9$	$S_2 = 11$	$S_3 = 10$	$S_4 = 12$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	⑨	17(14) ^a	⑥	10(7) ^a	③
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 9 - 9 = 0	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 11 - 6 = 5	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 10 - 3 = 7	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 12 - 4 = 8	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			
	Met	Not Met	Not Applic.
A. Building utilities conform to the requirements of Section 9.1.	✓		
B. In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.			✓
C. Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓		
D. Fuel-burning space heaters and portable electrical space heaters are not used.	✓		
E. There are no flue-fed incinerators.	✓		
F. An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓		
G. Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓		
H. Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓		
I. Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓		
J. Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓		
K. Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓		
L. Standpipes are provided in all new high rise buildings as required by 18.4.2.			✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 2 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>BASEMENT-SOUTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
1. Patient Mobility (M)	Risk Factor	1.0	1.6	3.2	4.5	
	No. of Patients	1-5	6-10	11-30	>30	
2. Patient Density (D)	Risk Factor	1.0	1.2	1.5	2.0	
	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
3. Zone Location (L)	Risk Factor	1.1	1.2	1.4	1.6	1.6
	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
4. Ratio of Patients to Attendants (T)	Risk Factor	1.0	1.1	1.2	1.5	4.0
	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
5. Patient Average Age (A)	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK $\frac{M}{\square} \times \frac{D}{\square} \times \frac{L}{\square} \times \frac{T}{\square} \times \frac{A}{\square} = \frac{F}{\square}$						
$\square \times \square \times \square \times \square \times \square = 1.6$						

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)	
$1.0 \times \frac{F}{\square} = \frac{R}{\square}$	

TABLE 3B. (EXISTING BUILDINGS)	
$0.6 \times \frac{F}{\square} = \frac{R}{\square}$	

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert L. Smith</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	(-4)	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ⁱ	0(3) ⁱ		(3)				
3. Interior Finish (Rooms)	Class C	Class B		Class A				
	-3(1) ⁱ	1(3) ⁱ		(3)				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		≥1/2 to <1 hour	≥1 hour			
	-10(0) ^a	0		1(0) ^a	(2)(0) ^a			
5. Doors to Corridor	No Door	<20 min FPR		≥20 min FPR	≥20 min FPR and Auto Clos.			
	-10	0		1(0) ^d	(2)(0) ^d			
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors		Enclosed with Indicated Fire Resist.				
	-14	-10		<1 hr	≥1 hr to <2 hr	≥2 hr		
				(0)	2(0) ^e	3(0) ^e		
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2				
9. Smoke Control	No Control	Smoke Barrier Serves Zone		Mech. Assisted Systems by Zone				
	-5(0) ^c	(0)		3				
10. Emergency Movement Routes	<2 Routes	Multiple Routes						
	(8)	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn.				
			1	(2)				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces in Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	(10)					

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients
(existing buildings only)

^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

ⁱ Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-4	-4		-4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	2		2	2
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 16$	$S_2 = 11$	$S_3 = 5$	$S_4 = 13$

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	9	17(14) ^a	6	10(7) ^a	3
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values *set* shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 16 - 9 = 7	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 11 - 6 = 5	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 5 - 3 = 2	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 13 - 1 = 12	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			
	Met	Not Met	Not Applic.
A. Building utilities conform to the requirements of Section 9.1.	✓		
B. In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.			✓
C. Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓		
D. Fuel-burning space heaters and portable electrical space heaters are not used.	✓		
E. There are no flue-fed incinerators.	✓		
F. An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓		
G. Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓		
H. Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓		
I. Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓		
J. Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓		
K. Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓		
L. Standpipes are provided in all new high rise buildings as required by 18.4.2.			✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

ZONE 3 OF 11 ZONES

2000 LIFE SAFETY CODE

FACILITY <u>EDENEZER CARE CENTERS</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>FIRST FLOOR CENTER</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	<u>1.6</u>	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	<u>2.0</u>	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	<u>1.1</u>	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>≥10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	<u>4.0</u>
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK	<u>M</u>	<u>D</u>	<u>L</u>	<u>T</u>	<u>A</u>	<u>F</u>
	<u>1.6</u>	<u>2.0</u>	<u>1.1</u>	<u>4.0</u>	<u>1.2</u>	<u>16.9</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)	
F	R
1.0 X <u>16.9</u>	= <u>16.9</u>

TABLE 3B. (EXISTING BUILDINGS)	
F	R
0.6 X <u>16.9</u>	= <u>10.1</u>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. White</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish (Rooms)	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		≥1/2 to <1 hour	≥1 hour			
	-10(0) ^a	0		1(0) ^a	2(0) ^a			
5. Doors to Corridor	No Door	<20 min FPR		≥20 min FPR	≥20 min FPR and Auto Clos.			
	-10	0		1(0) ^d	2(0) ^d			
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	≥1 hr to <2 hr	≥2 hr			
	-14	-10	0	2(0) ^a	3(0) ^a			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2				
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c		3					
		0						
10. Emergency Movement Routes	<2 Routes	Multiple Routes						
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn.				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients
(existing buildings only)

^d Use (0) where parameter 4 is -10.

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-2	-2		-2
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 17$	$S_2 = 13$	$S_3 = 4$	$S_4 = 14$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	⑤	15(12) ^a	④	8(5) ^a	①
2 nd or 3 rd story ^b	15	9	17(14) ^a	6	10(7) ^a	3
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_c)	≥ 0	$S_1 - S_a = C$ 17 - 5 = 12	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 13 - 4 = 9	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 4 - 1 = 3	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 14 - 11 = 3	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

ZONE 4 OF 11 ZONES

2000 LIFE SAFETY CODE

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>FIRST FLOOR NORTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
1. Patient Mobility (M)	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	<u>2.0</u>	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	<u>1.1</u>	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
	Risk Factor	1.0	1.1	1.2	<u>1.5</u>	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK	<u>M</u>	<u>D</u>	<u>L</u>	<u>T</u>	<u>A</u>	<u>F</u>
	<u>3.2</u>	<u>2.0</u>	<u>1.1</u>	<u>1.5</u>	<u>1.2</u>	<u>12.1</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
1.0 X	<u>F</u>	<u>R</u>
	<u>12.1</u>	<u>12.1</u>

TABLE 3B. (EXISTING BUILDINGS)		
0.6 X	<u>F</u>	<u>R</u>
	<u>12.1</u>	<u>7.6</u>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. Emballe</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

Safety Parameters	Safety Parameters Values						
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	(-2)	0	0	2	2
Second	-7	-2	-4	-2	-2	2	4
Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C -5(0) ^f	Class B 0(3) ^f	Class A (3)				
3. Interior Finish (Rooms)	Class C -3(1) ^f	Class B 1(3) ^f	Class A (3)				
4. Corridor Partitions/Walls	None or Incomplete -10(0) ^a	<1/2 hour 0	≥1/2 to <1 hour 1(0) ^a		≥1 hour (2)(0) ^a		
5. Doors to Corridor	No Door -10	<20 min FPR 0	≥20 min FPR (1)(0) ^d		≥20 min FPR and Auto Clos. 2(0) ^d		
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is		
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft	<100 ft
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^c	0	1
7. Vertical Openings	Open 4 or More Floors -14	Open 2 or 3 Floors -10	Enclosed with Indicated Fire Resist.				
			<1 hr 0		≥1 hr to <2 hr 2(0) ^c		≥2 hr 3(0) ^c
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone	Outside Zone	In Zone	In Adjacent Zone			
	-11	-5	-6	-2	(0)		
9. Smoke Control	No Control -5(0) ^c	Smoke Barrier Serves Zone (0)	Mech. Assisted Systems by Zone 3				
10. Emergency Movement Routes	<2 Routes (-8)	Multiple Routes					
		Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5		
11. Manual Fire Alarm	No Manual Fire Alarm -4		Manual Fire Alarm				
			W/O F.D. Conn. 1	W/F.D. Conn. (2)			
12. Smoke Detection and Alarm	None 0(3) ^c	Corridor Only 2(3) ^c	Rooms Only 3(3) ^c	Corridor and Habit. Spaces 4	Total Spaces In Zone 5		
13. Automatic Sprinklers	None 0	Corridor and Habit. Space 8	Entire Building (10)				

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-2	-2		-2
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 17$	$S_2 = 13$	$S_3 = 4$	$S_4 = 14$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	⑤	15(12) ^a	④	8(5) ^a	①
2 nd or 3 rd story ^b	15	9	17(14) ^a	6	10(7) ^a	3
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values *set* shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 17 - 5 = 12	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 13 - 4 = 9	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 4 - 1 = 3	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 14 - 8 = 6	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET

Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One or more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 5 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01 - MAIN BUILDING</u>
ZONE(S) EVALUATED <u>FIRST FLOOR SOUTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE, WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	<u>1.6</u>	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	<u>1.5</u>	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	<u>1.1</u>	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>>10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	<u>4.0</u>
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK $\frac{M}{1.6} \times \frac{D}{1.5} \times \frac{L}{1.1} \times \frac{T}{4.0} \times \frac{A}{1.2} = \frac{F}{12.7}$						

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	$\frac{F}{12.7}$	$\frac{R}{1.0}$

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	$\frac{F}{12.7}$	$\frac{R}{1.6}$

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. Imbelle</u>	TITLE <u>FIRE SAFETY RESOURCES, LLC</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters		Safety Parameters Values						
1. Construction		Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433	
First	-2	0	(-2)	0	0	2	2	
Second	-7	-2	-4	-2	-2	2	4	
Third	-9	-7	-9	-7	-7	2	4	
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)		Class C -5(0) ^f	Class B 0(3) ^f	Class A (3)				
3. Interior Finish (Rooms)		Class C -3(1) ^f	Class B 1(3) ^f	Class A (3)				
4. Corridor Partitions/Walls		None or Incomplete -10(0) ^g	<1/2 hour (0)	≥1/2 to <1 hour 1(0) ^g	≥1 hour 2(0) ^g			
5. Doors to Corridor		No Door -10	<20 min FPR 0	≥20 min FPR (10) ^d	≥20 min FPR and Auto Clos. 2(0) ^d			
6. Zone Dimensions		Dead End			No Dead Ends >30 ft and Zone Length Is			
	>100 ft -6(0) ^b	>50 ft to 100 ft -4(0) ^b	30 ft to 50 ft -2(0) ^b	>150 ft -2(0) ^e	100 ft to 150 ft 0	<100 ft 1		
7. Vertical Openings		Open 4 or More Floors -14	Open 2 or 3 Floors -10	Enclosed with Indicated Fire Resist.				
				<1 hr (0)	≥1 hr to <2 hr 2(0) ^g	≥2 hr 3(0) ^g		
8. Hazardous Areas		Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone -11	Outside Zone -5		In Zone -6	In Adjacent Zone -2		(0)	
9. Smoke Control		No Control -5(0) ^c	Smoke Barrier Serves Zone (0)	Mech. Assisted Systems by Zone 3				
10. Emergency Movement Routes		<2 Routes (-8)	Multiple Routes					
			Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5		
11. Manual Fire Alarm		No Manual Fire Alarm -4		Manual Fire Alarm				
				W/O F.D. Conn. 1	W/F.D. Conn. (2)			
12. Smoke Detection and Alarm		None 0(3) ^g	Corridor Only 2(3) ^g	Rooms Only 3(3) ^g	Corridor and Habit. Spaces 4	Total Spaces In Zone 5		
13. Automatic Sprinklers		None 0	Corridor and Habit. Space 8	Entire Building (10)				

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients
(existing buildings only)

^d Use (0) where parameter 4 is -10.

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-2	-2		-2
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	0			0
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 15$	$S_2 = 13$	$S_3 = 4$	$S_4 = 12$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	⑤	15(12) ^a	④	8(5) ^a	①
2 nd or 3 rd story ^b	15	9	17(14) ^a	6	10(7) ^a	3
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values *set* shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_c)	≥ 0	$S_1 - S_c = C$ $15 - 5 = 10$	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ $13 - 4 = 9$	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_a)	≥ 0	$S_3 - S_a = P$ $4 - 1 = 3$	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ $12 - 8 = 4$	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

FACILITY EBENEZER CARE CENTER BUILDING 01-MAIN BUILDING
ZONE(S) EVALUATED SECOND FLOOR CENTER
PROVIDER/VENDOR NO. 245587 DATE OF SURVEY 03/07/13

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	<u>1.5</u>	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	<u>1.2</u>	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>≥10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	<u>1.5</u>	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	<u>3.2</u>	<u>1.5</u>	<u>1.2</u>	<u>1.5</u>	<u>1.2</u>	<u>10.4</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)	
F	R
1.0 X <u> </u>	= <u> </u>

TABLE 3B. (EXISTING BUILDINGS)	
F	R
0.6 X <u>10.4</u>	= <u>6.2</u> ≈ 7

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE Robert J. Smith TITLE PRESIDENT DATE 03/12/13
FIRE AUTHORITY SIGNATURE [Signature] TITLE Fire Safety Supervisor DATE 4-2-13
Form CMS-2788T (06/07) EF 06/2007 Page 1

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.							
Safety Parameters	Safety Parameters Values						
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	(-4)	-2	-2	2	4
Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C -5(0) ^a	Class B 0(3) ^a	Class A (3)				
3. Interior Finish (Rooms)	Class C -3(1) ^a	Class B 1(3) ^a	Class A (3)				
4. Corridor Partitions/Walls	None or Incomplete -10(0) ^a	<½ hour 0	≥½ to <1 hour 1(0) ^a	≥1 hour (2)(0) ^a			
5. Doors to Corridor	No Door -10	<20 min FPR 0	≥20 min FPR (1)(0) ^d	≥20 min FPR and Auto Clos. 2(0) ^d			
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1	
7. Vertical Openings	Open 4 or More Floors -14	Open 2 or 3 Floors -10	Enclosed with Indicated Fire Resist.				
			<1 hr 0	≥1 hr to <2 hr 2(0) ^a	≥2 hr 3(0) ^a		
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone -11	Outside Zone -5	In Zone -6	In Adjacent Zone -2	(0)		
9. Smoke Control	No Control -5(0) ^c	Smoke Barrier Serves Zone (0)	Mech. Assisted Systems by Zone 3				
10. Emergency Movement Routes	<2 Routes (-8)	Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5		
11. Manual Fire Alarm	No Manual Fire Alarm -4		Manual Fire Alarm				
			W/O F.D. Conn. 1	W/F.D. Conn. (2)			
12. Smoke Detection and Alarm	None 0(3) ^a	Corridor Only 2(3) ^a	Rooms Only 3(3) ^a	Corridor and Habit. Spaces 4	Total Spaces In Zone 5		
13. Automatic Sprinklers	None 0	Corridor and Habit. Space 8	Entire Building (10)				

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients
(existing buildings only)

^d Use (0) where parameter 4 is -10.

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-4	-4		-4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 15$	$S_2 = 11$	$S_3 = 4$	$S_4 = 12$

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	⑨	17(14) ^a	⑥	10(7) ^a	③
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values *set* shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 15 - 9 = 6	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 11 - 6 = 5	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 4 - 3 = 1	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 12 - 7 = 5	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 7 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>ERENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>SECOND FLOOR NORTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	<u>1.5</u>	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	<u>1.2</u>	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>≥10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	<u>1.5</u>	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION

	M	D	L	T	A	F
OCCUPANCY RISK	<u>3.2</u>	<u>1.5</u>	<u>1.2</u>	<u>1.5</u>	<u>1.2</u>	= <u>10.4</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)

F	R
1.0 X	=

TABLE 3B. (EXISTING BUILDINGS)

F	R
0.6 X <u>10.4</u>	= <u>6.2</u> = 7

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. Smith</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

Safety Parameters	Safety Parameters Values						
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	(-4)	-2	-2	2	4
Thrd	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C -5(0) ⁱ	Class B 0(3) ⁱ	Class A (3)				
3. Interior Finish (Rooms)	Class C -3(1) ⁱ	Class B 1(3) ⁱ	Class A (3)				
4. Corridor Partitions/Walls	None or Incomplete -10(0) ^a	<1/2 hour 0	≥1/2 to <1 hour 1(0) ^a		≥1 hour (2)(0) ^a		
5. Doors to Corridor	No Door -10	<20 min FPR 0	≥20 min FPR (1)(0) ^a		≥20 min FPR and Auto Clos. 2(0) ^a		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1	
7. Vertical Openings	Open 4 or More Floors -14	Open 2 or 3 Floors -10	Enclosed with Indicated Fire Resist.				
			<1 hr 0	≥1 hr to <2 hr 2(0) ^b		≥2 hr 3(0) ^a	
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone	Outside Zone	In Zone	In Adjacent Zone			
	-11	-5	-6	-2	(0)		
9. Smoke Control	No Control -5(0) ^c	Smoke Barrier Serves Zone (0)	Mech. Assisted Systems by Zone 3				
10. Emergency Movement Routes	<2 Routes (-8)	Multiple Routes					
		Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5		
11. Manual Fire Alarm	No Manual Fire Alarm -4		Manual Fire Alarm				
			W/O F.D. Conn. 1	W/F.D. Conn. (2)			
12. Smoke Detection and Alarm	None 0(3) ^d	Corridor Only 2(3) ^d	Rooms Only 3(3) ^d	Corridor and Habl. Spaces 4	Total Spaces In Zone 5		
13. Automatic Sprinklers	None 0	Corridor and Habit. Space 8	Entire Building (10)				

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients (existing buildings only)

^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

ⁱ Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^d Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-4	-4		-4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 15$	$S_2 = 11$	$S_3 = 4$	$S_4 = 12$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	⑨	17(14) ^a	⑥	10(7) ^a	③
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 15 - 9 = 6	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 11 - 6 = 5	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 4 - 3 = 1	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 12 - 7 = 5	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

ZONE 8 OF 11 ZONES

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>SECOND FLOOR SOUTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	<u>1.5</u>	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	<u>1.2</u>	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>≥10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	<u>1.5</u>	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	<u>3.2</u>	<u>1.5</u>	<u>1.2</u>	<u>1.5</u>	<u>1.2</u>	= <u>10.4</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)	
F	R
1.0 X <u> </u>	= <u> </u>

TABLE 3B. (EXISTING BUILDINGS)	
F	R
0.6 X <u>10.4</u>	= <u>6.2</u> = 7

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. Vinkler</u>	TITLE <u>FIRE SAFETY RESOURCES, LLC</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.							
Safety Parameters	Safety Parameters Values						
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	(-4)	-2	-2	2	4
Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C -5(0) ^a	Class B 0(3) ^a	Class A (3)				
3. Interior Finish (Rooms)	Class C -3(1) ^a	Class B 1(3) ^a	Class A (3)				
4. Corridor Partitions/Walls	None or Incomplete -10(0) ^a	<1/2 hour 0	≥1/2 to <1 hour (1)(0) ^a		≥1 hour (2)(0) ^a		
5. Doors to Corridor	No Door -10	<20 min FPR 0	≥20 min FPR (1)(0) ^d		≥20 min FPR and Auto Clos. 2(0) ^d		
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is		
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft	<100 ft
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^c	0	1
7. Vertical Openings	Open 4 or More Floors -14	Open 2 or 3 Floors -10	Enclosed with Indicated Fire Resist.				
			<1 hr (0)		≥1 hr to <2 hr 2(0) ^a		≥2 hr 3(0) ^a
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone	Outside Zone	In Zone	In Adjacent Zone			
	-11	-5	-6	-2	(0)		
9. Smoke Control	No Control -5(0) ^a	Smoke Barrier Serves Zone (0)	Mech. Assisted Systems by Zone 3				
10. Emergency Movement Routes	<2 Routes (-8)	Multiple Routes					
		Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5		
11. Manual Fire Alarm	No Manual Fire Alarm -4		Manual Fire Alarm				
			W/O F.D. Conn. 1	W/F.D. Conn. (2)			
12. Smoke Detection and Alarm	None 0(3) ^a	Corridor Only (2)(3) ^b	Rooms Only 3(3) ^b	Corridor and Habit. Spaces 4	Total Spaces In Zone 5		
13. Automatic Sprinklers	None 0	Corridor and Habit. Space 8	Entire Building (10)				

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients (existing buildings only)

^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^b Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^c Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-4	-4		-4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 15$	$S_2 = 11$	$S_3 = 4$	$S_4 = 12$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	9	17(14) ^a	6	10(7) ^a	3
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_1 , S_2 , and S_3 in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_1)	≥ 0	$S_1 - S_a = C$ 15 - 9 = 6	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_2)	≥ 0	$S_2 - S_b = E$ 11 - 6 = 5	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_3)	≥ 0	$S_3 - S_c = P$ 4 - 3 = 1	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 12 - 7 = 5	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 9 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>THIRD FLOOR CENTER</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile		Limited Mobility		Not Mobile
	Risk Factor	1.0		1.6		(3.2)
2. Patient Density (D)	No. of Patients	1-5		6-10		11-30
	Risk Factor	1.0		1.2		(1.5)
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	(1.2)	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
	Risk Factor	1.0	1.1	1.2	(1.5)	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			(1.2)	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	(3.2)	(1.5)	(1.2)	(1.5)	(1.2)	= (10.4)

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)	
F	R
1.0 X	□ = □

TABLE 3B. (EXISTING BUILDINGS)	
F	R
0.6 X	(10.4) = (6.2) = 7

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert L. Smith</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.

TABLE 4.							
Safety Parameters		Safety Parameters Values					
1. Construction		Combustible Types III, IV, and V				NonCombustible Types I and II	
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	-4	-2	-2	2	4
Thlrđ	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)		Class C -5(0) ^f	Class B 0(3) ^f	Class A 3			
3. Interior Finish (Rooms)		Class C -3(1) ^f	Class B 1(3) ^f	Class A 3			
4. Corridor Partitions/Walls		None or Incomplete -10(0) ^g	<1/2 hour 0	≥1/2 to <1 hour 1(0) ^g	≥1 hour 2(0) ^g		
5. Doors to Corridor		No Door -10	<20 min FPR 0	≥20 min FPR 1(0) ^d	≥20 min FPR and Auto Clos. 2(0) ^d		
6. Zone Dimensions		Dead End				No Dead Ends >30 ft and Zone Length Is	
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1	
7. Vertical Openings		Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.			
	-14	-10	0	<1 hr	≥1 hr to <2 hr	≥2 hr	
					2(0) ^e	3(0) ^e	
8. Hazardous Areas		Double Deficiency		Single Deficiency		No Deficiencies	
	In Zone	Outside Zone	In Zone	In Adjacent Zone			
	-11	-5	-6	-2		0	
9. Smoke Control		No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone			
	-5(0) ^e	0	3				
10. Emergency Movement Routes		<2 Routes	Multiple Routes				
	8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)		
		-2	0	1	5		
11. Manual Fire Alarm		No Manual Fire Alarm		Manual Fire Alarm			
	-4		W/O F.D. Conn.	W/F.D. Conn			
			1	2			
12. Smoke Detection and Alarm		None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone	
	0(3) ^g	2(3) ^g	3(3) ^g	4	5		
13. Automatic Sprinklers		None	Corridor and Habit. Space	Entire Building			
	0	8	10				

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients
(existing buildings only)

^d Use (0) where parameter 4 is -10.

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-9	-9		-9
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 10$	$S_2 = 6$	$S_3 = 4$	$S_4 = 7$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exlst.	New	Exlst.	New	Exlst.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	⑨	17(14) ^a	⑥	10(7) ^a	③
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 10 - 9 = 1	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 6 - 6 = 0	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 4 - 3 = 1	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 7 - 7 = 0	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 10 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>EBENEZER CARE CENTER</u>	BUILDING <u>01 - MAIN BUILDING</u>
ZONE(S) EVALUATED <u>THIRD FLOOR NORTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	<u>1.5</u>	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	<u>1.2</u>	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>>10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	<u>1.5</u>	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK	M	D	L	T	A	F
	<u>3.2</u>	<u>1.5</u>	<u>1.2</u>	<u>1.5</u>	<u>1.2</u>	<u>10.4</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<u>10.4</u>	<u>10.4</u>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<u>10.4</u>	<u>6.2</u>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert J. Smith</u>	TITLE <u>FIRE SAFETY RESOURCES, LLC</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.

TABLE 4.							
Safety Parameters	Safety Parameters Values						
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	-4	-2	-2	2	4
Third	-8	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C -5(0) ^a	Class B 0(3) ^a	Class A 3				
3. Interior Finish (Rooms)	Class C -3(1) ^a	Class B 1(3) ^a	Class A 3				
4. Corridor Partitions/Walls	None or Incomplete -10(0) ^a	<1/2 hour 0	≥1/2 to <1 hour 1(0) ^a		≥1 hour 2(0) ^a		
5. Doors to Corridor	No Door -10	<20 min FPR 0	≥20 min FPR 1(0) ^a		≥20 min FPR and Auto Clos. 2(0) ^a		
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length is		
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1	
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.				
	-14	-10	<1 hr 0	≥1 hr to <2 hr 2(0) ^a	≥2 hr 3(0) ^a		
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone	Outside Zone	In Zone	In Adjacent Zone			
	-11	-5	-6	-2	0		
9. Smoke Control	No Control -5(0) ^c	Smoke Barrier Serves Zone 0	Mech. Assisted Systems by Zone 3				
10. Emergency Movement Routes	<2 Routes -8	Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5		
11. Manual Fire Alarm	No Manual Fire Alarm -4		Manual Fire Alarm				
			W/O F.D. Conn. 1	W/F.D. Conn. 2			
12. Smoke Detection and Alarm	None 0(3) ^a	Corridor Only 2(3) ^a	Rooms Only 3(3) ^a	Corridor and Habit. Spaces 4	Total Spaces In Zone 5		
13. Automatic Sprinklers	None 0	Corridor and Habit. Space 8	Entire Building 10				

NOTE: ^a Use (0) where parameter 5 is -10.

^b Use (0) where parameter 10 is -8.

^c Use (0) on floor with fewer than 31 patients
(existing buildings only)

^d Use (0) where parameter 4 is -10.

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

¹ Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

⁹ Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-9	-9		-9
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 10$	$S_2 = 6$	$S_3 = 4$	$S_4 = 7$

**TABLE 6.
MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)**

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	⑨	17(14) ^a	⑥	10(7) ^a	③
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_c)	≥ 0	$S_1 - S_c = C$ 10 - 9 = 1	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 6 - 6 = 0	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_a)	≥ 0	$S_3 - S_a = P$ 4 - 3 = 1	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 7 - 7 = 0	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET			
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met
A.	Building utilities conform to the requirements of Section 9.1.	✓	
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓	
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓	
E.	There are no flue-fed incinerators.	✓	
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓	
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓	
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓	
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓	
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓	
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓	
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 11 OF 11 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY <u>ERENEZER CARE CENTER</u>	BUILDING <u>01-MAIN BUILDING</u>
ZONE(S) EVALUATED <u>THIRD FLOOR SOUTH</u>	
PROVIDER/VENDOR NO. <u>245587</u>	DATE OF SURVEY <u>03/07/13</u>

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	<u>1.5</u>	2.0	
3. Zone Location (L)	Floor	1 st	2 nd or 3 rd	4 th to 6 th	7 th and Above	Basements
	Risk Factor	1.1	<u>1.2</u>	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	<u>1-2</u> 1	<u>3-5</u> 1	<u>6-10</u> 1	<u>≥10</u> 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	<u>1.5</u>	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	<u>3.2</u>	<u>1.5</u>	<u>1.2</u>	<u>1.5</u>	<u>1.2</u>	<u>10.4</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table 3B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<u>10.4</u>	<u>10.4</u>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<u>10.4</u>	<u>6.2</u>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke barriers.

SURVEYOR SIGNATURE <u>Robert V. Smith</u>	TITLE <u>PRESIDENT</u>	DATE <u>03/12/13</u>
FIRE AUTHORITY SIGNATURE <u>[Signature]</u>	TITLE <u>State Fire Marshal</u>	DATE <u>4-2-13</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

- A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

Safety Parameters	Safety Parameters Values						
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II		
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	-4	-2	-2	2	4
Third	-9	-7	-9 ^c	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C -5(0) ^f		Class B 0(3) ^f		Class A 3		
3. Interior Finish (Rooms)	Class C -3(1) ^f		Class B 1(3) ^f		Class A 3		
4. Corridor Partitions/Walls	None or Incomplete -10(0) ^a		<1/2 hour 0		≥1/2 to <1 hour 1(0) ^a		≥1 hour 2(0) ^a
5. Doors to Corridor	No Door -10		<20 min FPR 0		≥20 min FPR 1(0) ^d		≥20 min FPR and Auto Clos. 2(0) ^d
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is		
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft	<100 ft
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^e	0	1
7. Vertical Openings	Open 4 or More Floors -14		Open 2 or 3 Floors -10		Enclosed with Indicated Fire Resist.		
					<1 hr 0	≥1 hr to <2 hr 2(0) ^a	≥2 hr 3(0) ^a
8. Hazardous Areas	Double Deficiency			Single Deficiency		No Deficiencies	
	In Zone		Outside Zone		In Zone		In Adjacent Zone
	-11		-5		-6		-2
9. Smoke Control	No Control -5(0) ^c		Smoke Barrier Serves Zone 0		Mech. Assisted Systems by Zone 3		
10. Emergency Movement Routes	<2 Routes -8		Multiple Routes				
			Deficient -2	W/O Horizontal Exit(s) 0	Horizontal Exit(s) 1	Direct Exit(s) 5	
11. Manual Fire Alarm	No Manual Fire Alarm -4			Manual Fire Alarm			
				W/O F.D. Conn. 1	W/F.D. Conn. 2		
12. Smoke Detection and Alarm	None 0(3) ^a		Corridor Only 2(3) ^a		Rooms Only 3(3) ^a		Corridor and Habit. Spaces 4
							Total Spaces In Zone 5
13. Automatic Sprinklers	None 0		Corridor and Habit. Space 8		Entire Building 10		

NOTE:

- ^a Use (0) where parameter 5 is -10.
- ^b Use (0) where parameter 10 is -8.
- ^c Use (0) on floor with fewer than 31 patients (existing buildings only)
- ^d Use (0) where parameter 4 is -10.
- ^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
- ^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
- ^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations – Use Table 5.

- Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- Add the four columns, keeping in mind that any negative numbers deduct.
- Transfer the resulting total values for S_1 , S_2 , S_3 , S_4 to blocks labeled S_1 , S_2 , S_3 , S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS				
Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	-9	-9		-9
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			-8	-8
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		3	3	3
13. Automatic Sprinklers	10	10	$10 \div 2 = 5$	10
Total Value	$S_1 = 10$	$S_2 = 6$	$S_3 = 4$	$S_4 = 7$

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)						
Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12) ^a	4	8(5) ^a	1
2 nd or 3 rd story ^b	15	(9)	17(14) ^a	(6)	10(7) ^a	(3)
4 th story or higher	18	9	19(16) ^a	6	11(8) ^a	3

- Use () in zones that do not contain patient sleeping rooms.
- For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- Transfer the three circled values from Table 6 to the blocks marked S_a , S_b , and S_c in Table 7.
- For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S_1)	minus	Mandatory Containment (S_a)	≥ 0	$S_1 - S_a = C$ 10 - 9 = 1	✓	
Extinguishment Safety (S_2)	minus	Mandatory Extinguishment (S_b)	≥ 0	$S_2 - S_b = E$ 6 - 6 = 0	✓	
People Movement Safety (S_3)	minus	Mandatory People Movement (S_c)	≥ 0	$S_3 - S_c = P$ 4 - 3 = 1	✓	
General Safety (S_4)	minus	Occupancy Risk (R)	≥ 0	$S_4 - R = G$ 7 - 7 = 0	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET

Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.		Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.	✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.			✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.	✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.	✓		
E.	There are no flue-fed incinerators.	✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.	✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.	✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.	✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.	✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.	✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.	✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.			✓

CONCLUSIONS

- ☒ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*.*
- ☐ One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*.*

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.