



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered

April 9, 2026

Administrator
Park View Care Center
200 PARK LANE
BUFFALO, MN 55313

RE: CCN: 245474

Cycle Start Date: March 31, 2026

Dear Administrator:

On March 31, 2026, a survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be isolated deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level D), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

ELECTRONIC PLAN OF CORRECTION (ePoC)

Within **ten (10) calendar days** after your receipt of this notice, you must submit an acceptable ePOC for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

The state agency may, in lieu of an onsite revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417);
- Civil money penalty (42 CFR 488.430 through 488.444).
- Termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

DEPARTMENT CONTACT

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Travis Z. Ahrens
State Fire Safety Supervisor
Health Care & Correctional Facilities
MN Department of Public Safety-Fire Marshal Division
445 Minnesota St., Suite 145
St. Paul, MN 55101
Email: travis.ahrens@state.mn.us
Web: www.sfm.dps.mn.gov
Cell: 1-507-308-4189

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by **June 30, 2026** (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by **September 30, 2026** (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

INFORMAL DISPUTE RESOLUTION (IDR)

In accordance with 42 CFR 488.331 and Minnesota Statute 144A.10 subd 15, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to: <https://forms.web.health.state.mn.us/form/NHDisputeResolution>

This request must be sent within the same ten calendar days you have for submitting an ePoC for the cited deficiencies. Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

A copy of the Department's informal dispute resolution policies is posted on the MDH Information Bulletin website at: https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04_8.html

INDEPENDENT INFORMAL DISPUTE RESOLUTION (INDEPENDENT IDR)

In accordance with 42 CFR § 488.431 and Minnesota Statute 144A.10 subd 16, when a CMP subject to being collected and placed in an escrow account is imposed, you have one opportunity to question cited deficiencies through an Independent IDR process. You may also contest scope and severity assessments for deficiencies which resulted in a finding of SQC or immediate jeopardy. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to: <https://forms.web.health.state.mn.us/form/NHDisputeResolution>

A facility may not use both IDR and independent IDR for the same deficiency citation(s) arising from the same survey unless the IDR process was completed prior to the imposition of the CMP. This request must be sent within ten calendar days of receipt of this offer. An incomplete Independent IDR process will not delay the effective date of any enforcement action.

Feel free to contact me if you have questions.

Sincerely,



Holly Zahler, Compliance Analyst

Federal Enforcement | Health Regulation Division

Minnesota Department of Health

625 Robert Street North

P.O. Box 64975

St. Paul, MN 55164-0899

Office: 651-201-4384 | Email: holly.zahler@state.mn.us

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245474		(X2) MULTIPLE CONSTRUCTION A. BUILDING B. WING		(X3) DATE SURVEY COMPLETED 03/31/2026	
NAME OF PROVIDER OR SUPPLIER Park View Health Care Center				STREET ADDRESS, CITY, STATE, ZIP CODE 200 PARK LANE , BUFFALO, Minnesota, 55313			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
E0000	Initial Comments On 3/30/26 to 3/31/26, a survey for compliance with CFR §483.73, Appendix Z, Emergency Preparedness Requirements was conducted during a standard recertification survey. The facility was IN compliance. The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that the facility acknowledge receipt of the electronic documents.		E0000				
F0000	INITIAL COMMENTS On 3/30/26 to 3/31/26, a federal recertification survey was conducted using the Risk-Based Survey (RBS) process at your facility. Your facility was IN compliance with §42 CFR 483, Subpart B, Requirements for Long Term Care Facilities. The following complaints were reviewed: H54749581C (MN110720), H54749580C (iQIES #2685382), H54749560C (iQIES #2734461). NO deficiencies were cited. The facility is enrolled in ePOC, therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, the facility must acknowledge receipt of the electronic documents.		F0000				

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See reverse for further instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245474		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 0... B. WING		(X3) DATE SURVEY COMPLETED 04/01/2026	
NAME OF PROVIDER OR SUPPLIER Park View Care Center				STREET ADDRESS, CITY, STATE, ZIP CODE 200 PARK LANE , BUFFALO, Minnesota, 55313			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
K0000	INITIAL COMMENTS FIRE SAFETY An annual Life Safety recertification survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division on 04/01/2026. At the time of this survey, Park View Care Center was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99, Health Care Facilities Code. THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE. UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION. PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO: IF PARTICIPATING IN THE E-POC PROCESS, A PAPER COPY OF THE PLAN OF CORRECTION IS NOT REQUIRED. Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR By email to: FM.HC.Inspections@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:		K0000			04/20/2026	

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See reverse for further instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE		TITLE	(X6) DATE
---	--	-------	-----------

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245474		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 0... B. WING		(X3) DATE SURVEY COMPLETED 04/01/2026	
NAME OF PROVIDER OR SUPPLIER Park View Care Center				STREET ADDRESS, CITY, STATE, ZIP CODE 200 PARK LANE , BUFFALO, Minnesota, 55313			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE	
K0000	Continued from page 1 1. A detailed description of the corrective action taken or planned to correct the deficiency. 2. Address the measures that will be put in place to ensure the deficiency does not reoccur. 3. Indicate how the facility plans to monitor future performance to ensure solutions are sustained. 4. Identify who is responsible for the corrective actions and monitoring of compliance. 5. The actual or proposed date for completion of the remedy. Park View Care Center is a 1-story building with a partial basement. The building was constructed at four different times. The original building was constructed in 1961 and was determined to be of Type II(111) construction. In 1968, an addition was constructed to the northeast and was determined to be of Type II(111) construction. In 1979, an addition was constructed to the northwest and was determined to be of Type II(111) construction. In 2007 an addition was added to the southeast of the facility and was determined to be of Type II(111) construction. All buildings have been surveyed as one. The facility has a capacity of 92 beds and had a census of 80 at the time of the survey. The requirements at 42 CFR, Subpart 483.70(a), are NOT MET as evidenced by:		K0000				
K0930 SS = D Bldg. 01	Gas Equipment - Liquid Oxygen Equipment CFR(s): NFPA 101 Gas Equipment - Liquid Oxygen Equipment The storage and use of liquid oxygen in base reservoir containers and portable containers comply with sections 11.7.2 through 11.7.4 (NFPA 99). 11.7 (NFPA 99) This STANDARD is NOT MET as evidenced by: Based on observation and staff interview, the facility failed to safely store liquid oxygen per NFPA 99 (2012 edition), Health Care Facilities Code, section 11.7.4. This deficient finding could have an isolated impact on the residents within the facility.		K0930	This Plan of Correction constitutes my written allegation of compliance for the deficiencies cited. However, submission of this Plan of Correction is not an admission that a deficiency exists or that one was cited correctly. The Plan of Correction is submitted to meet requirements established by State and Federal law. K0930 D The identified resident will have tubing reattached to their liquid oxygen tank to ensure it is not considered as being stored. The facility will complete a facility-wide audit to identify proper storage of oxygen tanks. The facility will educate nurse staff about attaching tubing to all in-use oxygen tanks.		05/11/2026	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTIONS		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245474		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 0... B. WING		(X3) DATE SURVEY COMPLETED 04/01/2026	
NAME OF PROVIDER OR SUPPLIER Park View Care Center				STREET ADDRESS, CITY, STATE, ZIP CODE 200 PARK LANE , BUFFALO, Minnesota, 55313			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K0930 SS = D Bldg. 01	Continued from page 2 Findings include: On 04/01/2026 at 12:32 PM, it was revealed by observation that in resident room 215 there was a liquid oxygen container being stored in the room. An interview with the Maintenance Director verified this deficient finding at the time of discovery.			K0930	Continued from page 2 The facility will monitor for compliance using a weekly audit for 5 weeks and escalate the results for review aby the QAPI committee. The date the deficiency will be correct will be May 11th, 2026		