

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: 1LQ0

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00762

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245579		3. NAME AND ADDRESS OF FACILITY (L3) ESSENTIA HEALTH GRACE HOME			4. TYPE OF ACTION: <u>7</u> (L8)	
2.STATE VENDOR OR MEDICAID NO. (L2) 030525100		(L4) 116 WEST SECOND STREET			1. Initial 3. Termination 5. Validation 7. On-Site Visit	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		(L5) GRACEVILLE, MN (L6) 56240			2. Recertification 4. CHOW 6. Complaint 9. Other	
6. DATE OF SURVEY 07/14/2016 (L34)		7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)			8. Full Survey After Complaint	
8. ACCREDITATION STATUS: <u> </u> (L10)		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA			FISCAL YEAR ENDING DATE: (L35)	
0 Unaccredited 1 TJC 2 AOA 3 Other		02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF			09/30	
11. LTC PERIOD OF CERTIFICATION		03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC				
From (a) : To (b) :		04 SNF 08 OPT/SP 12 RHC 16 HOSPICE				
12.Total Facility Beds 45 (L18)		10.THE FACILITY IS CERTIFIED AS:				
13.Total Certified Beds 45 (L17)		X A. In Compliance With			And/Or Approved Waivers Of The Following Requirements: _____	
		Program Requirements _____ 2. Technical Personnel			6. Scope of Services Limit	
		Compliance Based On:			7. Medical Director	
		_____ 1. Acceptable POC			8. Patient Room Size	
		B. Not in Compliance with Program			9. Beds/Room	
		Requirements and/or Applied Waivers: * Code: A* (L12)				
14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS	
18 SNF	18/19 SNF	19 SNF	ICF	IID	1861 (e) (1) or 1861 (j) (1): (L15)	
	45					
(L37)	(L38)	(L39)	(L42)	(L43)		

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE Kimberly Swenson, DSFM	Date : 07/14/2016	18. STATE SURVEY AGENCY APPROVAL Kate JohnsTon, Program Specialist	Date: 08/24/2016
	(L19)		(L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____	
<input checked="" type="checkbox"/> 1. Facility is Eligible to Participate <input type="checkbox"/> 2. Facility is not Eligible (L21)					
22. ORIGINAL DATE OF PARTICIPATION 07/08/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		26. TERMINATION ACTION: (L30)	
		24. LTC AGREEMENT ENDING DATE (L25)		VOLUNTARY <u>00</u> INVOLUNTARY	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS		01-Merger, Closure 02-Dissatisfaction W/ Reimbursement 03-Risk of Involuntary Termination 04-Other Reason for Withdrawal	
		A. Suspension of Admissions: (L44)		05-Fail to Meet Health/Safety 06-Fail to Meet Agreement	
		B. Rescind Suspension Date: (L45)		OTHER 07-Provider Status Change 00-Active	
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 03001 (L28)		30. REMARKS	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE 08/11/2016 (L33)		DETERMINATION APPROVAL	



Protecting, Maintaining and Improving the Health of All Minnesotans

CMS Certification Number (CCN): 245579
August 24, 2017

Ms. Julie Rosenberg, Administrator
Essentia Health Grace Home
116 West Second Street
Graceville, MN 56240

Dear Ms. Rosenberg:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective July 11, 2016 the above facility is certified for or recommended for:

45 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 45 skilled nursing facility beds located in rooms .

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Essentia Health Grace Home

August 24, 2017

Page 2

Sincerely,

A handwritten signature in black ink, appearing to read "Kate Johnston". The signature is fluid and cursive, with a long horizontal flourish extending to the right.

Kate JohnsTon, Program Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
kate.johnston@state.mn.us
Telephone: (651) 201-3992 Fax: (651) 215-9697



cc: Licensing and Certification File



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered
August 15, 2016

Mr. Kevin Gish, Administrator
Essentia Health Grace Home
116 West Second Street
Graceville, MN 56240

RE: Project Number S5579026, F5579026

Dear Mr. Gish:

On June 23, 2016, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on June 14, 2016. This survey found the most serious deficiencies to be isolated deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level D) whereby corrections were required.

On July 14, 2016, the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on June 16, 2016. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of July 11, 2016. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on June 14, 2016, effective July 11, 2016 and therefore remedies outlined in our letter to you dated June 23, 2016, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Minnesota Department of Health
Kamala.Fiske-Downing@state.mn.us
Telephone: (651) 201-4112

POST-CERTIFICATION REVISIT REPORT

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 245579	MULTIPLE CONSTRUCTION A. Building 01 - MAIN BUILDING 01 B. Wing	DATE OF REVISIT 7/14/2016
NAME OF FACILITY ESSENTIA HEALTH GRACE HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240	

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction, that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # NFPA 101	Completed	Reg. # NFPA 101	Completed	Reg. # NFPA 101	Completed
LSC K0038	06/28/2016	LSC K0052	06/24/2016	LSC K0069	07/11/2016
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	

REVIEWED BY STATE AGENCY <input type="checkbox"/>	REVIEWED BY (INITIALS) SR/kfd	DATE 8/15/2016	SIGNATURE OF SURVEYOR 34764	DATE 7/14/2016
REVIEWED BY CMS RO <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	TITLE	DATE
FOLLOWUP TO SURVEY COMPLETED ON 6/14/2016		<input type="checkbox"/> CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY? <input type="checkbox"/> YES <input type="checkbox"/> NO		

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 1LQ0

Facility ID: 00762

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245579		3. NAME AND ADDRESS OF FACILITY (L3) ESSENTIA HEALTH GRACE HOME			4. TYPE OF ACTION: <u>2</u> (L8)	
2. STATE VENDOR OR MEDICAID NO. (L2) 030525100		(L4) 116 WEST SECOND STREET			1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)			FISCAL YEAR ENDING DATE: (L35) 09/30	
6. DATE OF SURVEY 06/16/2016 (L34)		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE				
8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other		10. THE FACILITY IS CERTIFIED AS: A. In Compliance With Program Requirements Compliance Based On: <u> </u> 1. Acceptable POC X B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: B* (L12)			And/Or Approved Waivers Of The Following Requirements: <u> </u> 2. Technical Personnel <u> </u> 6. Scope of Services Limit <u> </u> 3. 24 Hour RN <u> </u> 7. Medical Director <u> </u> 4. 7-Day RN (Rural SNF) <u> </u> 8. Patient Room Size <u> </u> 5. Life Safety Code <u> </u> 9. Beds/Room	
11. LTC PERIOD OF CERTIFICATION From (a): To (b):		12. Total Facility Beds 45 (L18) 13. Total Certified Beds 45 (L17)				
14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS	
18 SNF 18/19 SNF 19 SNF ICF IID					1861 (e) (1) or 1861 (j) (1): (L15)	
(L37) (L38) (L39) (L42) (L43)						

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE Tammy Williams, HFE NEII	Date : 06/30/2016 (L19)	18. STATE SURVEY AGENCY APPROVAL <i>Mark Meath, Enforcement Specialist</i>	Date: 08/03/2016 (L20)
---	-----------------------------------	---	----------------------------------

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY <u>X</u> 1. Facility is Eligible to Participate <u> </u> 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : <u> </u>	
22. ORIGINAL DATE OF PARTICIPATION 07/08/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		24. LTC AGREEMENT ENDING DATE (L25)	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)			
26. TERMINATION ACTION: (L30)		VOLUNTARY <u>00</u> 01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement 03-Risk of Involuntary Termination OTHER 04-Other Reason for Withdrawal 07-Provider Status Change 00-Active			
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 03001 (L28)		30. REMARKS (L31)	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE (L33)			
DETERMINATION APPROVAL					



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered
June 23, 2016

Mr. Kevin Gish, Administrator
Essentia Health Grace Home
116 West Second Street
Graceville, Minnesota 56240

RE: Project Number S5579026, F5579026

Dear Mr. Gish:

On June 16, 2016, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs. This survey found the most serious deficiencies in your facility to be isolated deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level D), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

**Gail Anderson, Unit Supervisor
Fergus Falls Survey Team
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health**

Email: gail.anderson@state.mn.us

Phone: (218) 332-5140

Fax: (218) 332-5196

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by July 24, 2016, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;

- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

The state agency may, in lieu of a revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by September 14, 2016 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original

Essentia Health Grace Home

June 23, 2016

Page 5

statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by December 14, 2016 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Fire Safety Supervisor
Health Care Fire Inspections
Minnesota Department of Public Safety
State Fire Marshal Division

Email: tom.linhoff@state.mn.us
Telephone: (651) 430-3012
Fax: (651) 215-0525


Essentia Health Grace Home

June 23, 2016

Page 6

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath". The signature is written in a cursive style with a horizontal line underlining the first name.

Mark Meath, Enforcement Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health

Email: mark.meath@state.mn.us

Telephone: (651) 201-4118

Fax: (651) 215-9697

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/11/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 06/16/2016
--	---	--	---

NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>Essentia Health Grace Home has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.</p> <p>The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.</p>	F 000		
-------	---	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 06/23/2016
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/11/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/16/2016
NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 000	Continued From page 1	F 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/11/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/16/2016
NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	Continued From page 2 The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Electronic submission of the POC will be used as verification of compliance.	F 000			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2016
FORM APPROVED
OMB NO. 0938-0391

75579024

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 06/14/2016
--	---	---	---

NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ON-SITE REVISIT MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division. At the time of this survey, Essentia Health - Grace Home was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St Paul, MN 55101-5145, or</p>	K 000		
-------	--	-------	--	--



LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 06/29/2016
--	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 06/14/2016
NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>By email to: Marian.Whitney@state.mn.us <mailto:Marian.Whitney@state.mn.us> and Angela.Kappenman@state.mn.us <mailto:Angela.Kappenman@state.mn.us></p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency <p>Essentia Health - Grace Home is a 1-story building with no basement. The building was constructed at 2 different times. The original building was constructed in 1976 and was determined to be of Type II(111) construction. In 1998, 3 additions were added to the southeast, northeast and northwest that were determined to be of Type II(111) construction. Because the original building and the addition meet the construction types allowed for existing buildings, the facility was surveyed as one building.</p> <p>The building is protected by a complete fire sprinkler system. The facility has a fire alarm system with smoke detection by the smoke barrier doors and spaces open to the corridor that is monitored for automatic fire department notification. The facility has a licensed capacity of 45 beds and had a census of 36 at the time of the</p>	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 06/14/2016
NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 survey.	K 000		
K 038 SS=D	The requirement at 42 CFR Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD Exit access is arranged so that exits are readily accessible at all times in accordance with section 7.1. 19.2.1 This STANDARD is not met as evidenced by: Exit access is arranged so that exits are readily accessible at all times in accordance with section 7.1. 19.2.1 Findings include: On the facility tour between 9:00 am to 11:30 am on 06/14/2016, observations and staff interview revealed the exterior walking surface at the exit of the North Wing exceeded the allowable height difference before a bevel or ramp is required.	K 038	A new cement walking surface was installed on 6/28/16 at the exit of the North wing so there is no height difference. Tom Montonye, Maintenance Supervisor, will be responsible to see that the work is completed. The repair information will be submitted to the Safety Committee and Quality Assurance Performance Improvement Committee for review.	6/28/16
K 052 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system required for life safety shall be, tested, and maintained in accordance with NFPA 70 National Electric Code and NFPA 72 National Fire Alarm Code and records kept readily available. The system shall have an approved maintenance and testing program complying with applicable requirement of NFPA 70 and 72. 9.6.1.4, 9.6.1.7, This STANDARD is not met as evidenced by: A fire alarm system required for life safety shall be, tested, and maintained in accordance with NFPA 70 National Electric Code and NFPA 72 National Fire Alarm Code and records kept readily available. The system shall have an approved maintenance and testing program	K 052	The Smoke detectors in dietary storage, physical therapy, central linen, Kitchen Manager's office, and therapeutic room were moved on 6/24/16 so they are at least 3 feet away from air supply or return vent.	6/24/16

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/30/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245579	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 06/14/2016
NAME OF PROVIDER OR SUPPLIER ESSENTIA HEALTH GRACE HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 116 WEST SECOND STREET GRACEVILLE, MN 56240		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 052	Continued From page 3 complying with applicable requirement of NFPA 70 and 72. 9.6.1.4, 9.6.1.7, Findings include: On the facility tour between 9:00 am to 11:30 am on 06/14/2016, observation revealed, that the following smoke detectors were placed with-in 3 feet of air supply or return vent: 1. Dietary Storage 2. Physical Therapy 3. Central Linen 4. Kitchen Manager Office 5. Therapeutic Room	K 052	Tom Montonye, Maintenance Supervisor, will be responsible to see that the work was completed. The repair information will be submitted to the Safety Committee and the Quality Assurance Performance Improvement Committee for review.		
K 069 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Cooking facilities are protected in accordance with 9.2.3. 19.3.2.6, NFPA 96 This STANDARD is not met as evidenced by: Cooking facilities are protected in accordance with 9.2.3. 19.3.2.6, NFPA 96 Findings include: On the facility tour between 9:00 am to 11:30 am on 06/14/2016, during the review of all available documentation for the kitchen hood ventilation system inspection reports the facility could not provide any documentation showing that the kitchen hood/ventilation system has been completely cleaned and professionally inspected during the last 12 month time period.	K 069	The kitchen hood/ventilation system will be professionally cleaned and inspected on 7/11/16. Tom Montonye, Maintenance Supervisor, will be responsible to see that the work was completed. The repair information will be submitted to the Safety Committee and the Quality Assurance Performance Improvement Committee for review.	7/11/16	