

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 1ZF4
Facility ID: 00259

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245170 2.STATE VENDOR OR MEDICAID NO. (L2) 616845105	3. NAME AND ADDRESS OF FACILITY (L3) FAIRVIEW UNIVERSITY TRANS SERV (L4) 2450 RIVERSIDE AVENUE SOUTH (L5) MINNEAPOLIS, MN (L6) 55454	4. TYPE OF ACTION: <u>7</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint															
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9) 6. DATE OF SURVEY 12/14/2015 (L34) 8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other	7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE	FISCAL YEAR ENDING DATE: (L35) 12/31															
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) : 12.Total Facility Beds 28 (L18) 13.Total Certified Beds 28 (L17)	10.THE FACILITY IS CERTIFIED AS: X A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements <u> </u> 2. Technical Personnel <u> </u> 6. Scope of Services Limit Compliance Based On: <u> </u> 3. 24 Hour RN <u> </u> 7. Medical Director <u> </u> 1. Acceptable POC <u> </u> 4. 7-Day RN (Rural SNF) <u> </u> 8. Patient Room Size <u> </u> 5. Life Safety Code <u> </u> 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: A (L12)																
14. LTC CERTIFIED BED BREAKDOWN <table style="width:100%; border: none;"> <tr> <td style="text-align: center;">18 SNF</td> <td style="text-align: center;">18/19 SNF</td> <td style="text-align: center;">19 SNF</td> <td style="text-align: center;">ICF</td> <td style="text-align: center;">IID</td> </tr> <tr> <td style="text-align: center;">28</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;">(L37)</td> <td style="text-align: center;">(L38)</td> <td style="text-align: center;">(L39)</td> <td style="text-align: center;">(L42)</td> <td style="text-align: center;">(L43)</td> </tr> </table>	18 SNF	18/19 SNF	19 SNF	ICF	IID	28					(L37)	(L38)	(L39)	(L42)	(L43)	15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)	
18 SNF	18/19 SNF	19 SNF	ICF	IID													
28																	
(L37)	(L38)	(L39)	(L42)	(L43)													
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):																	
17. SURVEYOR SIGNATURE <u>Kathy Sass ,HPR Dietary Specialist</u> 12/29/2015 (L19)	18. STATE SURVEY AGENCY APPROVAL Date: <u>Kamala Fiske-Downing, Enforcement Specialist</u> 12/29/2015 (L20)																

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY <u> </u> 1. Facility is Eligible to Participate <u> </u> 2. Facility is not Eligible (L21)	20. COMPLIANCE WITH CIVIL RIGHTS ACT: _____	21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____
22. ORIGINAL DATE OF PARTICIPATION 07/11/1969 (L24)	23. LTC AGREEMENT BEGINNING DATE (L41)	24. LTC AGREEMENT ENDING DATE (L25)
25. LTC EXTENSION DATE: (L27)	27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)	
28. TERMINATION DATE:	29. INTERMEDIARY/CARRIER NO. 03001 (L28)	30. REMARKS _____
31. RO RECEIPT OF CMS-1539 (L32)	32. DETERMINATION OF APPROVAL DATE (L33) DETERMINATION APPROVAL	



CMS Certification Number (CCN): 245170

December 29, 2015

Ms. Caroline Portoghese, Administrator
Fairview University Trans Services
2450 Riverside Avenue South
Minneapolis, MN 55454

Dear Ms. Portoghese:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective November 24, 2015 the above facility is certified for:

28 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 28 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Health Regulation Division
Kamala.Fiske-Downing@state.mn.us
Telephone: (651) 201-4112 Fax: (651) 215-9697

cc: Licensing and Certification File



December 29, 2015

Ms. Caroline Portoghese, Administrator
Fairview University Trans Serv
2450 Riverside Avenue South
Minneapolis, MN 55454

RE: Project Number S5170024

Dear Ms. Portoghese:

On November 12, 2015, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on November 5, 2015. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On December 14, 2015, the Minnesota Department of Health completed a Post Certification Revisit (PCR) and on December 7, 2015 the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on November 5, 2015. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of November 24, 2015. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on November 5, 2015, effective November 24, 2015 and therefore remedies outlined in our letter to you dated November 12, 2015, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Enclosed is a copy of the Post Certification Revisit Form, (CMS-2567B) from this visit.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
Kamala.Fiske-Downing@state.mn.us
Telephone: (651) 201-4112 Fax: (651) 215-9697

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245170	(Y2) Multiple Construction A. Building B. Wing	(Y3) Date of Revisit 12/14/2015
Name of Facility FAIRVIEW UNIVERSITY TRANS SERV	Street Address, City, State, Zip Code 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix F0156	Correction Completed 11/24/2015	ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed
Reg. # 483.10(b)(5) - (10), 483.10(t)		Reg. # _____		Reg. # _____	
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed
Reg. # _____		Reg. # _____		Reg. # _____	
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed
Reg. # _____		Reg. # _____		Reg. # _____	
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed
Reg. # _____		Reg. # _____		Reg. # _____	
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed	ID Prefix _____	Correction Completed
Reg. # _____		Reg. # _____		Reg. # _____	
LSC _____		LSC _____		LSC _____	

Reviewed By _____	Reviewed By GD/kfd	Date: 12/29/2015	Signature of Surveyor: 18623	Date: 12/14/2015
Reviewed By _____	Reviewed By	Date:	Signature of Surveyor:	Date:
CMS RO				

Followup to Survey Completed on: 11/5/2015	Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? <table style="float: right; margin-left: 20px;"> <tr> <td>YES</td> <td>NO</td> </tr> </table>	YES	NO
YES	NO		

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245170	(Y2) Multiple Construction A. Building 01 - MAIN BUILDING 01 B. Wing	(Y3) Date of Revisit 12/7/2015
Name of Facility FAIRVIEW UNIVERSITY TRANS SERV	Street Address, City, State, Zip Code 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix _____ Reg. # NFPA 101 LSC K0020	Correction Completed 11/23/2015	ID Prefix _____ Reg. # NFPA 101 LSC K0050	Correction Completed 11/24/2015	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

Reviewed By _____ State Agency	Reviewed By TL/kfd	Date: 12/29/2015	Signature of Surveyor: 28120	Date: 12/7/2015
Reviewed By _____ CMS RO	Reviewed By	Date:	Signature of Surveyor:	Date:

Followup to Survey Completed on: 11/5/2015	Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? <table style="float: right;"> <tr> <td>YES</td> <td>NO</td> </tr> </table>	YES	NO
YES	NO		



December 29, 2015

Ms. Caroline Portoghese, Administrator
Fairview University Trans Serv
2450 Riverside Avenue South
Minneapolis, MN 55454

Re: Enclosed Reinspection Results - Project Number S5170024

Dear Ms. Portoghese:

On December 14, 2015 survey staff of the Minnesota Department of Health, Licensing and Certification Program completed a reinspection of your facility, to determine correction of orders found on the survey completed on December 14, 2015. At this time these correction orders were found corrected and are listed on the attached Revisit Report Form.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,

A handwritten signature in black ink that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
Kamala.Fiske-Downing@state.mn.us
Telephone: (651) 201-4112 Fax: (651) 215-9697

Enclosure(s)

cc: Original - Facility
Licensing and Certification File

State Form: Revisit Report

(Y1) Provider / Supplier / CLIA / Identification Number 00259	(Y2) Multiple Construction A. Building B. Wing	(Y3) Date of Revisit 12/14/2015
---	---	---

Name of Facility FAIRVIEW UNIVERSITY TRANS SERV	Street Address, City, State, Zip Code 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
---	--

This report is completed by a State surveyor to show those deficiencies previously reported that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the State Survey Report (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix <u>21426</u> Reg. # <u>MN St. Statute 144A.04 Su</u> LSC _____	Correction Completed <u>12/07/2015</u>	ID Prefix <u>21800</u> Reg. # <u>MN St. Statute 144.651 Sub</u> LSC _____	Correction Completed <u>11/24/2015</u>
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

Reviewed By _____ State Agency	Reviewed By GD/kfd	Date: 12/29/2015	Signature of Surveyor: 18623	Date: 12/14/2015
Reviewed By _____ CMS RO	Reviewed By	Date:	Signature of Surveyor:	Date:

Followup to Survey Completed on: 11/5/2015	Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? YES NO
--	---

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 1ZF4
Facility ID: 00259

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245170
2. STATE VENDOR OR MEDICAID NO. (L2) 616845105
3. NAME AND ADDRESS OF FACILITY (L3) FAIRVIEW UNIVERSITY TRANS SERV (L4) 2450 RIVERSIDE AVENUE SOUTH (L5) MINNEAPOLIS, MN (L6) 55454
4. TYPE OF ACTION: 2 (L8)
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)
6. DATE OF SURVEY 11/05/2015 (L34)
7. PROVIDER/SUPPLIER CATEGORY 02 (L7)
8. ACCREDITATION STATUS: (L10)
10. THE FACILITY IS CERTIFIED AS:
11. LTC PERIOD OF CERTIFICATION
12. Total Facility Beds 28 (L18)
13. Total Certified Beds 28 (L17)
14. LTC CERTIFIED BED BREAKDOWN
15. FACILITY MEETS
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):
17. SURVEYOR SIGNATURE Date: 11/30/2015
18. STATE SURVEY AGENCY APPROVAL Date: 12/14/2015

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY
20. COMPLIANCE WITH CIVIL RIGHTS ACT:
21. 1. Statement of Financial Solvency (HCFA-2572)
2. Ownership/Control Interest Disclosure Stmt (HCFA-1513)
3. Both of the Above :
22. ORIGINAL DATE OF PARTICIPATION 07/11/1969 (L24)
23. LTC AGREEMENT BEGINNING DATE (L41)
24. LTC AGREEMENT ENDING DATE (L25)
25. LTC EXTENSION DATE: (L27)
26. TERMINATION ACTION: 00 (L30)
27. ALTERNATIVE SANCTIONS
28. TERMINATION DATE: (L28)
29. INTERMEDIARY/CARRIER NO. 03001 (L31)
30. REMARKS
31. RO RECEIPT OF CMS-1539 (L32)
32. DETERMINATION OF APPROVAL DATE (L33)
DETERMINATION APPROVAL



Protecting, Maintaining and Improving the Health of Minnesotans

Certified Mail # 7011 2000 0002 5143 6404

November 12, 2015

Ms. Caroline Portoghese, Administrator
Fairview University Transitional Services
2450 Riverside Avenue South
Minneapolis, Minnesota 55454

RE: Project Number S5170025

Dear Ms. Portoghese:

On November 5, 2015, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Gloria Derfus, Unit Supervisor
Minnesota Department of Health
P.O. Box 64900
St. Paul, Minnesota 55164-0900

Telephone: (651) 201-3792

Fax: (651) 201-3790

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by December 15, 2015, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by December 15, 2015 the following remedy will be imposed:

- Per instance civil money penalties. (42 CFR 488.430 through 488.444)

PLAN OF CORRECTION (PoC)

A PoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your PoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Include signature of provider and date.

If an acceptable PoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable PoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's PoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the PoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your PoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable PoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved PoC, unless it is determined that either correction actually occurred between the latest correction date on the PoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the PoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by February 5, 2016 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement

of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by May 5, 2016 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting a PoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Supervisor
Health Care Fire Inspections
State Fire Marshal Division
444 Minnesota Street, Suite 145
St. Paul, Minnesota 55101-5145

Telephone: (651) 201-7205

Fax: (651) 215-0525


Fairview University Transitional Services

November 12, 2015

Page 6

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads "Shellae Dietrich". The script is cursive and somewhat informal.

Shellae Dietrich, Certification Specialist

Licensing and Certification Program

Health Regulation Division

Telephone: (651) 201-4106 Fax: (651) 215-9697

Enclosure

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV			STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 000	INITIAL COMMENTS The facility's plan of correction (POC) will serve as your allegation of compliance upon the Department's acceptance. Because you are enrolled in ePOC, your signature is not required at the bottom of the first page of the CMS-2567 form. Your electronic submission of the POC will be used as verification of compliance. Upon receipt of an acceptable electronic POC, an on-site revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.	F000		
F 156 SS=D	483.10(b)(S)-(10), 483.10(b)(1) NOTICE OF RIGHTS, RULES, SERVICES, CHARGES The facility must inform the resident both orally and in writing in a language that the resident understands of his or her rights and all rules and regulations governing resident conduct and responsibilities during the stay in the facility. The facility must also provide the resident with the notice (if any) of the State developed under §1919(e)(6) of the Act. Such notification must be made prior to or upon admission and during the resident's stay. Receipt of such information, and any amendments to, must be acknowledged in writing. The facility must inform each resident who is entitled to Medicaid benefits, in writing, at the time of admission to the nursing facility or, when the resident becomes eligible for Medicaid of the items and services that are included in nursing facility services under the State plan and for which the resident may not be charged; those other items and services that the facility offers	F 156	483.10(b)(S)-(10), 483.10(b)(1) NOTICE OF RIGHTS, RULES, SERVICES, CHARGES • TCU Administrator re-educated Director of Nursing and MDS staff (who are responsible for issuing notices) regarding the TCU policy of providing residents with notices about Non-Coverage of Services within 2 calendar days of when the covered services are expected to end. • Administrator will conduct daily monitoring for compliance until 100% compliance for 30 days. Following this time, a random audit of 10 records will occur monthly for 3 months. Random monitoring on a quarterly basis after 3 months. o Monitoring began 11/25/15.	11/24/15

Accepted Gloria Defina 11-30-15

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE TITLE (X6) DATE

[Signature] TCU Administrator 11/25/15

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2015
FORM APPROVED
OMB NO 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING----- B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV			STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	D PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 156	<p>Continued From page 1</p> <p>and for which the resident may be charged, and the amount of charges for those services; and inform each resident when changes are made to the items and services specified in paragraphs (5) (i)(A) and (B) of this section.</p> <p>The facility must inform each resident before, or at the time of admission, and periodically during the resident's stay, of services available in the facility and of charges for those services, including any charges for services not covered under Medicare or by the facility's per diem rate.</p> <p>The facility must furnish a written description of legal rights which includes: A description of the manner of protecting personal funds, under paragraph (c) of this section.</p> <p>A description of the requirements and procedures for establishing eligibility for Medicaid, including the right to request an assessment under section 1924(c) which determines the extent of a couple's non-exempt resources at the time of institutionalization and attributes to the community spouse an equitable share of resources which cannot be considered available for payment toward the cost of the institutionalized spouse's medical care in his or her process of spending down to Medicaid eligibility levels.</p> <p>A posting of names, addresses, and telephone numbers of all pertinent State client advocacy groups such as the State survey and certification agency, the State licensure office, the State ombudsman program, the protection and advocacy network, and the Medicaid fraud control unit, and a statement that the resident may file a complaint with the State survey and certification</p>	F 156		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2015
FORM APPROVED
OMB NO 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A <u>BUILDING</u> B WING	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV		STREET ADDRESS CITY STATE ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	D PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)
F 156	<p>Continued From page 2</p> <p>agency concerning resident abuse, neglect, and misappropriation of resident property in the facility, and non-compliance with the advance directives requirements.</p> <p>The facility must inform each resident of the name, specialty, and way of contacting the physician responsible for his or her care.</p> <p>The facility must prominently display in the facility written information, and provide to residents and applicants for admission oral and written information about how to apply for and use Medicare and Medicaid benefits, and how to receive refunds for previous payments covered by such benefits.</p> <p>This REQUIREMENT is not met as evidenced by: Based on interview and document review, the facility failed to provide proper liability and appeal rights notices on a timely manner prior to termination of all Medicare skilled services for 1 of 3 residents (R53) reviewed for liability notice and beneficiary appeal rights.</p> <p>Findings include:</p> <p>R53 was admitted to the facility on 6/23/15, and discharged on 7/2/15. A Notice of Medicare Non-Coverage indicated R53's skilled services ending date was 7/2/15, but had been signed on 7/1/15, which was one day to the end of skilled services.</p> <p>On 11/3/15, at 8:48a.m. the Minimum Data Set (MDS) registered nurse (RN)-B verified and</p>	F 156	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2015
FORM APPROVED
OMB NO 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV		STREET ADDRESS CITY STATE ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 156	<p>Continued From page 3</p> <p>acknowledged the notice had not been given timely. When asked what the facility policy was for issuing notices, RN-8 stated notice was supposed to be given within two calendar days. RN-8 further indicated there was no documentation for why the notice had been given late and thought R53 had been cleared medically to be discharged to another setting.</p> <p>On 11/4/15, at 1:52 p.m. the director of nursing stated she was aware of the issue and would have expected the appropriate notices to be provided in a timely manner according to the regulatory requirements.</p> <p>Non-Coverage of Services: TCU policy revised 6/13, directed: "1. Procedure for Medicare patients B. The discharge planning team anticipates when Medicare covered services will end based on the plan of care and patient program, and a probable discharge date is established. At least two calendar days before the covered services are expected to end, a staff member in either care management or business services will deliver to the patient the letter specifying the date services end."</p>	F 156		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/22/2015
FORM APPROVED
OMB NO 0938-0391

FH170025

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B WING	(X3) DATE SURVEY COMPLETED 11/05/2015
--	--	---	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS CITY STATE ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	DATE COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRESAFETY</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, Fire Marshal Division on November 05, 2015. At the time of this survey, UMMC Fairview Transitional Services was found to be in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES TO:</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul MN 55101-5145. OR</p> <p>By email to: Marian.Whitney@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to 	K000		
-------	---	------	--	--

APPROVED *Tom Linhoff*
By Tom Linhoff at 8:16 am, Nov 30, 2015

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE <i>[Signature]</i>	TCC Administrator	TITLE	DATE 11/25/15
---	-------------------	-------	------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED 11/12/2015
FORM APPROVED
OMB NO 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV			STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	
DEFICIT PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	COMPLETION DATE
K 000	Continued From page 1 prevent a reoccurrence of the deficiency. This 5-story building was determined to be of Type 11(222) construction. It has a full basement and is fully sprinklered throughout. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors that is monitored for automatic fire department notification. The facility has a capacity of 28 beds and had a census of 11 at the time of the survey. Only the 4th floor is occupied as a skilled nursing facilities.	K000		
K 020 SS=F	The requirement at 42 CFR, Subpart 483.70(a) NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD Stairways, elevator shafts, light and ventilation shafts, chutes, and other vertical openings between floors are enclosed with construction having a fire resistance rating of at least one hour. An atrium may be used in accordance with 8 2.5.6. 19.3.1.1. This STANDARD is not met as evidenced by: Based on observation and interview, the facility failed to maintain vertical openings as required by LSC(OO) Section 19.3.1 1. This deficient practice could affect all residents. Findings include: On facility tour between 9:30 AM and 12:30 PM on 11/05/2015, observation revealed that the resident room ventilation system is served by a	K020		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2015
FORM APPROVED
OMB NO 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B WING	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV			STREET ADDRESS CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	COMPLETION DATE
K 020	Continued From page 2 vertical riser duct shaft with horizontal ductwork leading from the penthouse to the resident rooms. This deficient practice was verified by the Administrator at the time of the inspection. Note: This deficiency need not be corrected if an FSES can establish that the facility has an overall level of fire safety equivalent to that required by the Life Safety Code.	K020	Complete FSES establishes the facility has an overall level of fire safety equivalent to that required by the Life Safety Code.	11/2/15 11-23-15
K 050 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Responsibility for planning and conducting drills is assigned only to competent persons who are qualified to exercise leadership. Where drills are conducted between 9 PM and 6 AM a coded announcement may be used instead of audible alarms. 19.7.1.2 This STANDARD is not met as evidenced by: Based on review of records and staff interview, it was determined that the facility failed to vary the times in accordance with NFPA 101 LSC (00) Section 19.7.1.2. This deficient practice could affect how staff react in the event of a fire. Improper reaction by staff would affect the safety of all 11 residents. Findings include: On facility tour between 9:30 AM and 12:30 PM	K050	NFPA 101 LIFE SAFETY CODE STANDARD <ul style="list-style-type: none"> The Director of Facilities has completed a fire drill schedule for 2016, which includes greater variation of the time of fire drills, so drills are varied by at least 90 minutes and occur on each shift for each quarter. The TCU Administrator who will monitor for compliance with the varied shift and time requirements. 	11/24/15

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/12/2015
FORM APPROVED
OMB NO 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245170	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV		STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454	
ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) (X5) COMPLETION DATE
KOSO	Continued From page 3 on 11/05/2015, a review of the available fire drill reports in 2014 and 2015 revealed that the facility Day-shift fire drills were conducted between the hours of 9:36AM, 9:10 AM, 9:28AM, 1:00 PM not varied times in accordance with Section 19.7.1.2. This deficient practice was confirmed by the Maintenance Supervisor.	KOSO	

ZONE 1 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services BUILDING 01-Main Building

ZONE(S) EVALUATED First Floor Smoke Compartment A

PROVIDERNENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.**

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	or	4 ¹ 6 ¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.**

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	<input type="checkbox"/>	X <input type="checkbox"/>	X <input type="checkbox"/>	X <input type="checkbox"/>	X <input type="checkbox"/>	= <input type="checkbox"/>
			1.1			1.1

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.**

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="checkbox"/>	<input type="checkbox"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<input type="checkbox"/>	= <input type="checkbox"/>
	1.1	= 1

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE Mark Thugner TITLE Regional Director Facilities CHFM DATE 11/23/2015

FIRE AUTHORITY SIGNATURE Thomas Linhoff TITLE Fire Safety Supervisor DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^d		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr	>2 hr			
	-14	-10	0	2(0) ^e	3(0) ^e			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2	0			
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c	0	3					
10. Emergency Movement Routes	<2 Routes	Multiple Routes						
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^h	2(3) ^h	3(3) ^h	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE:

- ^a Use (0) where parameter 5 is -10.
- ^b Use (0) where parameter 10 is -8.
- ^c Use (0) on floor with fewer than 31 patients (existing buildings only)
- ^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

- ^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
- ^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
- ^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS				
Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	2	2		2
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	2		2	2
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 22	S₂ = 18	S₃ = 14	S₄ = 28

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)						
Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th or higher	18	9	19(16)a	6	11(8)a	3

- a. Use () in zones that do not contain patient sleeping rooms.
- b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 22 - 5 = 17	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E 18 - 4 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 14 - 1 = 13	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = GG 28 - 1 = 27	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 2 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services	BUILDING 01-Main Building
ZONE(S) EVALUATED First Floor Smoke Compartment B	
PROVIDER/NENDOR NO. 245170	DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.**

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	or	4 ¹ b6 ¹	7 ¹ and Above	Basements
	Risk Factor	<u>1.1</u>	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.**

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION							
OCCUPANCY RISK	M	D	L	T	A	F	
	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	= <input type="checkbox"/>
	X	X	1.1	X	X	X	= <input type="checkbox"/>
			1.1				= <input type="checkbox"/>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.**

TABLE 3A. (NEW BUILDINGS)		
F	R	
1.0 X <input type="checkbox"/>	<input type="checkbox"/>	

TABLE 3B. (EXISTING BUILDINGS)		
F	R	
0.6 X <input type="checkbox"/>	<input type="checkbox"/>	
0.6 X <input type="checkbox"/>	<input checked="" type="checkbox"/>	= <input type="checkbox"/>
	1.1	= <input type="checkbox"/>
		1

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE  FIRE AUTHORITY SIGNATURE Thomas Linhoff Form CMS-2786T (02/2013)	TITLE Regional Director Facilities CHFM TITLE Fire Safety Supervisor	DATE 11/23/2015 DATE 11/30/2015
--	--	--

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third 4th and Above	-9 -13	-7 -7	-9 -13	-7 -7	-7 -9	2 -7	4 4
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^d		2(0) ^g		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^g	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr		>2 hr		
	-14	-10	0	2(0) ^e		3(0) ^e		
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2		0		
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c		3					
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
1a Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE:

- ^a Use (0) where parameter 5 is -10.
- ^b Use (0) where parameter 10 is -8.
- ^c Use (0) on floor with fewer than 31 patients (existing buildings only)
- ^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	2	2		2
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	0			0
5. Doors to Corridor	2		2	2
6. Zone Dimensions			0	0
7. Vertical Openings	0		0	0
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 20	S₂ = 18	S₃ = 14	S₄ = 26

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4 th or higher	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 20 - 5 = 15	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 ≥ Sb = E 18 ≥ 4 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 14 - 1 = 13	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G 26 - 1 = 25	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services	BUILDING 01-Main Building
ZONE(S) EVALUATED Third Floor North	
PROVIDERNENDOR NO. 245170	DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4 ¹ b6 ¹	7 ¹ and Above	Basements
	Risk Factor	1.1	<u>1.2</u>	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION										
	M		D		L		T		A	F
OCCUPANCY RISK	<input type="checkbox"/>	X	<input type="checkbox"/>	X	<input type="checkbox" value="1.2"/>	X	<input type="checkbox"/>	X	<input type="checkbox"/>	= <input type="checkbox" value="1.2"/>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="checkbox"/>	<input type="checkbox"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<input type="checkbox" value="1.2"/>	= <input type="checkbox" value="1"/>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE <i>[Signature]</i>	TITLE Regional Director Facilities CHFM	DATE 11/23/2015
FIRE AUTHORITY SIGNATURE Thomas Linhoff <i>[Signature]</i>	TITLE Fire Safety Supervisor	DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.

Safety Parameters	Safety Parameters Values							
	Combustible Types III, IV, and V				NonCombustible Types I and II			
1. Construction								
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433	
First	-2	0	-2	0	0	2	2	
Second	-7	-2	-4	-2	-2	2	4	
Third	-9	-7	-9	-7	-7	2	4	
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C		Class B		Class A			
	-5(0) ^f		0(3) ^f		3			
3. Interior Finish (Rooms)	Class C		Class B		Class A			
	-3(1) ^f		1(3) ^f		3			
4. Corridor Partitions/Walls	None or Incomplete		<1/2 hour		>1/2 to <1 hour		>1 hour	
	-10(0) ^g		0		1(0) ^g		2(0) ^g	
5. Doors to Corridor	No Door		<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.	
	-10		0		1(0) ^g		2(0) ^d	
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^e	0	1	
7. Vertical Openings	Open 4 or More Floors		Open 2 or 3 Floors		Enclosed with Indicated Fire Resist.			
	-14		-10		<1 hr		>1 hr to <2 hr	
					0		2(0) ^e	
							3(0) ^e	
8. Hazardous Areas	Double Deficiency				Single Deficiency		No Deficiencies	
	In Zone		Outside Zone		In Zone		In Adjacent Zone	
	-11		-5		-6		-2	
							0	
9. Smoke Control	No Control		Smoke Barrier Serves Zone		Mech. Assisted Systems by Zone			
	-5(0) ^c		0		3			
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
			Deficient		W/O Horizontal Exit(s)		Horizontal Exit(s)	
			-2		0		1	
							5	
11. Manual Fire Alarm	No Manual Fire Alarm				Manual Fire Alarm			
	-4				W/O F.D. Conn.		W/F.D. Conn	
					1		2	
12. Smoke Detection and Alarm	None		Corridor Only		Rooms Only		Corridor and Habit. Spaces	
	0(3) ^g		2(3) ^g		3(3) ^g		4	
13. Automatic Sprinklers	None		Corridor and Habit. Space		Entire Building			
	0		8		10			

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	10 x 1/2 = 5	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 3	S₄ = 19

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4 th story or higher	18	9	19(16)a	6	11(8)a	3

- a. Use () in zones that do not contain patient sleeping rooms.
- b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION						Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C	<input type="text" value="13"/> - <input type="text" value="9"/> = <input type="text" value="4"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 \geq Sb = E	<input type="text" value="20"/> \geq <input type="text" value="6"/> = <input type="text" value="14"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P	<input type="text" value="3"/> - <input type="text" value="3"/> = <input type="text" value="0"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G	<input type="text" value="19"/> - <input type="text" value="1"/> = <input type="text" value="18"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
E.	There are no flue-fed incinerators.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

CONCLUSIONS

1. All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the *Life Safety Code*. *
2. One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the *Life Safety Code*. *

*The equivalency covered by this worksheet includes the majority of considerations covered by the *Life Safety Code*. There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 4 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Third Floor South

PROVIDER/NENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4 ¹ to 6 ¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
- B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION

OCCUPANCY RISK $M \times D \times L \times T \times A = F$
 X X X X =

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
- B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
- C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)

$1.0 \times F = R$
 $1.0 \times \text{[]} = \text{[]}$

TABLE 3B. (EXISTING BUILDINGS)

$0.6 \times F = R$
 $0.6 \times 1.2 = 1$

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE *Mark Chung*

TITLE Regional Director Facilities CHFM

DATE 11/23/2015

FIRE AUTHORITY SIGNATURE *Thomas Linhoff*

TITLE Fire Safety Supervisor

DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^g		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr		>2 hr		
	-14	-10	0	2(0) ^e		3(0) ^e		
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2		0		
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c		3					
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)		Direct Exit(s)		
		-2	0	1		5		
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
1a Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S1)	Extinguishment Safety (S2)	People Movement Safety (S3)	General Safety (S4)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	0			0
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 11	S₂ = 20	S₃ = 3	S₄ = 17

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (Sa)		Extinguishment (Sb)		People Movement (Sc)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **Sa=7, Sb=10, and Sc=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION				Yes	No	
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 11 - 9 = 2	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 \geq Sb = E 20 \geq 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 3 - 3 = 0	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G 17 - 1 = 16	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.				✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		✓		
E.	There are no flue-fed incinerators.		✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.				✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 5 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Third Floor East

PROVIDERNENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.

Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4 ¹ to 6 ¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.

B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION								
	M	D	L	T	A	F		
OCCUPANCY RISK	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	=	<input checked="" type="checkbox"/>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.

B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.

C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
F	R	
1.0 X <input type="checkbox"/>	<input type="checkbox"/>	

TABLE 3B. (EXISTING BUILDINGS)		
F	R	
0.6 X <input checked="" type="checkbox"/>	= <input type="checkbox"/>	

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE
[Signature]
FIRE AUTHORITY SIGNATURE
[Signature]
Thomas Linhoff
Form CMS-2786T (02/2013)

TITLE Regional Director Facilities CHFM
TITLE Fire Safety Supervisor

DATE 11/23/2015
DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish (Rooms)	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^g		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr	>2 hr			
	-14	-10	0	2(0) ^e	3(0) ^e			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2	0			
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c	0	3					
10. Emergency Movement Routes	<2 Routes	Multiple Routes						
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE: * Use (0) where parameter 5 is -10.
 b Use (0) where parameter 10 is -8.
 c Use (0) on floor with fewer than 31 patients (existing buildings only)
 d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

* Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
 f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
 * Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS				
Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			1	1
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	10 x 1/2 = 5	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 4	S₄ = 20

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)						
Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION				Yes	No	
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 \geq Sb = E 20 \geq 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 4 - 3 = 1	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G 20 - 1 = 19	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.				✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		✓		
E.	There are no flue-fed incinerators.		✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.				✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 6 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services BUILDING 01-Main Building

ZONE(S) EVALUATED Third Floor West

PROVIDER/ENDOR NO. 245170 DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.**

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4 ¹ to 6 ¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	One or More None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.**

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	<input type="checkbox"/>	X <input type="checkbox"/>	X <input type="checkbox"/>	X <input type="checkbox"/>	X <input type="checkbox"/>	= <input type="checkbox"/>
			1.2			1.2

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.**

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="checkbox"/>	<input type="checkbox"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<input type="checkbox"/>	<input type="checkbox"/>
	1.2	1

*FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE [Signature] TITLE Regional Director Facilities CHFM DATE 11/23/2015

FIRE AUTHORITY SIGNATURE [Signature] TITLE Fire Safety Supervisor DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^g		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr	>2 hr			
	-14	-10	0	2(0) ^e	3(0) ^e			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2	0			
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c	0	3					
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S1)	Extinguishment Safety (S2)	People Movement Safety (S3)	General Safety (S4)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			1	1
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 4	S₄ = 20

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (Sa)		Extinguishment (Sb)		People Movement (Sc)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **Sa=7, Sb=10, and Sc=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION						Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C	13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E	20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P	4 - 3 = 1	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G	20 - 1 = 19	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 7 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fourth Floor North

PROVIDER/NENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.**

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4¹ to 6¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.**

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION							
	M	D	L	T	A	F	
OCCUPANCY RISK	3.2	1.0	1.4	1.1	1.2	5.9	
	X	X	X	X	X	=	

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.**

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="text"/>	<input type="text"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	5.9	3.5

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE
[Signature]
FIRE AUTHORITY SIGNATURE
[Signature]
Thomas Linhoff
Form CMS-2786T (02/2013)

TITLE Regional Director Facilities
CHFM
TITLE Fire Safety Supervisor

DATE 11/23/2015
DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.

Safety Parameters	Safety Parameters Values						
	Combustible Types III, IV, and V				NonCombustible Types I and II		
1. Construction							
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	-4	-2	-2	2	4
Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C	Class B	Class A				
	-5(0) ^f	0(3) ^f	3				
3. Interior Finish	Class C	Class B	Class A				
	-3(1) ^f	1(3) ^f	3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour	>1/2 to <1 hour		≥1 hour		
	-10(0) ^g	0	1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR	>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0	1(0) ^g		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1	
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.				
	-14	10	<1 hr	>1 hr to <2 hr	>2 hr		
			0	2(0) ^e	3(0) ^e		
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies		
	In Zone	Outside Zone	In Zone	In Adjacent Zone	0		
	-11	-5	-6	-2			
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone				
	-5(0) ^c	0	3				
10. Emergency Movement Routes	<2 Routes	Multiple Routes					
		Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)		
	-8	-2	0	1	5		
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm				
	-4		W/O F.D. Conn.	W/F.D. Conn			
			1	2			
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone		
	0(3) ^g	2(3) ^g	3(3) ^g	4	5		
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building				
	0	8	10				

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1 , S_2 , S_3 , S_G to blocks labeled S_1 , S_2 , S_3 , S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S1)	Extinguishment Safety (S2)	People Movement Safety (S3)	General Safety (S4)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 3	S₄ = 19

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (Sa)		Extinguishment (Sb)		People Movement (Sc)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

- a. Use () in zones that do not contain patient sleeping rooms.
- b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **Sa=7, Sb=10, and Sc=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION						Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C	<input type="text" value="13"/> - <input type="text" value="9"/> = <input type="text" value="4"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 \geq Sb = E	<input type="text" value="20"/> \geq <input type="text" value="6"/> = <input type="text" value="14"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P	<input type="text" value="3"/> - <input type="text" value="3"/> = <input type="text" value="0"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G	<input type="text" value="19"/> - <input type="text" value="4"/> = <input type="text" value="15"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
E.	There are no flue-fed incinerators.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.		<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

CONCLUSIONS	
1.	<input checked="" type="checkbox"/> All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> .*
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> .*
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fourth Floor South

PROVIDER/NENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.

Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

Risk Parameters	Risk Factors Values					
	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
1. Patient Mobility (M)	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
	No. of Patients	1-5	6-10	11-30	>30	
2. Patient Density (D)	Risk Factor	<u>1.0</u>	1.2	1.5	2.0	
	Floor	1 ¹	2 or 3	<u>4¹ b6¹</u>	7 ¹ and Above	Basements
3. Zone Location (L)	Risk Factor	1.1	1.2	<u>1.4</u>	1.6	1.6
	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
4. Ratio of Patients to Attendants (T)	Risk Factor	1.0	<u>1.1</u>	1.2	1.5	4.0
	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
5. Patient Average Age (A)	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.

B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION

OCCUPANCY RISK $\boxed{3.2} \times \boxed{1.0} \times \boxed{1.4} \times \boxed{1.1} \times \boxed{1.2} = \boxed{5.9}$

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.

B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.

C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)

$1.0 \times \boxed{F} = \boxed{R}$

TABLE 3B. (EXISTING BUILDINGS)

$0.6 \times \boxed{5.9} = \boxed{3.5}$

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE 

TITLE Regional Director Facilities
CHFM

DATE 11/23/2015

FIRE AUTHORITY SIGNATURE 

TITLE Fire Safety Supervisor

DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish (Rooms)	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^g		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr	>2 hr			
	-14	-10	0	2(0) ^e	3(0) ^e			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone	0			
	-11	-5	-6	-2				
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c	0	3					
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	10 x 1/2 = 5	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 3	S₄ = 19

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E 20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 3 - 3 = 0	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G 19 - 4 = 15	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.				✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		✓		
E.	There are no flue-fed incinerators.		✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.				✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> .*
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> .*
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Maryland 21244-1850.

ZONE 9 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fourth Floor East

PROVIDERNENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.

Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4¹ b6¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.

B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION

OCCUPANCY RISK $\boxed{3.2} \times \boxed{1.5} \times \boxed{1.4} \times \boxed{1.1} \times \boxed{1.2} = \boxed{8.9}$

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.

B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.

C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)

$1.0 \times \boxed{F} = \boxed{R}$

TABLE 3B. (EXISTING BUILDINGS)

$0.6 \times \boxed{8.9} = \boxed{5.3}$

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE *Mark Tugger*

TITLE Regional Director Facilities CHFM

DATE 11/23/2015

FIRE AUTHORITY SIGNATURE *Thomas Linhoff*
Thomas Linhoff
Form CMS-2786T (02/2013)

TITLE Fire Safety Supervisor

DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.									
Safety Parameters	Safety Parameters Values								
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II				
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433	
	First	-2	0	-2	0	0	2	2	
	Second	-7	-2	-4	-2	-2	2	4	
	Third	-9	-7	-9	-7	-7	2	4	
4th and Above	-13	-7	-13	-7	-9	-7	4		
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A					
	-5(0) ^f	0(3) ^f		3					
3. Interior Finish (Rooms)	Class C	Class B		Class A					
	-3(1) ^f	1(3) ^f		3					
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour			
	-10(0) ^g	0		1(0) ^g		2(0) ^g			
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.			
	-10	0		1(0) ^g		2(0) ^d			
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft		<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^c	0		1	
7. Vertical Openings	Open 4 or More Floors		Open 2 or 3 Floors		Enclosed with Indicated Fire Resist.				
					<1 hr		>1 hr to <2 hr		>2 hr
	-14		-10		0		2(0) ^e		3(0) ^e
8. Hazardous Areas	Double Deficiency				Single Deficiency		No Deficiencies		
	In Zone		Outside Zone		In Zone		In Adjacent Zone		
	-11		-5		-6		-2		
9. Smoke Control	No Control		Smoke Barrier Serves Zone		Mech. Assisted Systems by Zone				
					3				
	-5(0) ^c		0						
10. Emergency Movement Routes	<2 Routes		Multiple Routes						
			Deficient		W/O Horizontal Exit(s)		Horizontal Exit(s)		Direct Exit(s)
	-8		-2		0		1		5
11. Manual Fire Alarm	No Manual Fire Alarm				Manual Fire Alarm				
					W/O F.D. Conn.		W/F.D. Conn		
	-4				1		2		
12. Smoke Detection and Alarm	None		Corridor Only		Rooms Only		Corridor and Habit. Spaces		Total Spaces In Zone
	0(3) ^g		2(3) ^g		3(3) ^g		4		5
13. Automatic Sprinklers	None		Corridor and Habit. Space		Entire Building				
	0		8		10				

NOTE:

- ^a Use (0) where parameter 5 is -10.
- ^b Use (0) where parameter 10 is -8.
- ^c Use (0) on floor with fewer than 31 patients (existing buildings only)
- ^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1 , S_2 , S_3 , S_G to blocks labeled S_1 , S_2 , S_3 , S_G in Table 7 on page 4 of this sheet.

Safety Parameters	Containment Safety (S1)	Extinguishment Safety (S2)	People Movement Safety (S3)	General Safety (S4)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			1	1
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 4	S₄ = 20

Zone Location	Containment (Sa)		Extinguishment (Sb)		People Movement (Sc)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2nd or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **Sa=7, Sb=10, and Sc=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION						Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C	13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E	20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P	4 - 3 = 1	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G	20 - 5 = 15	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.				✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		✓		
E.	There are no flue-fed incinerators.		✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.				✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 10 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fourth Floor West

PROVIDER/NENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.**

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

Risk Parameters	Risk Factors Values					
		Mobile	Limited Mobility	Not Mobile	Not Movable	
1. Patient Mobility (M)	Mobility Status					
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4¹ b6¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.**

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION

	M	D	L	T	A	F
OCCUPANCY RISK	3.2	1.5	1.4	1.1	1.2	8.9
	X	X	X	X	=	

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.**

TABLE 3A. (NEW BUILDINGS)

	F	R
1.0 X	<input type="text"/>	<input type="text"/>

TABLE 3B. (EXISTING BUILDINGS)

	F	R
0.6 X	8.9	5.3

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE
Mark...
FIRE AUTHORITY SIGNATURE
Thomas Linhoff
Form CMS-2786T (02/2013)

TITLE Regional Director Facilities
CHFM
TITLE Fire Safety Supervisor

DATE 11/23/2015
DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.

Safety Parameters	Safety Parameters Values						
	Combustible Types III, IV, and V				NonCombustible Types I and II		
1. Construction							
Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
First	-2	0	-2	0	0	2	2
Second	-7	-2	-4	-2	-2	2	4
Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4
2. Interior Finish (Corridors and Exits)	Class C		Class B		Class A		
	-5(0) ^f		0(3) ^f		3		
3. Interior Finish	Class C		Class B		Class A		
	-3(1) ^f		1(3) ^f		3		
4. Corridor Partitions/Walls	None or Incomplete		<1/2 hour		>1/2 to <1 hour		>1 hour
	-10(0) ^g		0		1(0) ^g		2(0) ^g
5. Doors to Corridor	No Door		<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.
	-10		0		1(0) ^g		2(0) ^d
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is		
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft	<100 ft
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^c	0	1
7. Vertical Openings	Open 4 or More Floors		Open 2 or 3 Floors		Enclosed with Indicated Fire Resist.		
	-14		-10		<1 hr	>1 hr to <2 hr	>2 hr
					0	2(0) ^e	3(0) ^e
8. Hazardous Areas	Double Deficiency			Single Deficiency		No Deficiencies	
	In Zone		Outside Zone		In Zone	In Adjacent Zone	
	-11		-5		-6	-2	
							0
9. Smoke Control	No Control		Smoke Barrier Serves Zone		Mech. Assisted Systems by Zone		
	-5(0) ^c		0		3		
10. Emergency Movement Routes	<2 Routes		Multiple Routes				
			Deficient		W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)
	-8		-2		0	1	5
11. Manual Fire Alarm	No Manual Fire Alarm				Manual Fire Alarm		
	-4				W/O F.D. Conn.	W/F.D. Conn	
					1	2	
12. Smoke Detection and Alarm	None		Corridor Only		Rooms Only		Corridor and Habit. Spaces
	0(3) ^g		2(3) ^g		3(3) ^g		Total Spaces In Zone
							5
13. Automatic Sprinklers	None		Corridor and Habit. Space		Entire Building		
	0		8		10		

NOTE: * Use (0) where parameter 5 is -10.
 b Use (0) where parameter 10 is -8.
 c Use (0) on floor with fewer than 31 patients (existing buildings only)
 d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

* Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
 f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
 g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	10 x 1/2 = 5	10
Total Value	S₁= 13	S₂= 20	S₃=3	S₄= 19

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

- a. Use () in zones that do not contain patient sleeping rooms.
- b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E 20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 3 - 3 = 0	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G 19 - 5 = 14	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fifth Floor North

PROVIDER/NENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.

Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS

Risk Parameters	Risk Factors Values					
	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4¹ b6¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	6-10 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year		65 Years and Over 1 Year and Younger		
	Risk Factor	1.0		1.2		

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.

B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION

OCCUPANCY RISK $\boxed{3.2} \times \boxed{1.2} \times \boxed{1.4} \times \boxed{1.1} \times \boxed{1.2} = \boxed{7.1}$

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.

B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.

C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)

$1.0 \times \boxed{F} = \boxed{R}$

TABLE 3B. (EXISTING BUILDINGS)

$0.6 \times \boxed{7.1} = \boxed{4.3}$

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE 

TITLE Regional Director Facilities
CHFM

DATE 11/23/2015

FIRE AUTHORITY SIGNATURE 

TITLE Fire Safety Supervisor

DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^h		2(0) ^d		
6. Zone Dimensions	Dead End				No Dead Ends >30 ft and Zone Length Is			
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft		>150 ft	100 ft to 150 ft	<100 ft	
	-6(0) ^b	-4(0) ^b	-2(0) ^b		-2(0) ^c	0	1	
7. Vertical Openings	Open 4 or More Floors		Open 2 or 3 Floors		Enclosed with Indicated Fire Resist.			
	-14		-10		<1 hr	>1 hr to <2 hr	>2 hr	
					0	2(0) ^e	3(0) ^e	
8. Hazardous Areas	Double Deficiency			Single Deficiency		No Deficiencies		
	In Zone		Outside Zone		In Zone	In Adjacent Zone		
	-11		-5		-6	-2		
9. Smoke Control	No Control		Smoke Barrier Serves Zone		Mech. Assisted Systems by Zone			
	-5(0) ^c		0		3			
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
			Deficient		W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)	
	-8		-2		0	1	5	
11. Manual Fire Alarm	No Manual Fire Alarm				Manual Fire Alarm			
	-4				W/O F.D. Conn.	W/F.D. Conn		
					1	2		
12. Smoke Detection and Alarm	None	Corridor Only		Rooms Only		Corridor and Habit. Spaces	Total Spaces In Zone	
	0(3) ^g	2(3) ^g		3(3) ^g		4	5	
13. Automatic Sprinklers	None	Corridor and Habit. Space		Entire Building				
	0	8		10				

NOTE: * Use (0) where parameter 5 is -10.
 b Use (0) where parameter 10 is -8.
 c Use (0) on floor with fewer than 31 patients (existing buildings only)
 d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

* Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_4 to blocks labeled S_1, S_2, S_3, S_4 in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 3	S₄ = 19

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E 20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 3 - 3 = 0	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = GG 19 - 4 = 15	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET					
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.			Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.		✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.				✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.		✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.		✓		
E.	There are no flue-fed incinerators.		✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.		✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.		✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.		✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.		✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.		✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.		✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.				✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> .*
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> .*
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Building, Baltimore, Maryland 21244-1850.

ZONE 12 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fifth Floor South

PROVIDERNENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value. Choose only one for each of the five Risk Parameters.**

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	<u>3.2</u>	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	<u>1.2</u>	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	<u>4¹ to 6¹</u>	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	<u>1.4</u>	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	<u>1.0</u>	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			<u>1.2</u>	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.**

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION											
	M	D	L	T	A	F					
OCCUPANCY RISK	<u>3.2</u>	X	<u>1.2</u>	X	<u>1.4</u>	X	<u>1.0</u>	X	<u>1.2</u>	=	<u>6.5</u>

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.**

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="text"/>	<input type="text"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	<u>6.5</u>	= <u>3.9</u>

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE
Maull Thompson
FIRE AUTHORITY SIGNATURE
Thomas Linhoff
Thomas Linhoff
Form CMS-2786T (02/2013)

TITLE Regional Director Facilities
CHFM
TITLE Fire Safety Supervisor

DATE 11/23/2015
DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		>1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^h		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors		Enclosed with Indicated Fire Resist.				
		-14		-10		-10		
			<1 hr	>1 hr to <2 hr	>2 hr			
		0		2(0) ^e		3(0) ^e		
8. Hazardous Areas	Double Deficiency		Single Deficiency			No Deficiencies		
	In Zone	Outside Zone	In Zone	In Adjacent Zone		0		
	-11	-5	-6	-2		0		
9. Smoke Control	No Control	Smoke Barrier Serves Zone		Mech. Assisted Systems by Zone				
	-5(0) ^c	0		3				
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
	-8	Deficient		W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)		
		-2		0		1	5	
11. Manual Fire Alarm	No Manual Fire Alarm			Manual Fire Alarm				
	-4			W/O F.D. Conn.	W/F.D. Conn			
				1	2			
12. Smoke Detection and Alarm	None	Corridor Only		Rooms Only		Corridor and Habit. Spaces	Total Spaces In Zone	
	0(3) ^g	2(3) ^g		3(3) ^g		4	5	
13. Automatic Sprinklers	None	Corridor and Habit. Space		Entire Building				
	0	8		10				

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

^e Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")
^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.
^g Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

For SI units: 1 ft = 0.3048 m

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1 , S_2 , S_3 , S_G to blocks labeled S_1 , S_2 , S_3 , S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS				
Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 3	S₄ = 19

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)						
Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2 nd or 3 rd story ^b	15	9	17(14)a	6	10(7)a	3
4 th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION				Yes	No	
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E 20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 3 - 3 = 0	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = GG 19 - 4 = 15	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

ZONE 13 OF 14 ZONES

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services BUILDING 01-Main Building

ZONE(S) EVALUATED Fifth Floor East

PROVIDER/NENDOR NO. 245170 DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
- Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4¹ to 6¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2	3-5	6-10	>10	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
- B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
OCCUPANCY RISK	M	D	L	T	A	F
	3.2	1.2	1.4	1.0	1.2	6.5
	X	X	X	X	=	

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
- B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
- C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="text"/>	<input type="text"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	6.5	= 3.9

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE <i>[Signature]</i>	TITLE <u>Regional Director Facilities CHFM</u>	DATE <u>11/23/2015</u>
FIRE AUTHORITY SIGNATURE <i>[Signature]</i>	TITLE <u>Fire Safety Supervisor</u>	DATE <u>11/30/2015</u>

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		≥ 1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^c		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr	>2 hr			
	-14	-10	0	2(0) ^e	3(0) ^e			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone	0			
	-11	-5	-6	-2				
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c		0	3				
10. Emergency Movement Routes	<2 Routes	Multiple Routes						
	-8	Deficient	-2	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)		
				0	1	5		
11. Manual Fire Alarm	No Manual Fire Alarm		Manual Fire Alarm					
	-4		W/O F.D. Conn.	W/F.D. Conn				
			1	2				
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
13. Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE: ^a Use (0) where parameter 5 is -10.
^b Use (0) where parameter 10 is -8.
^c Use (0) on floor with fewer than 31 patients (existing buildings only)
^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^e Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1, S_2, S_3, S_G to blocks labeled S_1, S_2, S_3, S_G in Table 7 on page 4 of this sheet.

TABLE 5. INDIVIDUAL SAFETY EVALUATIONS

Safety Parameters	Containment Safety (S ₁)	Extinguishment Safety (S ₂)	People Movement Safety (S ₃)	General Safety (S ₄)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			1	1
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	10 x 1/2 = 5	10
Total Value	S₁ = 13	S₂ = 20	S₃ = 4	S₄ = 20

TABLE 6. MANDATORY SAFETY REQUIREMENTS (FOR USE IN HOSPITALS OR NURSING HOMES)

Zone Location	Containment (S _a)		Extinguishment (S _b)		People Movement (S _c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

- a. Use () in zones that do not contain patient sleeping rooms.
- b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: **S_a=7, S_b=10, and S_c=7**

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION					Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C 13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 - Sb = E 20 - 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P 4 - 3 = 1	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G 20 - 4 = 16	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.

FIRE/SMOKE ZONE* EVALUATION WORKSHEET FOR HEALTH CARE FACILITIES

2000 LIFE SAFETY CODE

FACILITY FV University Transitional Services

BUILDING 01-Main Building

ZONE(S) EVALUATED Fifth Floor West

PROVIDER/NENDOR NO. 245170

DATE OF SURVEY 11/23/2015

COMPLETE THIS WORKSHEET FOR EACH ZONE. WHERE CONDITIONS ARE THE SAME IN SEVERAL ZONES, ONE WORKSHEET CAN BE USED FOR THOSE ZONES.

Step 1: Determine Occupancy Risk Parameter Factors - Use Table 1.

- A. For each Risk Parameter in Table 1, select and circle the appropriate risk factor value.
Choose only one for each of the five Risk Parameters.

TABLE 1. OCCUPANCY RISK PARAMETER FACTORS						
Risk Parameters	Risk Factors Values					
1. Patient Mobility (M)	Mobility Status	Mobile	Limited Mobility	Not Mobile	Not Movable	
	Risk Factor	1.0	1.6	3.2	4.5	
2. Patient Density (D)	No. of Patients	1-5	6-10	11-30	>30	
	Risk Factor	1.0	1.2	1.5	2.0	
3. Zone Location (L)	Floor	1 ¹	2 or 3	4 ¹ b6 ¹	7 ¹ and Above	Basements
	Risk Factor	1.1	1.2	1.4	1.6	1.6
4. Ratio of Patients to Attendants (T)	Patients Attendant	1-2 1	3-5 1	<u>6-10</u> 1	>10 1	<u>One or More</u> None
	Risk Factor	1.0	1.1	1.2	1.5	4.0
5. Patient Average Age (A)	Age	Under 65 Years and Over 1 year			65 Years and Over 1 Year and Younger	
	Risk Factor	1.0			1.2	

Step 2: Compute Occupancy Risk Factor (F) - Use Table 2.

- A. Transfer the circled risk factor values from Table 1 to the corresponding blocks in Table 2.
B. Compute F by multiplying the risk factor values as indicated in Table 2.

TABLE 2. OCCUPANCY RISK FACTOR CALCULATION						
	M	D	L	T	A	F
OCCUPANCY RISK	3.2	1.5	1.4	1.0	1.2	8.0
	=					

Step 3: Compute Adjusted Building Status (R) - Use Table 2.

- A. If building is classified as "NEW" use Table 3A. If building is classified as "Existing" use Table B.
B. Transfer the value of F from Table 2 to Table 3A or Table 3B as appropriate. Calculate R.
C. Transfer R to the block labeled R in Table 7 on page 4 of the work sheet.

TABLE 3A. (NEW BUILDINGS)		
	F	R
1.0 X	<input type="text"/>	<input type="text"/>

TABLE 3B. (EXISTING BUILDINGS)		
	F	R
0.6 X	8.0	4.8

* FIRE/SMOKE ZONE is a space separated from all other spaces by floors, horizontal exits, or smoke

SURVEYOR SIGNATURE
Mark Taylor
FIRE AUTHORITY SIGNATURE
Thomas Linhoff
Form CMS-2786T (02/2013)

TITLE Regional Director Facilities
CHFM
DATE 11/23/2015
TITLE Fire Safety Super Supervisor
DATE 11/30/2015

Step 4: Determine Safety Parameter Values - Use Table 4.

A. Select and circle the safety value for each safety parameter in Table 4 that best describes the conditions in the zone. Choose only one value for each of the 13 parameters. If two or more appear to apply, choose the one with the lowest point value.

TABLE 4.								
Safety Parameters	Safety Parameters Values							
1. Construction	Combustible Types III, IV, and V				NonCombustible Types I and II			
	Floor or Zone	000	111	200	211 + 2HH	000	111	222, 332, 433
	First	-2	0	-2	0	0	2	2
	Second	-7	-2	-4	-2	-2	2	4
	Third	-9	-7	-9	-7	-7	2	4
4th and Above	-13	-7	-13	-7	-9	-7	4	
2. Interior Finish (Corridors and Exits)	Class C	Class B		Class A				
	-5(0) ^f	0(3) ^f		3				
3. Interior Finish (Rooms)	Class C	Class B		Class A				
	-3(1) ^f	1(3) ^f		3				
4. Corridor Partitions/Walls	None or Incomplete	<1/2 hour		>1/2 to <1 hour		≥1 hour		
	-10(0) ^g	0		1(0) ^g		2(0) ^g		
5. Doors to Corridor	No Door	<20 min FPR		>20 min FPR		>20 min FPR and Auto Clos.		
	-10	0		1(0) ^g		2(0) ^d		
6. Zone Dimensions	Dead End			No Dead Ends >30 ft and Zone Length Is				
	>100 ft	>50 ft to 100 ft	30 ft to 50 ft	>150 ft	100 ft to 150 ft	<100 ft		
	-6(0) ^b	-4(0) ^b	-2(0) ^b	-2(0) ^c	0	1		
7. Vertical Openings	Open 4 or More Floors	Open 2 or 3 Floors	Enclosed with Indicated Fire Resist.					
			<1 hr	>1 hr to <2 hr	>2 hr			
	-14	-10	0	2(0) ^e	3(0) ^e			
8. Hazardous Areas	Double Deficiency		Single Deficiency		No Deficiencies			
	In Zone	Outside Zone	In Zone	In Adjacent Zone				
	-11	-5	-6	-2		0		
9. Smoke Control	No Control	Smoke Barrier Serves Zone	Mech. Assisted Systems by Zone					
	-5(0) ^c	0	3					
10. Emergency Movement Routes	<2 Routes		Multiple Routes					
	-8	Deficient	W/O Horizontal Exit(s)	Horizontal Exit(s)	Direct Exit(s)			
		-2	0	1	5			
11. Manual Fire Alarm	No Manual Fire Alarm			Manual Fire Alarm				
	-4			W/O F.D. Conn.	W/F.D. Conn			
				1	2			
12. Smoke Detection and Alarm	None	Corridor Only	Rooms Only	Corridor and Habit. Spaces	Total Spaces In Zone			
	0(3) ^g	2(3) ^g	3(3) ^g	4	5			
1a Automatic Sprinklers	None	Corridor and Habit. Space	Entire Building					
	0	8	10					

NOTE:

- ^a Use (0) where parameter 5 is -10.
- ^b Use (0) where parameter 10 is -8.
- ^c Use (0) on floor with fewer than 31 patients (existing buildings only)
- ^d Use (0) where parameter 4 is -10.

For SI units: 1 ft = 0.3048 m

^a Use (0) where Parameter 1 is based on first floor zone or on an unprotected type of construction (columns marked "000" or "200")

^f Use () if the area of Class B or C interior finish in the corridor and exit or room is protected by automatic sprinklers and Parameter 13 is 0; use () if the room with existing Class C interior finish is protected by automatic sprinklers, Parameter 4 is greater than or equal to 1, and Parameter 13 is 0.

^a Use this value in addition to Parameter 13 if the entire zone is protected with quick-response automatic sprinklers.

Step 5: Compute Individual Safety Evaluations — Use Table 5.

- A. Transfer each of the 13 circled Safety Parameter Values from Table 4 to every unshaded block in the line with the corresponding Safety Parameter in Table 5. For Safety Parameter 13 (Sprinklers) the value entered in the People Movement Safety column is recorded in Table 5 as $\frac{1}{2}$ the corresponding value circled in Table 4.
- B. Add the four columns, keeping in mind that any negative numbers deduct.
- C. Transfer the resulting total values for S_1 , S_2 , S_3 , S_G to blocks labeled S_1 , S_2 , S_3 , S_G in Table 7 on page 4 of this sheet.

Safety Parameters	Containment Safety (S_1)	Extinguishment Safety (S_2)	People Movement Safety (S_3)	General Safety (S_4)
1. Construction	4	4		4
2. Interior Finish (Corr. and Exit)	3		3	3
3. Interior Finish (Rooms)	3			3
4. Corridor Partitions/Walls	2			2
5. Doors to Corridor	1		1	1
6. Zone Dimensions			0	0
7. Vertical Openings	-10		-10	-10
8. Hazardous Areas	0	0		0
9. Smoke Control			0	0
10. Emergency Movement Routes			0	0
11. Manual Fire Alarm		2		2
12. Smoke Detection and Alarm		4	4	4
13. Automatic Sprinklers	10	10	$10 \times \frac{1}{2} = 5$	10
Total Value	$S_1 = 13$	$S_2 = 20$	$S_3 = 3$	$S_4 = 19$

Zone Location	Containment (S_a)		Extinguishment (S_b)		People Movement (S_c)	
	New	Exist.	New	Exist.	New	Exist.
1 st story	11	5	15(12)a	4	8(5)a	1
2d or 3rd story ^b	15	9	17(14)a	6	10(7)a	3
4th story or	18	9	19(16)a	6	11(8)a	3

a. Use () in zones that do not contain patient sleeping rooms.

b. For a 2nd story zone location in a sprinklered EXISTING facility, as an alternative to the mandatory safety requirement values set specified in the table, the following mandatory values set shall be permitted to be used: $S_a=7$, $S_b=10$, and $S_c=7$

Step 6: Determine Mandatory Safety Requirement Values - Use Table 6.

- A. Using the classification of the building (i.e., New or Existing) and the floor where the zone is located circle the appropriate value in each of the three columns in Table 6.
- B. Transfer the three circled values from Table 6 to the blocks marked **Sa**, **Sb**, and **Sc** in Table 7.
- C. For each row check "Yes" if the value in the answer block is zero or greater. Check "No" if the value in the answer block is a negative number.

TABLE 7. ZONE FIRE SAFETY EQUIVALENCY EVALUATION						Yes	No
Containment Safety (S1)	minus	Mandatory Containment (Sa)	≥ 0	S1 - Sa = C	13 - 9 = 4	✓	
Extinguishment Safety (S2)	minus	Mandatory Extinguishment (Sb)	≥ 0	S2 ≥ Sb = E	20 ≥ 6 = 14	✓	
People Movement Safety (S3)	minus	Mandatory People Movement (Sc)	≥ 0	S3 - Sc = P	3 - 3 = 0	✓	
General Safety (S4)	minus	Occupancy Risk (R)	≥ 0	S4 - R = G	19 - 5 = 14	✓	

TABLE 8. FACILITY FIRE SAFETY REQUIREMENTS WORKSHEET						
Complete one copy of this worksheet for each facility. For each consideration, select and mark the appropriate column.				Met	Not Met	Not Applic.
A.	Building utilities conform to the requirements of Section 9.1.			✓		
B.	In new facilities only, life-support systems, alarms, emergency communication systems, and illumination of generator set locations are powered as prescribed by 18.5.1.2 and 18.5.1.3.					✓
C.	Heating and air conditioning systems conform with the air conditioning, heating, and ventilating systems requirements within Section 9.2, except for enclosure of vertical openings, which have been considered in Safety Parameter 7 of Worksheet 4.7.6.			✓		
D.	Fuel-burning space heaters and portable electrical space heaters are not used.			✓		
E.	There are no flue-fed incinerators.			✓		
F.	An evacuation plan is provided and fire drills conducted in accordance with 18.7.1/18.7.2 and 19.7.1/19.7.2.			✓		
G.	Smoking regulations have been adopted and implemented in accordance with 18.7.4 and 19.7.4.			✓		
H.	Draperies, upholstered furniture, mattresses, furnishings, and decoration combustibility is limited in accordance with 18.7.5 and 19.7.5.			✓		
I.	Fire extinguishers are provided in accordance with the requirements of 18.3.5.4 and 19.3.5.6.			✓		
J.	Exit signs are provided in accordance with the requirements of 18.2.10.1 and 19.2.10.			✓		
K.	Emergency lighting is provided in accordance with 18.2.9.1 or 19.2.9.			✓		
L.	Standpipes are provided in all new high rise buildings as required by 18.4.2.					✓

CONCLUSIONS	
1.	✓ All of the checks in Table 7 are in the "Yes" column. The level of fire safety is at least equivalent to that prescribed by the <i>Life Safety Code</i> . *
2.	One of more of the checks in Table 7 are in the "No" column. The level of fire safety is not shown by this system to be equivalent to that prescribed by the <i>Life Safety Code</i> . *
*The equivalency covered by this worksheet includes the majority of considerations covered by the <i>Life Safety Code</i> . There are a few considerations that are not evaluated by this method. These must be considered separately. These additional considerations are covered in Table 8, the "Facility Fire Safety Requirements Worksheet." One copy of this separate worksheet is to be completed for each facility.	

According to the Paperwork Reduction Act of 1995, no persons are required to respond to a collection of information unless it displays a valid OMB control number. The valid OMB control number for this information collection is 0938-0242. The time required to complete this information collection is estimated to average 5 minutes per response, including the time to review instructions, search existing data resources, gather the data needed, and complete and review the information collection. If you have any comments concerning the accuracy of the time estimate(s) or suggestions for improving this form, please write to: CMS, Attn: PRA Reports Clearance Officer, 7500 Security Boulevard, Baltimore, Maryland 21244-1850.



Protecting, Maintaining and Improving the Health of Minnesotans

Certified Mail # 7011 2000 0002 5143 6404

November 12, 2015

Ms. Caroline Portoghese, Administrator
Fairview University Transitional Services
2450 Riverside Avenue South
Minneapolis, Minnesota 55454

Re: Enclosed State Nursing Home Licensing Orders - Project Number S5170025

Dear Ms. Portoghese:

The above facility was surveyed on November 2, 2015 through November 5, 2015 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules. At the time of the survey, the survey team from the Minnesota Department of Health, Health Regulation Division, noted one or more violations of these rules that are issued in accordance with Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a civil fine for each deficiency not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.

To assist in complying with the correction order(s), a "suggested method of correction" has been added. This provision is being suggested as one method that you can follow to correct the cited deficiency. Please remember that this provision is only a suggestion and you are not required to follow it. Failure to follow the suggested method will not result in the issuance of a penalty assessment. You are reminded, however, that regardless of the method used, correction of the deficiency within the established time frame is required. The "suggested method of correction" is for your information and assistance only.

The State licensing orders are delineated on the attached Minnesota Department of Health order form (attached). The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes.

The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule number and the corresponding text of the state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction order. This column also includes the findings that are in violation of the state statute after the statement, "This Rule

Fairview University Trans Serv

November 12, 2015

Page 2

is not met as evidenced by." Following the surveyors findings are the Suggested Method of Correction and the Time Period For Correction.

PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.

THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES.


When all orders are corrected, the order form should be signed and returned to this office at Minnesota Department of Health, P.O. Box 64900, St. Paul, Minnesota 55164-0900. We urge you to review these orders carefully, item by item, and if you find that any of the orders are not in accordance with your understanding at the time of the exit conference following the survey, you should immediately contact me.

You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.

Please note it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,



Shellae Dietrich, Certification Specialist
Licensing and Certification Program
Health Regulation Division
Telephone: (651) 201-4106 Fax: (651) 215-9697

Enclosure(s)

cc: Original - Facility
Licensing and Certification File


Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING:----- B WING	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	---	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	10 PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

2 000	<p>Initial Comments</p> <p style="text-align: center;">*****ATTENTION-</p> <p style="text-align: center;">NH LICENSING CORRECTION ORDER</p> <p>In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.</p> <p>Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected.</p> <p>You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.</p> <p>INITIAL COMMENTS: On 11/2/15, through 11/5/15, surveyors of this Department's, visited the above provider and the following correction orders were issued. Please indicate in your electronic plan of correction that you have reviewed these orders, and identify the date when they will be completed.</p>	2 000	<p>Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota State Statutes/Rules for Nursing Homes.</p>	
-------	--	-------	--	--

Minnesota Department of Health LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE  TCM Administrator	TITLE	(X6) DATE 11/25/15
--	-------	-----------------------

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING ----- B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	--	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	--	--------------------

2000 Continued From page 1

2 000

The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction order. This column also includes the findings which are in violation of the state statute after the statement, "This Rule is not met as evidence by." Following the surveyors findings are the Suggested Method of Correction and Time period for Correction.

PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.

THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES.

21426 MN St. Statute 144A.04 Subd. 3 Tuberculosis Prevention And Control

21426

(a) A nursing home provider must establish and maintain a comprehensive tuberculosis infection control program according to the most current tuberculosis infection control guidelines issued by the United States Centers for Disease Control and Prevention (CDC), Division of Tuberculosis Elimination, as published in CDC's Morbidity and Mortality Weekly Report (MMWR). This program must include a tuberculosis infection control plan that covers all paid and unpaid employees, contractors, students,

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING:----- B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	--	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY, STATE ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

21426	<p>Continued From page 2</p> <p>residents, and volunteers. The Department of Health shall provide technical assistance regarding implementation of the guidelines.</p> <p>(b) Written compliance with this subdivision must be maintained by the nursing home.</p> <p>This MN Requirement is not met as evidenced by: Based on interview and document review, the facility failed to ensure resident tuberculin skin test (TST) was completed/documentated appropriately and tuberculosis symptom screening was completed for 5 of 5 residents (R75, R82, R85, R70, R83) who were recently admitted to the facility. In addition the facility's TB policy did not include current guidelines for TST reading including measurements and documentation in millimeters (mm), and did not include direction for staff when residents refused TST testing.</p> <p>Findings include:</p> <p>Five residents electronic medical record was reviewed with the facility's director of nursing (DON) on 11/2/15, at 1:30 p.m. the following were identified, and verbally confirmed by the DON: - R75 was admitted to the facility on 10/29/15, had the baseline TB symptoms screening on 10/28/15. R75 refused the 2 step TST. The medical record lacked evidence the physician was notified, or of a follow up of the refusal. The DON stated staff should have called the physician to report R75's refusal and to ask for further</p>	21426		
-------	---	-------	--	--

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING # _____ B. WING _____	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	--	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	D PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	--------------	---	--------------------

21426	<p>Continued From page 3</p> <p>guidance.</p> <p>- R82 was admitted to the facility on 10/14/15, did not have the baseline TB symptoms screening completed. R82 received the first step TST on 10/14/15, read on 10/16/15, documented as "Negative result", however no induration in mm was documented. The second step was not administered, nor scheduled in the system to be administered. The DON stated a baseline TB symptoms screening should have been completed upon admission, staff should have documented the results in mm's, and a second step TST supposed to be administered one to three weeks after the first TST.</p> <p>-R85 was admitted to the facility on 10/20/15, and had the baseline TB symptoms screening completed on 10/20/15. The first step TST was administered on 10/21/15, with results read "Negative", however no induration in mm was indicated. The second step TST was not administered or scheduled yet. The DON stated staff should have documented results in mm's and should have scheduled the second step TST to be administered.</p> <p>- R70 was admitted to the facility on 9/11/15. There was no evidence in the medical record of a baseline TB symptoms screening. The first TST was administered on 10/3/15, read as "0 mm of induration" on 10/5/15, however the second step TST was not administered. The DON verified R70 should have had a second step TST administered one to three weeks after the first TST.</p> <p>- R83 was admitted to the facility on 10/26/17, and had the baseline TB symptom screening completed on 10/27/15. R83 refused the TST on 10/27/15, however the medical record lacked evidence the physician was notified, or of a follow up of the refusal. The DON stated staff should have called the physician to report R75's refusal and to ask for further guidance. The DON did not</p>	21426		
-------	---	-------	--	--

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV		STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
21426	Continued From page 4 know what was the facility's policy was for patient refusal of TB testing. The facility's TB (Tuberculosis) and Other Airborne Infectious Disease Control Plan-UMMC [University of Minnesota Medical Center] dated revised on 7/15, indicated: - "3. All residents admitted to the TCU will have a baseline tuberculosis screening tool completed on admission." - "4. Residents must have a baseline TST. Minnesota Rule states that a TST must be administered within three months prior to or within 72 hours after admission." - "5. The baseline TB screening includes either a TB blood test or a two-step procedure with the initial TST administered within 72 hours of admission. If the initial TST is negative, a second test should be administered one to three weeks later. The policy did not include current guidelines for induration measurements in mm's, and did not include directions for staff when residents refused the 2 step TST. SUGGESTED METHOD OF CORRECTION: The DON could inservice all staff responsible for TB on the most current standards and requirements in regards to TB control. Facility policies and procedures related to TB could be reviewed and revised if necessary. An auditing system could be developed, with review by the quality assessment and assurance committee to ensure ongoing compliance. TIME PERIOD FOR CORRECTION: Twenty One (21) days.	21426	MN St. Statute 144A.04 Subd. 3 Tuberculosis Prevention And Control <ul style="list-style-type: none"> FV System TB Policy updated to include the most recent SNF requirements (July, 2013). Nursing education developed and completed to highlight policy changes. Items to be highlighted involve: <ul style="list-style-type: none"> Tuberculosis assessment paper screening to be done on every admission. Policy will outline RN and MD steps if patient refuses TB screening. Skin reading documentation will be reflected as being read in mm amount of induration in addition to positive and negative results. Monthly audits of all admissions for 100% compliance to the screening for 3 months. Once maintaining 100% compliance, will move to random, quarterly audits. 	11/20/15 12/7/15
21800	MN St. Statute 144.651 Subd. 4 Patients & Residents of HC Fac. Bill of Rights	21800		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BLDING : _____ B. WING	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	--	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	---

(X4) D PREFIX TAG SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTON (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
---	---------------	--	--------------------

<p>21800 Continued From page 5</p> <p>Subd. 4. Information about rights. Patients and residents shall, at admission, be told that there are legal rights for their protection during their stay at the facility or throughout their course of treatment and maintenance in the community and that these are described in an accompanying written statement of the applicable rights and responsibilities set forth in this section. In the case of patients admitted to residential programs as defined in section 253C.01, the written statement shall also describe the right of a person 16 years old or older to request release as provided in section 2538.04, subdivision 2, and shall list the names and telephone numbers of individuals and organizations that provide advocacy and legal services for patients in residential programs. Reasonable accommodations shall be made for those with communication impairments and those who speak a language other than English. Current facility policies, inspection findings of state and local health authorities, and further explanation of the written statement of rights shall be available to patients, residents, their guardians or their chosen representatives upon reasonable request to the administrator or other designated staff person, consistent with chapter 13, the Data Practices Act, and section 626.557, relating to vulnerable adults.</p> <p>This MN Requirement is not met as evidenced by: Based on interview and document review, the facility failed to provide proper liability and appeal rights notices on a timely manner prior to termination of all Medicare skilled services for 1 of 3 residents (R53) reviewed for liability notice</p>	21800		
--	-------	--	--

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	--	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	---

(X4) D PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
-------------------------	--	---------------------	--	--------------------------

21800	<p>Continued From page 6 and beneficiary appeal rights.</p> <p>Findings include:</p> <p>R53 was admitted to the facility on 6/23/15, and discharged on 7/2/15. A Notice of Medicare Non-Coverage indicated R53's skilled services ending date was 7/2/15, but had been signed on 7/1/15, which was one day to the end of skilled services.</p> <p>On 11/3/15, at 8:48 a.m. the Minimum Data Set (MDS) registered nurse (RN)-8 verified and acknowledged the notice had not been given timely. When asked what the facility policy was for issuing notices RN-B stated notice was supposed to be given within two calendar days. RN-B further indicated there was no documentation for why the notice had been given late and thought R53 had been cleared medically to be discharged to another setting.</p> <p>On 11/4/15, at 1:52 p.m. the director of nursing stated she was aware of the issue and would have expected the appropriate notices to be provided in a timely manner according to the regulatory requirements.</p> <p>Non-Coverage of Services: TCU policy revised 6/13, directed: "I. Procedure for Medicare patients B. The discharge planning team anticipates when Medicare covered services will end based on the plan of care and patient program, and a probable discharge date is established. At least two calendar days before the covered services are expected to end, a staff member in either care management or business services will deliver to the patient the letter specifying the date services end."</p>	21800		
-------	--	-------	--	--

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00259	(X2) MULTIPLE CONSTRUCTION A. BUILDING: --- B. WING: _____	(X3) DATE SURVEY COMPLETED 11/05/2015
--	---	--	--

NAME OF PROVIDER OR SUPPLIER FAIRVIEW UNIVERSITY TRANS SERV	STREET ADDRESS, CITY, STATE, ZIP CODE 2450 RIVERSIDE AVENUE SOUTH MINNEAPOLIS, MN 55454
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

21800	Continued From page 7 SUGGESTED METHOD OF CORRECTION: The administrator or designee could educate staff on the process of providing liability notices and resident appeals rights. The administrator or designee could then audit to ensure compliance. TIME PERIOD FOR CORRECTION Twenty-one (21) days.	21800		
-------	--	-------	--	--