



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
August 28, 2023

Administrator
Mount Olivet Home
5517 Lyndale Avenue South
Minneapolis, MN 55419

RE: CCN: 24E102
Cycle Start Date: August 10, 2023

Dear Administrator:

On August 10, 2023, a survey was completed at your facility by the Minnesota Departments of Health and Public Safety, to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

ELECTRONIC PLAN OF CORRECTION (ePoC)

Within **ten (10) calendar days** after your receipt of this notice, you must submit an acceptable ePOC for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

Mount Olivet Home

August 28, 2023

Page 2

The state agency may, in lieu of an onsite revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417);
- Civil money penalty (42 CFR 488.430 through 488.444).
- Termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by an "F" and/or an "E" tag), i.e., the plan of correction should be directed to:

Nathan Schreier, Unit Supervisor
Metro B District Office
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
85 East Seventh Place, Suite 220
P.O. Box 64900
Saint Paul, Minnesota 55164-0900
Email: nate.schreier@state.mn.us
Office: (651) 201-4348 Mobile (651) 392-2726

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or

Mount Olivet Home

August 28, 2023

Page 3

Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by November 10, 2023 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by February 10, 2024 (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

INFORMAL DISPUTE RESOLUTION (IDR) / INDEPENDENT INFORMAL DISPUTE RESOLUTION (IIDR)

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: https://mdhprovidercontent.web.health.state.mn.us/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04_8.html

Please note that the failure to complete the informal dispute resolution process will not delay the

Mount Olivet Home

August 28, 2023

Page 4

dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Travis Z. Ahrens
Interim State Fire Safety Supervisor
Health Care & Correctional Facilities/Explosives
MN Department of Public Safety-Fire Marshal Division
445 Minnesota St., Suite 145
St. Paul, MN 55101
Cell: 1-507-308-4189

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Melissa Poepping". The signature is fluid and cursive, with a large initial "M" and a long, sweeping underline.

Melissa Poepping, Compliance Analyst
Federal Enforcement | Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
Saint Paul, Minnesota 55164-0970
Phone: 651-201-4117
Email: Melissa.Poepping@state.mn.us



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered

August 28, 2023

Administrator
Mount Olivet Home
5517 Lyndale Avenue South
Minneapolis, MN 55419

Re: Event ID: 2DSO11

Dear Administrator:

The above facility survey was completed on August 10, 2023 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules. At the time of the survey, the survey team from the Minnesota Department of Health - Health Regulation Division noted no violations of these rules promulgated under Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10.

Electronically posted is the Minnesota Department of Health order form stating that no violations were noted at the time of this survey. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Please disregard the heading of the fourth column which states, "Provider's Plan of Correction." This applies to Federal deficiencies only. There is no requirement to submit a Plan of Correction.

Please feel free to call me with any questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Melissa Poepping'.

Melissa Poepping, Compliance Analyst
Federal Enforcement | Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
Saint Paul, Minnesota 55164-0970
Phone: 651-201-4117
Email: Melissa.Poepping@state.mn.us

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/07/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED C 08/10/2023
--	---	--	---

NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDALE AVENUE SOUTH MINNEAPOLIS, MN 55419
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
E 000	Initial Comments On 8/7/23-8/10/23, a survey for compliance with Appendix Z, Emergency Preparedness Requirements, §483.73(b)(6) was conducted during a standard recertification survey. The facility was in compliance.	E 000		
F 000	INITIAL COMMENTS On 8/7/23-8/10/23, a standard recertification survey was conducted at your facility. A complaint investigation was also conducted. Your facility was not in compliance with the requirements of 42 CFR 483, Subpart B, Requirements for Long Term Care Facilities. In addition to the recertification survey, the following complaints were reviewed with no deficiency issued: HE1024247C (MN83933) HE1024248C (MN89967) HE1024249C (MN89940) HE1024250C (MN89657) HE1024251C (MN87500) HE1024465C (MN84056) The facility's plan of correction (POC) will serve as your allegation of compliance upon the Departments acceptance. Because you are enrolled in ePOC, your signature is not required	F 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

09/07/2023

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 08/10/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 000	Continued From page 1 at the bottom of the first page of the CMS-2567 form. Your electronic submission of the POC will be used as verification of compliance.	F 000		
F 700 SS=D	<p>Bedrails CFR(s): 483.25(n)(1)-(4)</p> <p>§483.25(n) Bed Rails. The facility must attempt to use appropriate alternatives prior to installing a side or bed rail. If a bed or side rail is used, the facility must ensure correct installation, use, and maintenance of bed rails, including but not limited to the following elements.</p> <p>§483.25(n)(1) Assess the resident for risk of entrapment from bed rails prior to installation.</p> <p>§483.25(n)(2) Review the risks and benefits of bed rails with the resident or resident representative and obtain informed consent prior to installation.</p> <p>§483.25(n)(3) Ensure that the bed's dimensions are appropriate for the resident's size and weight.</p> <p>§483.25(n)(4) Follow the manufacturers' recommendations and specifications for installing and maintaining bed rails. This REQUIREMENT is not met as evidenced by: Based on observation, interview, and document review, the facility failed to assess the resident for risk of entrapment, review risks and benefits of</p>	F 700	Physical Device Procedure policy was reviewed. Residents must be assessed for safe use of all physical devices and	9/29/23

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 08/10/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDALE AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 700	<p>Continued From page 2</p> <p>bed rails with the resident or their representative, and obtain informed consent for 1 of 2 residents (R50) reviewed who had bed rails on their beds.</p> <p>Findings include:</p> <p>R50's quarterly Minimum Data Set (MDS) dated 6/28/23, included R50 was moderately impaired cognition, had a diagnosis of dementia, and was independent with bed mobility and transfers. The MDS indicated bed rails were not used.</p> <p>R50's medical record lacked assessment, consent, care plan, and physician orders for bed rail use.</p> <p>On 8/7/23 at 1:53 p.m., R50 was sitting in the recliner in their room and grab bars to each side of their bed were observed. R50 stated they used the grab bars to get into bed and to prevent them from falling out of bed.</p> <p>During interview on 8/9/23 at 1:21 p.m., nursing assistant (NA)-A stated R50 used the grab bars to get out of bed and R50 moved around the bed by themself.</p> <p>During interview on 8/9/23 at 1:44 p.m., registered nurse (RN-A) stated nursing needed to assess residents, provide education, and obtain consent for residents' use of grab bars. RN-A stated these steps were followed to ensure residents knew how to use grab bars safely.</p> <p>During interview on 8/10/23 at 8:23 a.m., licensed practical nurse (LPN)-A stated residents who used grab bars needed an assessment to make sure they needed them and a consent for use. LPN-A reviewed R50's medical record and</p>	F 700	<p>receive consent from the resident/resident representative. R50 was assessed for safety with grab bars. Physical device assessment completed. Consent and provider order obtained for use of grab bars. An audit of all residents beds to be completed and compared against physical device assessments to ensure in compliance. All residents will be reviewed quarterly or with MDS schedule to ensure appropriate use of physical devices. Education provided to nurses on policy and procedure. Engineering to complete room/bed check when rooms are vacated to ensure grab bars are removed prior to another resident admitting to that room. Audits of grab bar removal of empty beds to be completed by Engineering Director or designee weekly x4 weeks then monthly x3 months. Audits of Physical Device Assessment and consent to be audited by Director of Nursing or designee weekly x4 weeks then monthly x3 months. All audits will be provided to administration. Administration will review audits for any concerns or trends. Concerns and trends will be reported at each QAPI meeting.</p>	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 08/10/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDALE AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
F 700	<p>Continued From page 3</p> <p>confirmed it did not contain evidence of grab bar use in their orders, care plan, Physical Device Data Collection assessment, or consent.</p> <p>The facility's policy "Physical Device Procedure" dated 3/16/16, defined physical restraints as "any manual method or physical or mechanical device, material, or equipment attached or adjacent to the resident's body that the individual cannot remove easily which restricts freedom of movement or normal access to one's body." The policy indicated a Physical Device Data Collection Tool will be completed on admission, annually and significant change for residents utilizing a physical device or with the initiation of a physical device to ensure the safety of the resident.</p>	F 700		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00236	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED C 08/10/2023
--	--	---	--

NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDALE AVENUE SOUTH MINNEAPOLIS, MN 55419
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

2 000	<p>Initial Comments</p> <p>*****ATTENTION*****</p> <p>NH LICENSING CORRECTION ORDER</p> <p>In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.</p> <p>Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected.</p> <p>You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.</p> <p>INITIAL COMMENTS: On 8/7/2023-8/10/2023, a licensing survey was conducted at your facility by surveyors from the Minnesota Department of Health (MDH). Your facility was in compliance with the MN State Licensure and the following correction orders are issued. Please indicate in your electronic plan of correction you have reviewed these orders and</p>	2 000		
-------	---	-------	--	--

Minnesota Department of Health
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Electronically Signed

TITLE

(X6) DATE

09/07/23

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00236	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED C 08/10/2023
--	--	---	--

NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDALE AVENUE SOUTH MINNEAPOLIS, MN 55419
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Continued From page 1</p> <p>identify the date when they will be completed.</p> <p>The following complaints were reviewed during the survey: and no licensing orders were issued.</p> <p>HE1024247C MN83933 HE1024248C MN89967 HE1024249C MN89940 HE1024250C MN89657 HE1024251C MN87500 HE1024465C MN84056</p> <p>Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes. The assigned tag number appears in the far left column entitled " ID Prefix Tag." The state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction order. This column also includes the findings which are in violation of the state statute after the statement, "This Rule is not met as evidence by." Following the surveyors findings are the Suggested Method of Correction and Time period for Correction.</p> <p>You have agreed to participate in the electronic receipt of State licensure orders consistent with the Minnesota Department of Health Informational Bulletin <https://www.health.state.mn.us/facilities/regulation/infobulletins/ib14_1.html> The State licensing orders are delineated on the attached Minnesota Department of Health orders being submitted to you electronically. Although no plan of correction is necessary for State Statutes/Rules, please enter the word "corrected" in the box available for text. You must then indicate in the electronic State licensure process, under the heading</p>	2 000		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00236	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED C 08/10/2023
--	--	---	--

NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Continued From page 2</p> <p>completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health.</p> <p>PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE. THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES. http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm. The State licensing orders are delineated on the attached Minnesota Department of Health orders being submitted to you electronically. Although no plan of correction is necessary for State Statutes/Rules, please enter the word "CORRECTED" in the box available for text. You must then indicate in the electronic State licensure process, under the heading completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health. The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of state form.</p> <p>PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.</p>	2 000		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 08/09/2023
--	---	---	---

NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>An annual Life Safety recertification survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division on 08/09/2023. At the time of this survey, Mount Olivet Home was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99, Health Care Facilities Code.</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>IF PARTICIPATING IN THE E-POC PROCESS, A PAPER COPY OF THE PLAN OF CORRECTION IS NOT REQUIRED.</p>	K 000		
-------	---	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 09/07/2023
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR</p> <p>By email to: FM.HC.Inspections@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A detailed description of the corrective action taken or planned to correct the deficiency. 2. Address the measures that will be put in place to ensure the deficiency does not reoccur. 3. Indicate how the facility plans to monitor future performance to ensure solutions are sustained. 4. Identify who is responsible for the corrective actions and monitoring of compliance. 5. The actual or proposed date for completion of the remedy. <p>Mount Olivet Home is a 4-story building without a basement. The building was constructed at 2 different times. The original building was constructed in 1968 and was determined to be of Type II(222) construction. In 2003, an addition was constructed to the South side of the building that was determined to be of Type II(222) construction. The building shares a common wall with Mount Olivet Careview Home which is separated by 2-hour fire rated construction. The facility also contains a child day-care center that</p>	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 was surveyed as part of the nursing home because there is no separation between the two occupancies. Because the original building and the addition meet the construction type allowed for existing buildings, the facility was surveyed as one building. The facility has a capacity of 92 beds and had a census of 89 at the time of the survey. The requirements at 42 CFR, Subpart 483.70(a), are NOT MET as evidenced by:	K 000			
K 211 SS=D	Means of Egress - General CFR(s): NFPA 101 Means of Egress - General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full use in case of emergency, unless modified by 18/19.2.2 through 18/19.2.11. 18.2.1, 19.2.1, 7.1.10.1 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain egress corridors per NFPA 101 (2012 edition), Life Safety Code, sections 19.2.1, 19.2.3.4 and 7.1.10.1. This deficient finding could have an isolated impact on the residents within the facility. Findings include: On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by observation that there were	K 211	Tables and chairs were removed from the corridor. Staff to be educated on keeping means of egress clear. No furniture or items that may prevent egress can be in the corridor. Environmental rounds initiated by Engineering department. Engineering department or designee will complete weekly rounds to ensure means of egress are clear x4 weeks, then monthly x3 months. Results of environmental rounds will be reported to	9/29/23	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 211	Continued From page 3 two tables and six chairs in the egress corridor near resident room 303.	K 211	the QAPI committee.		
K 222 SS=D	Egress Doors CFR(s): NFPA 101 Egress Doors Doors in a required means of egress shall not be equipped with a latch or a lock that requires the use of a tool or key from the egress side unless using one of the following special locking arrangements: CLINICAL NEEDS OR SECURITY THREAT LOCKING Where special locking arrangements for the clinical security needs of the patient are used, only one locking device shall be permitted on each door and provisions shall be made for the rapid removal of occupants by: remote control of locks; keying of all locks or keys carried by staff at all times; or other such reliable means available to the staff at all times. 18.2.2.2.5.1, 18.2.2.2.6, 19.2.2.2.5.1, 19.2.2.2.6 SPECIAL NEEDS LOCKING ARRANGEMENTS Where special locking arrangements for the safety needs of the patient are used, all of the Clinical or Security Locking requirements are being met. In addition, the locks must be electrical locks that fail safely so as to release upon loss of power to the device; the building is protected by a supervised automatic sprinkler system and the locked space is protected by a complete smoke detection system (or is constantly monitored at an attended location within the locked space); and both the sprinkler	K 222		9/29/23	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 222	<p>Continued From page 4</p> <p>and detection systems are arranged to unlock the doors upon activation. 18.2.2.2.5.2, 19.2.2.2.5.2, TIA 12-4 DELAYED-EGRESS LOCKING ARRANGEMENTS Approved, listed delayed-egress locking systems installed in accordance with 7.2.1.6.1 shall be permitted on door assemblies serving low and ordinary hazard contents in buildings protected throughout by an approved, supervised automatic fire detection system or an approved, supervised automatic sprinkler system. 18.2.2.2.4, 19.2.2.2.4 ACCESS-CONTROLLED EGRESS LOCKING ARRANGEMENTS Access-Controlled Egress Door assemblies installed in accordance with 7.2.1.6.2 shall be permitted. 18.2.2.2.4, 19.2.2.2.4 ELEVATOR LOBBY EXIT ACCESS LOCKING ARRANGEMENTS Elevator lobby exit access door locking in accordance with 7.2.1.6.3 shall be permitted on door assemblies in buildings protected throughout by an approved, supervised automatic fire detection system and an approved, supervised automatic sprinkler system. 18.2.2.2.4, 19.2.2.2.4 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain egress doors per NFPA 101 (2012 edition), Life Safety Code, sections 19.2.2.2.1, 19.2.2.2.5.2, and 7.2.1.5.10.1. This deficient finding could have an isolated impact on the residents within the facility.</p> <p>Findings include:</p>	K 222	<p>Button to unlock front exit door after hours was lowered down to 42". Audit of all egress doors was completed and all doors are within compliance. Engineering department educated on appropriate height of door release buttons to ensure any future work on doors ensures appropriate height of release buttons. Engineering Director or designee will audit</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 222	Continued From page 5 On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by observation and staff interview that the button that unlocks the front exit door after hours was mounted 76" high which is above the maximum height. When I arrived on site and talked with the Minnesota Department of Health, they informed me that they were unable to exit through the front door the day before until a staff member pushed the button to let them out, I interviewed staff and they stated that the door is locked after hours and requires the release button to be pushed to exit. An interview with the Associate Administrator and the Director of engineering verified this deficient finding at the time of discovery.	K 222	all egress doors annually to ensure compliance. Audit results will be reported to the QAPI Committee.		
K 324 SS=D	Cooking Facilities CFR(s): NFPA 101 Cooking Facilities Cooking equipment is protected in accordance with NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, unless: * residential cooking equipment (i.e., small appliances such as microwaves, hot plates, toasters) are used for food warming or limited cooking in accordance with 18.3.2.5.2, 19.3.2.5.2 * cooking facilities open to the corridor in smoke compartments with 30 or fewer patients comply with the conditions under 18.3.2.5.3, 19.3.2.5.3, or * cooking facilities in smoke compartments with 30 or fewer patients comply with conditions under 18.3.2.5.4, 19.3.2.5.4. Cooking facilities protected according to NFPA 96 per 9.2.3 are not required to be enclosed as hazardous areas, but shall not be open to the	K 324		9/29/23	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 324	<p>Continued From page 6 corridor. 18.3.2.5.1 through 18.3.2.5.4, 19.3.2.5.1 through 19.3.2.5.5, 9.2.3, TIA 12-2</p> <p>This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to inspect their kitchen hood per NFPA 101 (2012 edition), Life Safety Code, section 19.3.2.5.1 and 9.2.3, and NFPA 96 (2011 edition), Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, section 11.2.1. This deficient finding could have an isolated impact on the residents within the facility.</p> <p>Findings include:</p> <p>On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by a review of available documentation the facility provided me a kitchen hood inspection report dated 01/18/2023 but was not able to provide an inspection report for an inspection completed within six months after that date.</p> <p>An interview with the Associate Administrator and the Director of engineering verified this deficient finding at the time of discovery.</p>	K 324	<p>Documentation obtained for kitchen hood inspection dated 7/25/2023. Engineering staff educated on requirement of inspection semi-annually and requirement to maintain documentation of inspections. Administrator or designee to audit for inspection semi-annually. Audit results will be reported to the QAPI Committee.</p>	
K 353 SS=F	<p>Sprinkler System - Maintenance and Testing CFR(s): NFPA 101</p> <p>Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance</p>	K 353		9/29/23

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDALE AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 353	<p>Continued From page 7</p> <p>with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available.</p> <p>a) Date sprinkler system last checked</p> <p>_____</p> <p>b) Who provided system test</p> <p>_____</p> <p>c) Water system supply source</p> <p>_____</p> <p>Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain the fire sprinkler system per NFPA 101 (2012 edition), Life Safety Code, sections 19.3.5.1, 9.7.1.1, and 9.7.5, NFPA 25 (2011 edition), Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, section 5.1.1.2, 5.2.1.2 and 5.2.1.3, and NFPA 13 (2010 edition), Standard for the installation of Sprinkler Systems, section 8.6.5.3.2. These deficient findings could have a widespread impact on the residents within the facility.</p> <p>Findings include:</p> <p>1. On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by a review of available documentation that the facility could not provide an up-to-date annual fire sprinkler inspection report.</p>	K 353	<p>Documentation obtained for annual fire sprinkler inspection dated 3/22/2023. Documentation obtained for quarterly fire sprinkler inspection from Q3 of 2022 dated 9/19/2022. Summit Fire Protection will send documentation of all inspections to Engineering Director after each inspection. Engineering Director or designee will maintain all records. Administrator or designee will audit for inspection documentation quarterly x4 quarters.</p> <p>All items removed from top shelf in storage room to ensure 18" of clearance from sprinklers. Staff educated on need for clearance. Environmental rounds initiated including audit to ensure appropriate clearance. Rounds to be completed weekly x4 weeks then monthly x3 months. Round results will be reported</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 353	Continued From page 8 2. On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by a review of available documentation that the facility could not provide a quarterly fire sprinkler inspection report for the third quarter of 2022. 3. On 08/09/2023 at 11:24 AM, it was revealed by observation that there was storage within 18" of the ceiling in the storage room at the end of the hall in the old daycare. An interview with the Associate Administrator and the Director of engineering verified these deficient findings at the time of discovery.	K 353	to the QAPI Committee.		
K 372 SS=D	Subdivision of Building Spaces - Smoke Barrie CFR(s): NFPA 101 Subdivision of Building Spaces - Smoke Barrier Construction 2012 EXISTING Smoke barriers shall be constructed to a 1/2-hour fire resistance rating per 8.5. Smoke barriers shall be permitted to terminate at an atrium wall. Smoke dampers are not required in duct penetrations in fully ducted HVAC systems where an approved sprinkler system is installed for smoke compartments adjacent to the smoke barrier. 19.3.7.3, 8.6.7.1(1) Describe any mechanical smoke control system in REMARKS. This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain smoke barriers per NFPA 101 (2012 edition), Life Safety Code, sections 19.3.7.1, 19.3.7.3, 8.5.2.2, and 8.5.6.2. This deficient finding could have an isolated impact on	K 372	Fire caulking applied to fill in space where there was penetration of fire barrier. Audit of all fire barriers completed and appropriately filled. Director of Engineering or designee will audit fire	9/29/23	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 372	Continued From page 9 the residents within the facility. Findings include: On 08/09/2023 at 10:49 AM, it was revealed by observation that there was a penetration in the smoke barrier in the wire chase that is above the ceiling near resident room 221. An interview with the Associate Administrator and the Director of engineering verified this deficient finding at the time of discovery.	K 372	barriers with any construction or wiring in the area to ensure fire barrier isn't penetrated. Audit results will be reported to the QAPI Committee.	
K 511 SS=D	Utilities - Gas and Electric CFR(s): NFPA 101 Utilities - Gas and Electric Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life. 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain clearance in front of electrical equipment per NFPA 101 (2012 edition), Life Safety Code, sections 19.5.1.1 and 9.1.2, and NFPA 70 (2011 edition), National Electrical Code, section 110.26. This deficient finding could have an isolated impact on the residents within the facility.	K 511	Storage room cleared to ensure space in front of electrical panel is clear. Staff education on need to ensure space in front of electrical panels is clear. Environmental rounds initiated including audit of space in front of electrical panels to ensure clearance. Environmental rounds to be completed weekly x4 weeks then monthly x3 months. Round results	9/29/23

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 511	Continued From page 10 Findings include: On 08/09/2023 at 11:22 AM, it was revealed by observation that there was storage in front of the electrical panels that are located in the first-floor storage room. An interview with the Associate Administrator and the Director of engineering verified this deficient finding at the time of discovery.	K 511	will be reported to the QAPI Committee.	
K 711 SS=F	Evacuation and Relocation Plan CFR(s): NFPA 101 Evacuation and Relocation Plan There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. Employees are periodically instructed and kept informed with their duties under the plan, and a copy of the plan is readily available with telephone operator or with security. The plan addresses the basic response required of staff per 18/19.7.2.1.2 and provides for all of the fire safety plan components per 18/19.2.2. 18.7.1.1 through 18.7.1.3, 18.7.2.1.2, 18.7.2.2, 18.7.2.3, 19.7.1.1 through 19.7.1.3, 19.7.2.1.2, 19.7.2.2, 19.7.2.3 This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to implement a fire safety plan per NFPA 101 (2012 edition), Life Safety Code, section 19.7.2.2. These deficient findings could have a widespread impact on the residents within the facility. Findings include:	K 711	Fire Safety Plan updated to include reference of transmission of fire alarms to the fire department and guidance to call 911 in case of a fire. Education of all departments on updated policy and procedure. Director of Engineering will review and update policy annually. Any changes to the policy will be reported to the QAPI Committee and education will	9/29/23

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 711	Continued From page 11 1. On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by a review of available documentation that the facility's Fire Safety Plan did not include an emergency phone call to the fire department. 2. On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by a review of available documentation that the facility's Fire Safety Plan did not include the transmission of alarms to the fire department. An interview with the Associate Administrator and the Director of engineering verified this deficient finding at the time of discovery.	K 711	be provided to all departments.		
K 712 SS=D	Fire Drills CFR(s): NFPA 101 Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7 This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to conduct fire drills per NFPA 101 (2012 edition), Life Safety Code sections 19.7.1.6. This deficient finding could have an isolated impact on the residents within the facility.	K 712	Fire Drill Policy reviewed. Fire drills to be conducted at least quarterly on each shift. Education provided to Engineering department. Administrator or designee to audit fire drills quarterly x4 quarters. Audit results will be reported to the QAPI	9/29/23	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2023
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 24E102	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 08/09/2023
NAME OF PROVIDER OR SUPPLIER MOUNT OLIVET HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 5517 LYNDAL AVENUE SOUTH MINNEAPOLIS, MN 55419		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 712	<p>Continued From page 12</p> <p>Findings include:</p> <p>On 08/09/2023 between 08:45 AM and 12:00 PM, it was revealed by a review of available documentation the facility could not provide documentation showing that a fire drill was conducted on the second shift during the second quarter of 2023.</p> <p>An interview with the Associate Administrator and the Director of engineering verified this deficient finding at the time of discovery.</p>	K 712	Committee.	



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically Delivered
October 16, 2023

Administrator
Mount Olivet Home
5517 Lyndale Avenue South
Minneapolis, MN 55419

RE: CCN: 24E102
Cycle Start Date: August 10, 2023

Dear Administrator:

On October 4, 2023, the Minnesota Departments of Health and Public Safety completed a revisit to verify that your facility had achieved and maintained compliance. Based on our review, we have determined that your facility has achieved substantial compliance; therefore no remedies will be imposed.

Feel free to contact me if you have questions.

A handwritten signature in black ink, appearing to read 'Melissa Poepping'.

Melissa Poepping, Compliance Analyst
Federal Enforcement | Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
Saint Paul, Minnesota 55164-0970
Phone: 651-201-4117
Email: Melissa.Poepping@state.mn.us