

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 3ZSJ
Facility ID: 00058

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245476		3. NAME AND ADDRESS OF FACILITY (L3) GOOD SAMARITAN SOCIETY - PINE RIVER			4. TYPE OF ACTION: <u>2</u> (L8)	
2. STATE VENDOR OR MEDICAID NO. (L2) 017040200		(L4) 518 JEFFERSON AVENUE, PO BOX 29			1. Initial 3. Termination 5. Validation 7. On-Site Visit	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)			2. Recertification 4. CHOW 6. Complaint 9. Other	
6. DATE OF SURVEY 06/18/2015 (L34)		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA			8. Full Survey After Complaint	
8. ACCREDITATION STATUS: <u> </u> (L10)		02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF			FISCAL YEAR ENDING DATE: (L35)	
0 Unaccredited 1 TJC 2 AOA 3 Other		03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC			09/30	
11. LTC PERIOD OF CERTIFICATION		10. THE FACILITY IS CERTIFIED AS:				
From (a): To (b):		X A. In Compliance With Program Requirements Compliance Based On: <u> </u> 1. Acceptable POC			And/Or Approved Waivers Of The Following Requirements: <u> </u> 2. Technical Personnel <u> </u> 3. 24 Hour RN <u> </u> 4. 7-Day RN (Rural SNF) <u> </u> 5. Life Safety Code	
12. Total Facility Beds 56 (L18)		B. Not in Compliance with Program Requirements and/or Applied Waivers:			* Code: A* (L12)	
13. Total Certified Beds 56 (L17)						
14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS	
18 SNF 18/19 SNF 19 SNF ICF IID					1861 (e) (1) or 1861 (j) (1): (L15)	
56						
(L37) (L38) (L39) (L42) (L43)						
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE): See Attached Remarks						
17. SURVEYOR SIGNATURE			Date :		18. STATE SURVEY AGENCY APPROVAL	
<u>Jana Bromenshenkel, HFE NEII</u>			06/18/2015 (L19)		<u>Mark Meath, Enforcement Specialist</u> 06/22/2015 (L20)	

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : <u> </u>	
<u> </u> 1. Facility is Eligible to Participate <u> </u> 2. Facility is not Eligible (L21)					
22. ORIGINAL DATE OF PARTICIPATION 05/01/1987 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		26. TERMINATION ACTION: (L30)	
		24. LTC AGREEMENT ENDING DATE (L25)		<u>VOLUNTARY</u> <u>00</u> <u>INVOLUNTARY</u>	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS		01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement 03-Risk of Involuntary Termination <u>OTHER</u> 04-Other Reason for Withdrawal 07-Provider Status Change 00-Active	
		A. Suspension of Admissions: (L44)			
		B. Rescind Suspension Date: (L45)			
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 00140 (L28)		30. REMARKS	
				(L31)	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE (L33)		Posted 06/22/2015 Co.	
				DETERMINATION APPROVAL	

C&T REMARKS - CMS 1539 FORM**STATE AGENCY REMARKS**

CCN: 24 5476

On June 18, 2015, a standard survey was completed at Good Samaritan Society - Pine River. The facility has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements of Long Term Care Facilities.

Refer to the CMS 2567 for both health and life safety code. Post Certification Revisit N/A.

Effective June 18, 2015, the facility is certified for 56 skilled nursing facility beds.



Protecting, Maintaining and Improving the Health of Minnesotans

CMS Certification Number (CCN): 245476

June 22, 2015

Ms Karen Prososki, Administrator
Good Samaritan Society - Pine River
518 Jefferson Avenue, PO Box 29
Pine River, Minnesota 56474

Dear Ms. Prososki:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective June 18, 2015 the above facility is certified for:

56 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 56 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath".

Mark Meath, Enforcement Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Email: mark.meath@state.mn.us
Telephone: (651) 201-4118 Fax: (651) 215-9697

cc: Licensing and Certification File

Minnesota Department of Health - Health Regulation Division •
General Information: 651-201-5000 • Toll-free: 888-345-0823
<http://www.health.state.mn.us>

An equal opportunity employer



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered

June 22, 2015

Ms. Karen Prosocki, Administrator
Good Samaritan Society - Pine River
518 Jefferson Avenue, PO Box 29
Pine River, Minnesota 56474

RE: Project Number S5476026

Dear Ms.. Prosocki:

On June 18, 2015, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

We are pleased to inform you that this survey resulted in no deficiencies being issued.

The Federal Form CMS-2567 is being electronically delivered.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath".

Mark Meath, Enforcement Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Email: mark.meath@state.mn.us

Telephone: (651) 201-4118

Fax: (651) 215-9697

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/22/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245476	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/18/2015
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - PINE RIVER			STREET ADDRESS, CITY, STATE, ZIP CODE 518 JEFFERSON AVENUE, PO BOX 29 PINE RIVER, MN 56474		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	INITIAL COMMENTS Good Samaritan Society - Pine River has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.	F 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/22/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245476	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 1985 BUILDING AND ADDITIONS B. WING _____		(X3) DATE SURVEY COMPLETED 06/17/2015
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - PINE RIVER			STREET ADDRESS, CITY, STATE, ZIP CODE 518 JEFFERSON AVENUE, PO BOX 29 PINE RIVER, MN 56474		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, Fire Marshal Division on June 17, 2015. At the time of this survey, Good Samaritan Society Pine River was found in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care.</p> <p>Good Samaritan Society of Pine River is a 1-story building with two basements. The building was constructed at five different times. In 1961 the nursing home was built and was determined to be of Type II(111) construction without a basement. In 1968 an addition was constructed to the north of the original building, that was determined to be of Type II(111) construction and has a basement. In 1985 an addition was constructed to the southwest of the 1961 building that was determined to be of Type II(111) construction and has a partial basement. In 1993 an addition was constructed to the west of the 1985 addition that was determined to be of Type II(111) construction. In 1996 the last addition was added to the west of the 1993 addition that was determined to be of Type II(111) construction. The building is divided into 7 smoke zones by one and two hour fire barriers. The facility is separated by 2-hour fire barriers form an outpatient physical therapy building.</p>	K 000			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/22/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245476	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 1985 BUILDING AND ADDITIONS B. WING _____		(X3) DATE SURVEY COMPLETED 06/17/2015
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - PINE RIVER			STREET ADDRESS, CITY, STATE, ZIP CODE 518 JEFFERSON AVENUE, PO BOX 29 PINE RIVER, MN 56474		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1</p> <p>The building and additions are fully sprinkler protected in accordance with NFPA 13 Standard for the Installation of Sprinkler Systems 1999 edition. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors, that is monitored for automatic fire department notification and installed in accordance with NFPA "The National Fire Alarm Code" 1999 edition. Other hazardous areas have either heat detection or smoke detection that are on the fire alarm system in accordance with the Minnesota State Fire Code 2007 edition. The sleeping rooms in the 1961 and 1968 sections have battery operated smoke detectors in them and the sleeping rooms in the 1993 and 1996 additions have smoke detectors that are wired to the facilities electrical system that alarm in accordance with the Minnesota State Fire Code 2007 edition.</p> <p>The facility has a capacity of 56 beds and had a census of 44 at the time of the survey.</p> <p>Because the buildings and all additions meet the construction types allowed for existing Health Care buildings, the facility was surveyed as one building.</p>	K 000			