

DEPARTMENT OF HEALTH AND HUMAN SERVICES

CENTERS FOR MEDICARE & MEDICAID SERVICES

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 5K7U

Facility ID: 00668

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245564	3. NAME AND ADDRESS OF FACILITY (L3) BROWNS VALLEY HEALTH CENTER (L4) 114 JEFFERSON STREET SOUTH (L5) BROWNS VALLEY, MN (L6) 56219	4. TYPE OF ACTION: <u>7</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint
2. STATE VENDOR OR MEDICAID NO. (L2) 990343700	5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)	7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE
6. DATE OF SURVEY 08/28/2015 (L34)	8. ACCREDITATION STATUS: ___ (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other	FISCAL YEAR ENDING DATE: (L35) 06/30
11. LTC PERIOD OF CERTIFICATION From (a): To (b):	10. THE FACILITY IS CERTIFIED AS: X A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements ___ 2. Technical Personnel ___ 6. Scope of Services Limit Compliance Based On: ___ 3. 24 Hour RN ___ 7. Medical Director ___ 1. Acceptable POC ___ 4. 7-Day RN (Rural SNF) ___ 8. Patient Room Size ___ 5. Life Safety Code ___ 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: A* (L12)	12. Total Facility Beds 38 (L18)
13. Total Certified Beds 38 (L17)	14. LTC CERTIFIED BED BREAKDOWN 18 SNF 18/19 SNF 19 SNF ICF IID 38 (L37) (L38) (L39) (L42) (L43)	15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE): See Attached Remarks		
17. SURVEYOR SIGNATURE <u>James Anderson, DSFM</u>	Date: 10/19/2015 (L19)	18. STATE SURVEY AGENCY APPROVAL <u>Mark Meath, Enforcement Specialist</u> Date: 12/22/2015 (L20)
PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY		
19. DETERMINATION OF ELIGIBILITY <input checked="" type="checkbox"/> 1. Facility is Eligible to Participate <input type="checkbox"/> 2. Facility is not Eligible (L21)	20. COMPLIANCE WITH CIVIL RIGHTS ACT:	21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above: _____
22. ORIGINAL DATE OF PARTICIPATION 06/01/1991 (L24)	23. LTC AGREEMENT BEGINNING DATE (L41)	24. LTC AGREEMENT ENDING DATE (L25)
25. LTC EXTENSION DATE: (L27)	27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)	26. TERMINATION ACTION: (L30) <u>VOLUNTARY</u> 00 <u>INVOLUNTARY</u> 01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement 03-Risk of Involuntary Termination <u>OTHER</u> 04-Other Reason for Withdrawal 07-Provider Status Change 00-Active
28. TERMINATION DATE:	29. INTERMEDIARY/CARRIER NO. 03001 (L28) (L31)	30. REMARKS DETERMINATION APPROVAL
31. RO RECEIPT OF CMS-1539 (L32)	32. DETERMINATION OF APPROVAL DATE 09/23/2015 (L33)	

C&T REMARKS - CMS 1539 FORM

STATE AGENCY REMARKS

CCN: 24 5564

On August 28, 2015 a Life Safety Code (LSC) Post Certification Revisit was completed at this facility and found the deficiencies issued pursuant to the July 30, 2015 standard survey had been corrected, effective August 12, 2015.

Effective August 12, 2015, the facility is certified for 38 skilled nursing facility beds.



CMS Certification Number (CCN): 245564

December 15, 2015

Ms. Autumn Roark, Administrator
Browns Valley Health Center
114 Jefferson Street South
Browns Valley, Minnesota 56219

Dear Ms. Roark:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective August 12, 2015 the above facility is certified for:

38 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 38 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath".

Mark Meath, Enforcement Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
Email: mark.meath@state.mn.us
Telephone: (651) 201-4118 Fax: (651) 215-9697



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
October 19, 2015

Ms. Autumn Roark, Administrator
Browns Valley Health Center
114 Jefferson Street South
Browns Valley, Minnesota 56219

RE: Project Number F5564023

Dear Ms. Roark:

On August 5, 2015, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on July 30, 2015. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), whereby corrections were required.

On August 28, 2015, the Minnesota Department of Public Safety completed a Post Certification Revisit (PCR) to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on July 30, 2015. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of August 12, 2015. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on July 30, 2015, effective August 12, 2015 and therefore remedies outlined in our letter to you dated August 5, 2015, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions related to this letter / eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath".

Mark Meath, Enforcement Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
Email: mark.meath@state.mn.us
Telephone: (651) 201-4118 Fax: (651) 215-9697

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245564	(Y2) Multiple Construction A. Building 01 - MAIN BUILDING 01 B. Wing	(Y3) Date of Revisit 8/28/2015
Name of Facility BROWNS VALLEY HEALTH CENTER	Street Address, City, State, Zip Code 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219	

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix _____ Reg. # NFPA 101 LSC <u>K0025</u>	Correction Completed 08/12/2015	ID Prefix _____ Reg. # NFPA 101 LSC <u>K0052</u>	Correction Completed 08/12/2015	ID Prefix _____ Reg. # NFPA 101 LSC <u>K0067</u>	Correction Completed 08/12/2015
ID Prefix _____ Reg. # NFPA 101 LSC <u>K0073</u>	Correction Completed 08/12/2015	ID Prefix _____ Reg. # NFPA 101 LSC <u>K0144</u>	Correction Completed 08/12/2015	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

Reviewed By _____ State Agency	Reviewed By _____	Date:	Signature of Surveyor:	Date:		
Reviewed By _____ CMS RO	Reviewed By _____	Date:	Signature of Surveyor:	Date:		
Followup to Survey Completed on: 7/28/2015		Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? <table style="float: right; margin-left: 20px;"> <tr> <td>YES</td> <td>NO</td> </tr> </table>			YES	NO
YES	NO					

SURVEY TEAM COMPOSITION AND WORKLOAD REPORT

Public reporting burden for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing the burden, to Office of Financial Management, HCFA, P.O. Box 26684, Baltimore, MD 21207; or to the Office of Management and Budget, Paperwork Reduction Project(0838-0583), Washington, D.C. 20503.

Provider/Supplier Number 245564	Provider/Supplier Name BROWNS VALLEY HEALTH CENTER
------------------------------------	-------------------------------------------------------

Type of Survey (select all that apply):

D					
---	--	--	--	--	--

- A Complaint Investigation E Initial Certification I Recertification
- B Dumping Investigation F Inspection of Care J Sanction/Hearing
- C Federal Monitoring G Validation K State License
- D Follow-up Visit H Life safety Code L Chow

Extent of Survey (Select all that apply):

A					
---	--	--	--	--	--

- A Routine/Standard (all providers/suppliers)
- B Extended Survey (HHA or long term care facility)
- C Partial Extended Survey (HHA)
- D Other Survey

SURVEY TEAM AND WORKLOAD DATA

Please enter the workload information for each surveyor. Use the surveyor's information number.

Surveyor Id Number (A)	First Date Arrived (B)	Last Date Departed (C)	Pre-Survey Preparation Hours (D)	On-Site Hours 12am-8am (E)	On-Site Hours 8am-6pm (F)	On-Site Hours 6pm-12am (G)	Travel Hours (H)	Off-Site Report Preparation Hours (I)
1. Team Leader 27200	8/28/15	8/28/15	0.25	0.00	0.00	0.00	0.00	0.25
2.								
3.								
4.								
5.								
6.								
7.								
8.								
9.								
10.								

Total Supervisory Review Hours 0.25

Total Clerical/Data Entry Hours..... 0.25

Was Statement of Deficiencies given to the provider on-site at completion of the survey?



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
August 5, 2015

Ms. Autumn Roark, Administrator
Browns Valley Health Center
114 Jefferson Street South
Browns Valley, Minnesota 56219

RE: Project Number S5564025

Dear Ms. Roark:

On July 30, 2015, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

**Gail Anderson, Unit Supervisor
Fergus Falls Survey Team
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
Email: gail.anderson@state.mn.us**

Phone: (218) 332-5140

Fax: (218) 332-5196

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by September 8, 2015, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by September 8, 2015 the following remedy will be imposed:

- Per instance civil money penalties. (42 CFR 488.430 through 488.444)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by October 30, 2015 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement

of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by January 30, 2016 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Patrick Sheehan, Supervisor
Health Care Fire Inspections
State Fire Marshal Division
pat.sheehan@state.mn.us

Telephone: (651) 201-7205
Fax: (651) 215-0525


Browns Valley Health Center

August 5, 2015

Page 6

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath". The signature is written in a cursive style with a horizontal line underlining the first name.

Mark Meath, Enforcement Specialist

Program Assurance Unit

Licensing and Certification Program

Health Regulation Division

Minnesota Department of Health

Email: mark.meath@state.mn.us

Telephone: (651) 201-4118

Fax: (651) 215-9697

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 09/11/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 07/30/2015
--------------------------------------------------	-------------------------------------------------------------------------	----------------------------------------------------------------------	-----------------------------------------------------

NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219
------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>Browns Valley Health Center has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.</p> <p>The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.</p>	F 000		
-------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 08/12/2015
-----------------------------------------------------------------------------------------------------------	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

F5564023

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/28/2015
--------------------------------------------------	-------------------------------------------------------------------------	---------------------------------------------------------------------------------------------	-----------------------------------------------------

NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219
------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ON-SITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOU VERIFICATION.</p> <p>FIRE SAFETY</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division. At the time of this survey, Browns Valley Health Center was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145</p>	K 000		
-------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------	--	--

EPOC

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 08/12/2015
----------------------------------------------------------------------------------------------------	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1 St. Paul, MN 55101-5145, OR</p> <p>Or by email to: Marian.Whitney@state.mn.us or Angela.Kappenman@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. <p>Browns Valley Health Care is a 1-story building with a partial basement. The building was constructed at 2 different times. The original building was constructed in 1970 and was determined to be of Type II(111) construction. In 2001 an addition was added to the north that was determined to be of Type II(111) construction and is protected by a fire sprinkler system. Because the original building and the addition are of the same type construction, meet the construction type allowed for existing buildings, the facility was surveyed as one building.</p> <p>The building is fully sprinkler protected and the sprinkler system is installed in accordance with</p>	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 NFPA 13 the Standard for the Installation of Sprinkler Systems (1999 edition) The facility has a manual fire alarm system with corridor smoke detection and smoke detection in spaces open to the corridors. The system is monitored for automatic fire department notification and installed in accordance with NFPA 72 "The National Fire Alarm Code" (1999 edition). The facility has a capacity of 41 beds and had a census of 32 on the day of the survey. The requirement at 42 CFR, Subpart 483.70(a) are NOT MET.	K 000		
K 025 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Smoke barriers are constructed to provide at least a one half hour fire resistance rating in accordance with 8.3. Smoke barriers may terminate at an atrium wall. Windows are protected by fire-rated glazing or by wired glass panels and steel frames. A minimum of two separate compartments are provided on each floor. Dampers are not required in duct penetrations of smoke barriers in fully ducted heating, ventilating, and air conditioning systems. 19.3.7.3, 19.3.7.5, 19.1.6.3, 19.1.6.4 This STANDARD is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain 1 of several smoke barrier walls construction that meet the requirements of NFPA 101 - 2000 edition, Sections 19-3.7.3 and 8.3. This deficient practice could affect residents, staff and visitors by	K 025	Penetrations in Firewall have been filled with rated fire caulk, and a sweep of building has been performed looking for more penetrations. Done 7/29/15	8/12/15

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 025	Continued From page 3 allowing smoke to propagate from one smoke compartment to another. Findings include: On facility tour between 9:30 AM to 12:30 PM on 07/28/2015, observation revealed that there was a 1.5 by 2 inch penetration around communication wires that are passing through the smoke barrier wall above the corridor smoke barrier doors by resident room 171.	K 025		
K 052 SS=C	This deficient condition was verified by the Maintenance Supervisor (AR). NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system required for life safety is installed, tested, and maintained in accordance with NFPA 70 National Electrical Code and NFPA 72. The system has an approved maintenance and testing program complying with applicable requirements of NFPA 70 and 72. 9.6.1.4 This STANDARD is not met as evidenced by: Based on observation and staff interview, it was revealed that the facility had failed to install and maintain the fire alarm system in accordance with the requirements of 2000 NFPA 101, Sections 9.6, as well as 1999 NFPA 72. This deficient	K 052	Will remove plastic covered smoke detector and in the future do all work that will set off smoke detector in a different location. Done 7/29/15	8/12/15

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 052	Continued From page 4 condition could adversely affect the functioning of the fire alarm system, and could delay the timely notification and emergency actions for the facility thus negatively affecting all residents, staff, and visitors of the facility. Findings include: On facility tour between 9:30 AM to 12:30 PM on 07/28/2015, observations reveled during a facility walk through that the smoke detector that is located in the emergency generator room was covered by a sheet of plastic wrap that was taped to the detector head.	K 052		
K 067 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD Heating, ventilating, and air conditioning comply with the provisions of section 9.2 and are installed in accordance with the manufacturer's specifications. 19.5.2.1, 9.2, NFPA 90A, 19.5.2.2 This STANDARD is not met as evidenced by: Based on documentation review and staff interview, the fire/smoke damper system has not been maintained in accordance with the requirements of NFPA 90(99) section 3-4.7. This deficient practice does not ensure the proper operation of the fire/smoke dampers and could allow smoke migration to negatively affect the	K 067	A contract was setup to do Fire Damper checks on a 4 year basis with Protection Systems. In progress, waiting to hear back to come and inspect.	8/12/15

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 067	Continued From page 5 safety of all residents, staff and visitors in the event of a fire. Findings include: On facility tour between 9:30 AM to 12:30 PM on 07/28/2015, it was revealed during the review of the facility's fire and smoke damper test/inspection documentation and was confirmed by interview with the Maintenance Supervisor (AR), that the facility had failed to provide documentation verifying that the fire and smoke dampers have been tested/inspected within the last 4 years.	K 067			
K 073 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD No furnishings or decorations of highly flammable character are used. 19.7.5.2, 19.7.5.3, 19.7.5.4 This STANDARD is not met as evidenced by: Based on observations and staff interview, the facility failed to maintain combustible decoration in accordance with NFPA Life Safety Code 101 (00) section 19.7.5.4. The failure to treat and maintain the combustible decorations throughout the facility in accordance with NFPA Life Safety Code 101 (00) could allow smoke and fire to rapidly migrate through the corridors and negatively affect the egress capability in the event of an emergency for residents, visitors and staff of the facility.	K 073	Decorations on outer corridor resident doors will be removed entirely and a new policy requiring the outsides of our corridor doors to be clear will be implemented. Family and Residents notified and decorations will be removed on 8/14/15	8/12/15	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 073	Continued From page 6 Findings include: On facility tour between 9:30 AM to 12:30 PM on 07/28/2015, observations revealed that the facility could not verify if the decoration that are hanging on resident room doors are flames retardant of if they have been treated with any type of approved flame retardant treatment.	K 073		
K 144 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD Generators are inspected weekly and exercised under load for 30 minutes per month in accordance with NFPA 99. 3.4.4.1. This STANDARD is not met as evidenced by: Based on documentation review and staff interview, the facility failed to test the emergency generators in accordance with the requirements of 2000 NFPA 101 - 9.1.3 and 1999 NFPA 110 6-4.2 (a) & (b) and 6-4.2.2. The deficient practice could affect all patients, staff, and visitors. Findings include: On facility tour between 9:30 AM to 12:30 PM on	K 144	Generator logs are to be filled out in accordance with the guidelines set by the State of Minnesota. Done 7/29/15	8/12/15

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/27/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245564	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/28/2015
NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 144	Continued From page 7 07/28/2015, documentation review of the emergency generator testing logs reveled that the facility could not provide complete monthly generator testing reports for their generator maintenance program. The facility had documented that they ran their emergency generator for the minimum required time; but the facility could not provide any written documentation at the time of the inspection that all the monthly generator maintenance checks were completed during the monthly maintenance. This deficient condition was verified by the Maintenance Supervisor (AR).	K 144			



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
August 5, 2015

Ms. Autumn Roark, Administrator
Browns Valley Health Center
114 Jefferson Street South
Browns Valley, Minnesota 56219

Re: Project Number S5564025

Dear Ms. Roark:

The above facility survey was completed on July 30, 2015 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules and to investigate complaint number that was found to be unsubstantiated. At the time of the survey, the survey team from the Minnesota Department of Health, Health Regulation Division, noted no violations of these rules promulgated under Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10.

Electronically posted is the Minnesota Department of Health order form stating that no violations were noted at the time of this survey. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Please disregard the heading of the fourth column which states, "Provider's Plan of Correction." This applies to Federal deficiencies only. There is no requirement to submit a Plan of Correction.

Please note it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions related to this Notice.

Sincerely,

A handwritten signature in cursive script that reads "Mark Meath".

Mark Meath, Enforcement Specialist
Program Assurance Unit
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
Email: mark.meath@state.mn.us

Telephone: (651) 201-4118
Fax: (651) 215-9697

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00668	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 07/30/2015
--------------------------------------------------	------------------------------------------------------------------------	-----------------------------------------------------------------------	-----------------------------------------------------

NAME OF PROVIDER OR SUPPLIER BROWNS VALLEY HEALTH CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 114 JEFFERSON STREET SOUTH BROWNS VALLEY, MN 56219
------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	------------------------------------------------------------------------------------------------------------------------	---------------	-----------------------------------------------------------------------------------------------------------------	--------------------

2 000	<p>Initial Comments</p> <p>*****ATTENTION*****</p> <p>NH LICENSING CORRECTION ORDER</p> <p>In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.</p> <p>Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected.</p> <p>You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.</p> <p>INITIAL COMMENTS: The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the State form. Although no plan of correction is required, it is required that the facility acknowledge receipt of the electronic documents.</p>	2 000		
-------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------	--	--

Minnesota Department of Health LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 08/12/15
--------------------------------------------------------------------------------------------------------------------------------------	-------	------------------------------