



*Protecting, Maintaining and Improving the Health of All Minnesotans*

Electronically delivered

April 12, 2023

Administrator  
Minnesota Veterans Home - Silver Bay  
56 Outer Drive  
Silver Bay, MN 55614

RE: CCN: 245628  
Cycle Start Date: March 23, 2023

Dear Administrator:

On March 23, 2023, a survey was completed at your facility by the Minnesota Departments of Health and Public Safety, to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

#### **ELECTRONIC PLAN OF CORRECTION (ePoC)**

Within **ten (10) calendar days** after your receipt of this notice, you must submit an acceptable ePOC for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

The state agency may, in lieu of an onsite revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417);
- Civil money penalty (42 CFR 488.430 through 488.444).
- Termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

#### DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by an "F" and/or an "E" tag), i.e., the plan of correction should be directed to:

Judy Loecken, Unit Supervisor  
St. Cloud B District Office  
Licensing and Certification Program  
Health Regulation Division  
Minnesota Department of Health  
Midtown Square  
3333 Division Street, Suite 212  
Saint Cloud, Minnesota 56301-4557  
Email: judy.loecken@state.mn.us  
Office: (320) 223-7300 Mobile: (320) 241-7797

#### PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

#### VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

#### **FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY**

If substantial compliance with the regulations is not verified by June 23, 2023 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by September 23, 2023 (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

#### **INFORMAL DISPUTE RESOLUTION (IDR) / INDEPENDENT INFORMAL DISPUTE RESOLUTION (IIDR)**

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process  
Minnesota Department of Health  
Health Regulation Division  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: [https://mdhprovidercontent.web.health.state.mn.us/lrc\\_idr.cfm](https://mdhprovidercontent.web.health.state.mn.us/lrc_idr.cfm)

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: [https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04\\_8.html](https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04_8.html)

Minnesota Veterans Home - Silver Bay

April 12, 2023

Page 4

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

William Abderhalden, Fire Safety Supervisor  
Deputy State Fire Marshal  
Health Care/Corrections Supervisor – Interim  
Minnesota Department of Public Safety  
445 Minnesota Street, Suite 145  
St. Paul, MN 55101-5145  
Cell: (507) 361-6204  
Email: [william.abderhalden@state.mn.us](mailto:william.abderhalden@state.mn.us)  
Fax: (651) 215-0525

Feel free to contact me if you have questions.

Sincerely,



Holly Zahler, Compliance Analyst  
Federal Enforcement | Health Regulation Division  
Minnesota Department of Health  
P.O. Box 64900  
Saint Paul, Minnesota 55164-0970  
Phone: 651-201-4384  
Email: [holly.zahler@state.mn.us](mailto:holly.zahler@state.mn.us)

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/12/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>C</b> <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE</b> <b>SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments  On 3/20/23 - 3/23/23, a survey for compliance with Appendix Z, Emergency Preparedness Requirements, §483.73(b)(6) was conducted during a standard recertification survey. The facility was IN compliance.  The facility is enrolled in the electronic Plan of Correction (ePoC) and therefore a signature is not required at the bottom of the first page of the State form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.	E 000			
F 000	INITIAL COMMENTS  On 3/20/23 - 3/23/23, a standard recertification survey was conducted at your facility. A complaint investigation was also conducted. Your facility was IN compliance with the requirements of 42 CFR 483, Subpart B, Requirements for Long Term Care Facilities.  In addition to the recertification survey, the following complaints were reviewed  The following complaints were reviewed with no deficiency issued. H5628052C MN00081948 H56289439C MN00090219 H56289438C MN00091699 H56289437C MN00091781  The facility is enrolled in ePOC, therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, the facility must acknowledge receipt of the electronic documents.	F 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

04/13/2023

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
--	---	---	---

NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p><b>INITIAL COMMENTS</b></p> <p><b>FIRE SAFETY</b></p> <p>An annual Life Safety recertification survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division on 03/23/2023. At the time of this survey, Minnesota Veterans Home Silver Bay was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99, Health Care Facilities Code.</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>IF PARTICIPATING IN THE E-POC PROCESS, A PAPER COPY OF THE PLAN OF CORRECTION IS NOT REQUIRED.</p>	K 000		
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE  <b>Electronically Signed</b>	TITLE	(X6) DATE <b>04/20/2023</b>
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/01/2023  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR</p> <p>By email to: FM.HC.Inspections@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> <li>1. A detailed description of the corrective action taken or planned to correct the deficiency.</li> <li>2. Address the measures that will be put in place to ensure the deficiency does not reoccur.</li> <li>3. Indicate how the facility plans to monitor future performance to ensure solutions are sustained.</li> <li>4. Identify who is responsible for the corrective actions and monitoring of compliance.</li> <li>5. The actual or proposed date for completion of the remedy.</li> </ol> <p>Minnesota Veterans Home-Silver Bay is a one story building, partial basement original year of construction 1960's, and it was converted into a nursing home in the early 1990's. The original building and additions are all Type II(111) construction.</p> <p>The building is fully sprinkler protected. The facility has a complete fire alarm system with smoke detection in the corridors and spaces open to the corridor, that is monitored for</p>	K 000		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 automatic fire department notification.  The facility has a capacity of 83 beds and had a census of 80 at the time of the survey.  The requirements at 42 CFR, Subpart 483.70(a), are NOT MET as evidenced by:	K 000		
K 372 SS=F	Subdivision of Building Spaces - Smoke Barrie CFR(s): NFPA 101  Subdivision of Building Spaces - Smoke Barrier Construction 2012 EXISTING Smoke barriers shall be constructed to a 1/2-hour fire resistance rating per 8.5. Smoke barriers shall be permitted to terminate at an atrium wall. Smoke dampers are not required in duct penetrations in fully ducted HVAC systems where an approved sprinkler system is installed for smoke compartments adjacent to the smoke barrier. 19.3.7.3, 8.6.7.1(1) Describe any mechanical smoke control system in REMARKS. This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain their smoke barrier per NFPA 101 (2012 edition), Life Safety Code, sections 19.3.7.1, 19.3.7.3, 8.5.2.2, and 8.5.6.5. These deficient findings could have a widespread impact on the residents within the facility.  Findings include:  1) On 03/23/2023, between 9:30am and 12:30pm, it was revealed by observation that there was a penetration running from one smoke	K 372	Facility Citation Action: On Monday (4/24/2023) Peterson Sheet Metal will be on site to complete fire caulking in the smoke barrier penetrations noted by Fire Marshall.  Prevention Plan: Physical Plant Director will inspect the facility smoke barriers after contractors have done work in the facility.  Monitoring Plan: Physical Plan Director shall review facility shall review facility	4/24/23



STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 372	Continued From page 3 compartment to another above doors at west end of corridor.  2) On 03/23/2023, between 9:30am and 12:30pm, it was revealed by observation that there was a penetration running from one smoke compartment to another, on penthouse level, through smoke barrier wall and and were ceiling and wall surface meet along south wall.	K 372	blue prints for accuracy every 6 months x 2; then annually until 100% compliance is achieved. The Physical Plant Director will report findings in QAPI.	
K 511 SS=D	Utilities - Gas and Electric CFR(s): NFPA 101  Utilities - Gas and Electric Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life. 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2  This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to secure electrical panels per NFPA 99 (2012 edition), Health Care Facilities Code, section 6.3.2.2.1.3 and failed to maintain the Gas and Utility System per NFPA 101 (2012 edition), Life Safety Code section 9.2.2 and NFPA 54 (2012 edition), National Fuel Gas Code, sections 9.2.2 and 10.3.2.2. This deficient finding could have an isolated impact on the residents within	K 511	Facility Citation Action: Electrical panel was locked at the time noted by the Fire Marshall.  Prevention Plan: Physical Plant Director shall check all electrical panels in the facility daily after onsite contractors have been working in the facility.	3/23/23

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 511	Continued From page 4 the facility.  Findings include:  On 03/23/2023, between 9:30am and 12:30pm, it was revealed by observation that the electrical panel located in the main corridor area was not locked..  An interview with the Maintenance Director verified this deficient finding at the time of discovery.	K 511	Monitoring Plan: The Physical Plant Director shall continue the preventative maintenance monthly audits of the electrical panels and report to QAPI monthly x 3 until 100% compliance is achieved; then quarterly x 3 until 100% compliance is achieved.	
K 761 SS=F	Maintenance, Inspection & Testing - Doors CFR(s): NFPA 101  Maintenance, Inspection & Testing - Doors Fire doors assemblies are inspected and tested annually in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives. Non-rated doors, including corridor doors to patient rooms and smoke barrier doors, are routinely inspected as part of the facility maintenance program. Individuals performing the door inspections and testing possess knowledge, training or experience that demonstrates ability. Written records of inspection and testing are maintained and are available for review. 19.7.6, 8.3.3.1 (LSC) 5.2, 5.2.3 (2010 NFPA 80) This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to inspect fire doors per NFPA 101 (2012 edition), Life Safety Code section 8.3.3.1, and NFPA 80 (2010 edition), Standard for Fire Doors and Other Opening Protectives, section 5.2.1. This deficient	K 761	Facility Citation Action: The Physical Plant Director searched records for fire door inspection per NFPA 101 (2012 edition), Life Safety Code section 8.3.3.1, and NFPA 80 (2010 edition), Standard for Fire Doors and Other Opening	3/23/23

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 761	Continued From page 5 finding could have a widespread impact on the residents within the facility.  Findings include:  On 03/23/2023, between 9:30am and 12:30pm, it was revealed by a review of available documentation the required annual door inspection documentation was not available at the time of the survey.  An interview with Maintenance Director verified these deficient findings at the time of discovery.	K 761	Protectives, section 5.2.1. Records were found and placed into the Life Safety Code Book for compliance.  Prevention Plan: The Physical Plant Director will continue to file the fire door inspection audits in the Life Safety Code Book and have available for the Fire Marshall at times of inspection.  Monitoring Plan: The Physical Plant Director shall complete monthly audits to ensure fire door inspection reports continue to be located in the Life Safety Book, and report to QAPI monthly x 3 until 100% compliance is achieve; then quarterly x 3 until 100% compliance is achieved.	
K 920 SS=D	Electrical Equipment - Power Cords and Extens CFR(s): NFPA 101  Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assembles that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a	K 920		3/24/23

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245628</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MN VETS HOME</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>03/23/2023</b>
NAME OF PROVIDER OR SUPPLIER  <b>MINNESOTA VETERANS HOME - SILVER BAY</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>56 OUTER DRIVE SILVER BAY, MN 55614</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 920	<p>Continued From page 6</p> <p>substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4.</p> <p>10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on observation and staff interview, the facility failed to maintain the usage of electrical adaptive devices per NFPA 99 (2012 edition), Health Care Facilities Code, sections 10.5.2.3.1 and 10.2.4.2.1, NFPA 70, (2011 edition), National Electrical Code, sections 400-8, and UL 1363. This deficient finding could have an isolated impact on the residents within the facility.</p> <p>Findings include:</p> <p>On 03/23/2023 between 09:30am and 12:30pm, it was revealed by observation that there were several electrical appliances plugged into a power strip in Pharmacy Office area.</p> <p>An interview with the Maintenance Director verified this deficient finding at the time of discovery.</p>	K 920	<p>Facility Citation Action: On 3/24/2023 the power strip was removed and replaced with hospital grade outlet.</p> <p>Preventative Plan: Physical Plant Director shall complete random audits in the facility for power strip use monthly.</p> <p>Monitoring Plan: The Physical Plant Director shall continue the preventative maintenance monthly audits for power strips and report to QAPI monthly x 3 until 100% compliance is achieved; then quarterly x 3 until 100% compliance is achieved.</p>	