

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 82L9
Facility ID: 00806

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245229		3. NAME AND ADDRESS OF FACILITY (L3) FRIENDSHIP VILLAGE OF BLOOMINGTON (L4) 8100 HIGHWOOD DRIVE (L5) BLOOMINGTON, MN (L6) 55438			4. TYPE OF ACTION: <u>7</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint	
2.STATE VENDOR OR MEDICAID NO. (L2)		5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)			7. PROVIDER/SUPPLIER CATEGORY <u>04</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA	
6. DATE OF SURVEY 06/16/2014 (L34)		8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other			FISCAL YEAR ENDING DATE: (L35) 12/31	
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) :		10.THE FACILITY IS CERTIFIED AS: X A. In Compliance With Program Requirements Compliance Based On: 1. Acceptable POC			And/Or Approved Waivers Of The Following Requirements: 2. Technical Personnel 6. Scope of Services Limit 3. 24 Hour RN 7. Medical Director 4. 7-Day RN (Rural SNF) 8. Patient Room Size 5. Life Safety Code 9. Beds/Room	
12.Total Facility Beds 119 (L18)		B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: A (L12)				
13.Total Certified Beds 66 (L17)						
14. LTC CERTIFIED BED BREAKDOWN 18 SNF 18/19 SNF 19 SNF ICF IID 66 (L37) (L38) (L39) (L42) (L43)				15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)		
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE): See Attached Remarks						
17. SURVEYOR SIGNATURE <u>Robert Rexeisen, SFMO</u>			Date : 06/16/2014 (L19)	18. STATE SURVEY AGENCY APPROVAL <u>Anne Kleppe, Enforcement Specialist</u>		
				Date: 06/16/2014 (L20)		
PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY						
19. DETERMINATION OF ELIGIBILITY <input checked="" type="checkbox"/> 1. Facility is Eligible to Participate <input type="checkbox"/> 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____		
22. ORIGINAL DATE OF PARTICIPATION 01/29/1980 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)	24. LTC AGREEMENT ENDING DATE (L25)		26. TERMINATION ACTION: (L30) VOLUNTARY <u>00</u> INVOLUNTARY 01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement 03-Risk of Involuntary Termination 04-Other Reason for Withdrawal OTHER 07-Provider Status Change 00-Active	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)				
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 03001 (L28) (L31)		30. REMARKS Posted 07/16/2014 Co.		
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE 06/18/2014 (L33)			DETERMINATION APPROVAL	

C&T REMARKS - CMS 1539 FORM

STATE AGENCY REMARKS

CCN: 24-5229

On 06/16/14, a Post Certification Revisit (PCR) was completed by the Minnesota Department of Public Safety. Based on the PCR, it has been determined that the facility had achieved substantial compliance pursuant to the 05/22/14 standard survey, effective 06/13/14. Refer to the CMS 2567b for both health and life safety code. Effective 06/13/14, the facility is certified for 66 skilled nursing facility beds.



Protecting, Maintaining and Improving the Health of Minnesotans

CMS Certification Number (CCN): 24-5229

Electronically Delivered: June 19, 2014

Mr. Ronald Donacik, Administrator
Friendship Village of Bloomington
8100 Highwood Drive
Bloomington, Minnesota 55438

Dear Mr. Donacik:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective June 13, 2014, the above facility is certified for:

66 - Skilled Nursing Facility

Your facility's Medicare approved area consists of all 66 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status. Please note, it is your responsibility to share the information contained in this letter and the results of this PCR with the President of your facility's Governing Body.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination. Please contact me if you have any questions about this electronic notice.

Sincerely,

A handwritten signature in cursive script that reads "Anne Kleppe".

Anne Kleppe, Enforcement Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Minnesota Department of Health
Telephone: (651) 201-4124 Fax: (651) 215-9697



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically Delivered: June 19, 2014

Mr. Ronald Donacik, Administrator
Friendship Village of Bloomington
8100 Highwood Drive
Bloomington, Minnesota 55438

RE: Project Number F5229023

Dear Mr. Donacik:

On May 28, 2014, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on May 22, 2014 that included an investigation of complaint number . This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On June 16, 2014, the Minnesota Department of Public Safety completed a Post Certification Revisit (PCR) to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on May 22, 2014. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of June 13, 2014. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on May 22, 2014, effective June 13, 2014 and therefore remedies outlined in our letter to you dated May 28, 2014, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body. Feel free to contact me if you have questions about this electronic notice.

Sincerely,

A handwritten signature in cursive script that reads "Anne Kleppe".

Anne Kleppe, Enforcement Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Minnesota Department of Health
Email: anne.kleppe@state.mn.us
Telephone: (651) 201-4124
Fax: (651) 215-9697

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245229	(Y2) Multiple Construction A. Building 01 - MAIN BUILDING 01 B. Wing	(Y3) Date of Revisit 6/16/2014
Name of Facility FRIENDSHIP VILLAGE OF BLOOMINGTON		Street Address, City, State, Zip Code 8100 HIGHWOOD DRIVE BLOOMINGTON, MN 55438

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix _____ Reg. # NFPA 101 LSC K0029	Correction Completed 06/13/2014	ID Prefix _____ Reg. # NFPA 101 LSC K0144	Correction Completed 06/05/2014	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

Reviewed By _____ State Agency	Reviewed By PS/AK	Date: 06/19/2014	Signature of Surveyor: 28120	Date: 06/16/2014
Reviewed By _____ CMS RO	Reviewed By	Date:	Signature of Surveyor:	Date:

Followup to Survey Completed on: 5/22/2014	Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? <table style="float: right; margin-left: 20px;"> <tr> <td>YES</td> <td>NO</td> </tr> </table>	YES	NO
YES	NO		

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 82L9
Facility ID: 00806

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245229
2. STATE VENDOR OR MEDICAID NO. (L2)
3. NAME AND ADDRESS OF FACILITY (L3) FRIENDSHIP VILLAGE OF BLOOMINGTON (L4) 8100 HIGHWOOD DRIVE (L5) BLOOMINGTON, MN (L6) 55438
4. TYPE OF ACTION: 2 (L8)
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)
6. DATE OF SURVEY 05/22/2014 (L34)
7. PROVIDER/SUPPLIER CATEGORY 04 (L7)
8. ACCREDITATION STATUS: (L10)
9. FISCAL YEAR ENDING DATE: 12/31 (L35)

11. LTC PERIOD OF CERTIFICATION
12. Total Facility Beds 66 (L18)
13. Total Certified Beds 66 (L17)
10. THE FACILITY IS CERTIFIED AS:
A. In Compliance With
B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: B* (L12)

14. LTC CERTIFIED BED BREAKDOWN
18 SNF 66 (L37)
18/19 SNF (L38)
19 SNF (L39)
ICF (L42)
IID (L43)
15. FACILITY MEETS
1861 (e) (1) or 1861 (j) (1): (L15)

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):
See Attached Remarks

17. SURVEYOR SIGNATURE
Lisa Hakanson HPR Dietary Specialist
Date: 06/12/2014 (L19)
18. STATE SURVEY AGENCY APPROVAL
Anne Kleppe, Enforcement Specialist
Date: 06/16/2014 (L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY
20. COMPLIANCE WITH CIVIL RIGHTS ACT:
21. 1. Statement of Financial Solvency (HCFA-2572)
2. Ownership/Control Interest Disclosure Stmt (HCFA-1513)
3. Both of the Above :

22. ORIGINAL DATE OF PARTICIPATION 01/29/1980 (L24)
23. LTC AGREEMENT BEGINNING DATE (L41)
24. LTC AGREEMENT ENDING DATE (L25)
26. TERMINATION ACTION: 00 (L30)
25. LTC EXTENSION DATE: (L27)
27. ALTERNATIVE SANCTIONS
A. Suspension of Admissions: (L44)
B. Rescind Suspension Date: (L45)

28. TERMINATION DATE: (L28)
29. INTERMEDIARY/CARRIER NO. 03001 (L31)
30. REMARKS

31. RO RECEIPT OF CMS-1539 (L32)
32. DETERMINATION OF APPROVAL DATE (L33)
DETERMINATION APPROVAL

CCN: 24-5229

At the time of the standard survey completed 05/22/14, the facility was not in substantial compliance and the most serious deficiencies were found to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), whereby corrections were required as evidenced by the attached CMS-2567. The facility has been given an opportunity to correct before remedies are imposed. Post Certification Revisit to follow.



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
May 28, 2014

Mr. Ronald Donacik, Administrator
Friendship Village Of Bloomington
8100 Highwood Drive
Bloomington, Minnesota 55438

RE: Project Number S5229024 & F5229023

Dear Mr. Donacik:

On May 22, 2014, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Gayle Lantto, Unit Supervisor
Minnesota Department of Health
P.O. Box 64900
St. Paul, Minnesota 55108-2970
Telephone: (651) 201-3794
Fax: (651) 201-3790

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by July 1, 2014, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by July 1, 2014 the following remedy will be imposed:

- Per instance civil money penalties. (42 CFR 488.430 through 488.444)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;

- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by August 22, 2014 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by November 22, 2014 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Division of Compliance Monitoring
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at:

http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

Friendship Village Of Bloomington

May 28, 2014

Page 5

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at:

<http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Patrick Sheehan, Supervisor
Health Care Fire Inspections
State Fire Marshal Division
pat.sheehan@state.mn.us
Telephone: (651) 201-7205
Fax: (651) 215-0541

Feel free to contact me if you have questions.

Sincerely,



Kate Johnston, Program Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Telephone: (651) 201-3992 Fax: (651) 215-9697

Enclosure (s)

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/28/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245229	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/22/2014
--	---	--	---

NAME OF PROVIDER OR SUPPLIER FRIENDSHIP VILLAGE OF BLOOMINGTON	STREET ADDRESS, CITY, STATE, ZIP CODE 8100 HIGHWOOD DRIVE BLOOMINGTON, MN 55438
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>Friendship Village of Bloomington is in full compliance with requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.</p>	F 000		
-------	---	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245229	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/22/2014
NAME OF PROVIDER OR SUPPLIER FRIENDSHIP VILLAGE OF BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 8100 HIGHWOOD DRIVE BLOOMINGTON, MN 55438	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety. At the time of this survey, Friendship Village of Bloomington was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR</p> <p>By email to:</p>	K 000		

EPOC

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE
Electronically Signed

TITLE

(X6) DATE
06/05/2014

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245229	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/22/2014
NAME OF PROVIDER OR SUPPLIER FRIENDSHIP VILLAGE OF BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 8100 HIGHWOOD DRIVE BLOOMINGTON, MN 55438	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 Marian.Whitney@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. Friendship Village of Bloomington is a 2-story building with partial basement. The building was constructed at 2 different times. The original building was constructed in 1979 and was determined to be of Type V(111) construction. In 2003, an addition was constructed and was determined to be of Type II(111) construction. Because the original building and the 1 addition met the construction type allowed for existing buildings, the facility was surveyed as one building. The building is fully fire sprinklered. The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors which are monitored for automatic fire department notification. The facility has a capacity of 66 beds and had a census of 59 at time of the survey. The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by:	K 000		
K 029	NFPA 101 LIFE SAFETY CODE STANDARD	K 029		6/13/14

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245229	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/22/2014
NAME OF PROVIDER OR SUPPLIER FRIENDSHIP VILLAGE OF BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 8100 HIGHWOOD DRIVE BLOOMINGTON, MN 55438	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 029 SS=D	Continued From page 2 One hour fire rated construction (with ¾ hour fire-rated doors) or an approved automatic fire extinguishing system in accordance with 8.4.1 and/or 19.3.5.4 protects hazardous areas. When the approved automatic fire extinguishing system option is used, the areas are separated from other spaces by smoke resisting partitions and doors. Doors are self-closing and non-rated or field-applied protective plates that do not exceed 48 inches from the bottom of the door are permitted. 19.3.2.1 This STANDARD is not met as evidenced by: Based on observation and interview, the hazardous areas are not maintained in accordance with NFPA 101-2000, Section 19.3.2.1. This deficient practice could affect some residents. Findings include: During facility tour between 9:15 AM and 10:45 AM on 05/22/2014, observation revealed that the soiled linen room door in the Maple Leaf wing does not latch closed. There is also a gap between the top of the door and door frame. This deficient practice was verified by the Maintenance Director at the time of the inspection.	K 029	The door will be fixed by Contract Hardware the week of June 9, 2014. Director of Facilities is responsible for this.	
K 144 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD Generators are inspected weekly and exercised under load for 30 minutes per month in	K 144		6/5/14

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245229	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/22/2014
NAME OF PROVIDER OR SUPPLIER FRIENDSHIP VILLAGE OF BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 8100 HIGHWOOD DRIVE BLOOMINGTON, MN 55438		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 144	Continued From page 3 accordance with NFPA 99. 3.4.4.1. This STANDARD is not met as evidenced by: Based on record review and interview, the facility's emergency generators do not comply with NFPA 99 Health Care Facilities (1999 edition) nor NFPA 110 Standard for Standby Power Systems (1998 edition). This deficient practice could affect all residents. Findings include: On facility tour between 9:15 AM and 10:45 AM on 05/22/2014, record review revealed that: 1. The Aspen generator, which has a diesel prime mover, is being run for only 15 minutes and not the required 30 minutes at operating temperature 2. There is no documentation of testing for the Linden generator for the months of August through December of 2013. Also, this generator which has a natural gas prime mover, is being run for only 15 minutes and not the required 30 minutes. These deficient practices were verified by the Maintenance Director at the time of the inspection.	K 144	All generators when tested weekly will be run for atleast 30 minutes. All tests will be done weekly and recorded in log sheet. These logs will be audited monthly by facilities Operatios Coordinator (my assistant).		