

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL  
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 94F1  
Facility ID: 27996

1. MEDICARE/MEDICAID PROVIDER NO. (L1) <b>245618</b>		3. NAME AND ADDRESS OF FACILITY (L3) <b>WALKER METHODIST WESTWOOD RIDGE II</b>			4. TYPE OF ACTION: <u>7</u>	
2.STATE VENDOR OR MEDICAID NO. (L2)		(L4) <b>61 THOMPSON AVENUE WEST</b>			1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>04</u> (L7)			8. Full Survey After Complaint	
6. DATE OF SURVEY <b>05/12/2016</b> (L34)		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA			FISCAL YEAR ENDING DATE: (L35)	
8. ACCREDITATION STATUS: <u>    </u> (L10)		02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF			<b>12/31</b>	
0 Unaccredited 1 TJC 2 AOA 3 Other		03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC				
11. LTC PERIOD OF CERTIFICATION		04 SNF 08 OPT/SP 12 RHC 16 HOSPICE				
From (a) : To (b) :		10.THE FACILITY IS CERTIFIED AS:				
12.Total Facility Beds <b>37</b> (L18)		X A. In Compliance With			And/Or Approved Waivers Of The Following Requirements: _____	
13.Total Certified Beds <b>37</b> (L17)		Program Requirements _____ 2. Technical Personnel _____ 6. Scope of Services Limit				
		Compliance Based On:			_____ 3. 24 Hour RN _____ 7. Medical Director	
		_____ 1. Acceptable POC			_____ 4. 7-Day RN (Rural SNF) _____ 8. Patient Room Size	
		B. Not in Compliance with Program			_____ 5. Life Safety Code _____ 9. Beds/Room	
		Requirements and/or Applied Waivers: * Code: <b>A*</b> (L12)				
14. LTC CERTIFIED BED BREAKDOWN				15. FACILITY MEETS		
18 SNF	18/19 SNF	19 SNF	ICF	1861 (e) (1) or 1861 (j) (1):		(L15)
37						
(L37)	(L38)	(L39)	(L42)	(L43)		

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE		Date :	18. STATE SURVEY AGENCY APPROVAL		Date:
<u>Kimberly Swenson, DSFM</u>		03/02/2016	<u>Kate JohnsTon, Program Specialist</u>		05/03//2016
		(L19)			(L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____	
<input checked="" type="checkbox"/> 1. Facility is Eligible to Participate <input type="checkbox"/> 2. Facility is not Eligible (L21)					
22. ORIGINAL DATE OF PARTICIPATION <b>11/21/2012</b> (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		26. TERMINATION ACTION: (L30)	
		24. LTC AGREEMENT ENDING DATE (L25)		<u>VOLUNTARY</u> <u>00</u> <u>INVOLUNTARY</u>	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS		01-Merger, Closure 02-Dissatisfaction W/ Reimbursement 03-Risk of Involuntary Termination 04-Other Reason for Withdrawal	
		A. Suspension of Admissions: (L44)		05-Fail to Meet Health/Safety 06-Fail to Meet Agreement	
		B. Rescind Suspension Date: (L45)		<u>OTHER</u> 07-Provider Status Change 00-Active	
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. <b>00320</b> (L28)		30. REMARKS	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE <b>03/10/2016</b> (L33)		DETERMINATION APPROVAL	



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

CMS Certification Number (CCN): 245618  
May 3, 2016

Ms. Brenda Schrupp, Administrator  
Walker Methodist Westwood Ridge II  
61 Thompson Avenue West  
West Saint Paul, Minnesota 55118

Dear Ms. Schrupp:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective March 1, 2016 the above facility is certified for or recommended for:

37 Skilled Nursing Facility Beds

Your facility's Medicare approved area consists of all 37 skilled nursing facility beds located in rooms .

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Walker Methodist Westwood Ridge II

May 3, 2016

Page 2

Sincerely,

A handwritten signature in black ink, appearing to read "Kate Johnston". The signature is fluid and cursive, with a long horizontal flourish extending to the right.

Kate JohnsTon, Program Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
85 East Seventh Place, Suite 220  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900  
kate.johnston@state.mn.us  
Telephone: (651) 201-3992 Fax: (651) 215-9697

cc: Licensing and Certification File



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered  
May 3, 2016

Ms. Brenda Schrupp, Administrator  
Walker Methodist Westwood Ridge II  
61 Thompson Avenue West  
West Saint Paul, Minnesota 55118

RE: Project Number F5618004

Dear Ms. Schrupp:

On February 8, 2016, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on January 27, 2016. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On March 2, 2016 the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on January 27, 2016. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of March 1, 2016. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on January 27, 2016, effective March 1, 2016 and therefore remedies outlined in our letter to you dated February 8, 2016, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Walker Methodist Westwood Ridge II

May 3, 2016

Page 2

Sincerely,

A handwritten signature in black ink that reads "Kate Johnston". The signature is fluid and cursive, with a long horizontal flourish extending to the right.

Kate JohnsTon, Program Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
85 East Seventh Place, Suite 220  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900  
kate.johnston@state.mn.us  
Telephone: (651) 201-3992 Fax: (651) 215-9697

Enclosure

cc: Licensing and Certification File

## STATE FORM: REVISIT REPORT

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 27996	MULTIPLE CONSTRUCTION A. Building B. Wing	DATE OF REVISIT 5/12/2016
NAME OF FACILITY WALKER METHODIST WESTWOOD RIDGE II		STREET ADDRESS, CITY, STATE, ZIP CODE 61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118

This report is completed by a State surveyor to show those deficiencies previously reported that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the State Survey Report (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix 21426	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # MN St. Statute 144A.04 Subd. 3	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____	03/07/2016	LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	

REVIEWED BY STATE AGENCY <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	SIGNATURE OF SURVEYOR	DATE
REVIEWED BY CMS RO <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	TITLE	DATE
FOLLOWUP TO SURVEY COMPLETED ON 1/27/2016		<input type="checkbox"/> CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY? <input type="checkbox"/> YES <input type="checkbox"/> NO		

## POST-CERTIFICATION REVISIT REPORT

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 245618	Y1	MULTIPLE CONSTRUCTION A. Building 01 - MAIN BUILDING B. Wing	Y2	DATE OF REVISIT 3/2/2016	Y3
NAME OF FACILITY WALKER METHODIST WESTWOOD RIDGE II			STREET ADDRESS, CITY, STATE, ZIP CODE 61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118		

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction, that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix _____ Reg. # NFPA 101 LSC K0027	Correction Completed 03/01/2016	ID Prefix _____ Reg. # NFPA 101 LSC K0147	Correction Completed 03/01/2016	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed _____

REVIEWED BY STATE AGENCY <input type="checkbox"/>	REVIEWED BY (INITIALS) TL/KJ	DATE 05/03/2016	SIGNATURE OF SURVEYOR 34764	DATE 03/02/2016
REVIEWED BY CMS RO <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	TITLE	DATE

FOLLOWUP TO SURVEY COMPLETED ON 1/27/2016	<input type="checkbox"/> CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY?	<input type="checkbox"/> YES <input type="checkbox"/> NO
--	---	--



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered  
May 26, 2016

Ms. Brenda Schrupp, Administrator  
Walker Methodist Westwood Ridge II  
61 Thompson Avenue West  
West Saint Paul, Minnesota 55118

Re: Reinspection Results - Project Number S5618003

Dear Ms. Schrupp:

On May 12, 2016 survey staff of the Minnesota Department of Health, Licensing and Certification Program completed a reinspection of your facility, to determine correction of orders found on the survey completed on May 12, 2016. At this time these correction orders were found corrected and are listed on the accompanying Revisit Report Form submitted to you electronically.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,

A handwritten signature in black ink that reads "Kate Johnston". The signature is fluid and cursive, with a long horizontal flourish extending to the right.

Kate JohnsTon, Program Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
85 East Seventh Place, Suite 220  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900  
kate.johnston@state.mn.us  
Telephone: (651) 201-3992 Fax: (651) 215-9697



**STATE FORM: REVISIT REPORT**

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 27996 <span style="float:right">Y1</span>	MULTIPLE CONSTRUCTION A. Building B. Wing	DATE OF REVISIT 5/12/2016 <span style="float:right">Y3</span>
NAME OF FACILITY WALKER METHODIST WESTWOOD RIDGE II		STREET ADDRESS, CITY, STATE, ZIP CODE 61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118

This report is completed by a State surveyor to show those deficiencies previously reported that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the State Survey Report (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix 21426	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # MN St. Statute 144A.04 Subd. 3	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____	03/07/2016	LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____		LSC _____		LSC _____	

REVIEWED BY STATE AGENCY <input type="checkbox"/>	REVIEWED BY (INITIALS) SR/KJ	DATE 05/26/2016	SIGNATURE OF SURVEYOR 22580	DATE 05/12/2016
REVIEWED BY CMS RO <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	TITLE	DATE

FOLLOWUP TO SURVEY COMPLETED ON 1/27/2016

CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY?  YES  NO

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL  
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: 94F1  
Facility ID: 27996

1. MEDICARE/MEDICAID PROVIDER NO. (L1) <b>245618</b>		3. NAME AND ADDRESS OF FACILITY (L3) <b>WALKER METHODIST WESTWOOD RIDGE II</b> (L4) <b>61 THOMPSON AVENUE WEST</b> (L5) <b>WEST SAINT PAUL, MN</b> (L6) <b>55118</b>			4. TYPE OF ACTION: <u>2</u> (L8)  1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other  8. Full Survey After Complaint	
2.STATE VENDOR OR MEDICAID NO. (L2)		5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)			7. PROVIDER/SUPPLIER CATEGORY <u>04</u> (L7) <b>01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA</b> <b>02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF</b> <b>03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC</b> <b>04 SNF 08 OPT/SP 12 RHC 16 HOSPICE</b>	
6. DATE OF SURVEY <b>01/27/2016</b> (L34)		8. ACCREDITATION STATUS: <u>    </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other			FISCAL YEAR ENDING DATE: (L35) <b>12/31</b>	
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) :		10. THE FACILITY IS CERTIFIED AS: <b>X</b> A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements <u>    </u> 2. Technical Personnel <u>    </u> 6. Scope of Services Limit Compliance Based On: <u>    </u> 1. Acceptable POC <u>    </u> 3. 24 Hour RN <u>    </u> 7. Medical Director <u>    </u> 4. 7-Day RN (Rural SNF) <u>    </u> 8. Patient Room Size <u>    </u> 5. Life Safety Code <u>    </u> 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: <b>A*</b> (L12)			12.Total Facility Beds <b>37</b> (L18) 13.Total Certified Beds <b>37</b> (L17)	
14. LTC CERTIFIED BED BREAKDOWN 18 SNF 18/19 SNF 19 SNF ICF IID 37 (L37) (L38) (L39) (L42) (L43)				15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)		

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE  <u>Mary Heim, HPR Social Work Specialist</u> (L19)	Date : <b>02/18/2016</b>	18. STATE SURVEY AGENCY APPROVAL  <u>Kate JohnsTon, Program Specialist</u> (L20)	Date: <b>03/09/2016</b>
---	-----------------------------	---	----------------------------

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY <u>    </u> 1. Facility is Eligible to Participate <u>    </u> 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT:  <u>    </u>		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : <u>    </u>	
22. ORIGINAL DATE OF PARTICIPATION <b>11/21/2012</b> (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		24. LTC AGREEMENT ENDING DATE (L25)	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)		26. TERMINATION ACTION: (L30) <b>00</b> <u>VOLUNTARY</u> 01-Merger, Closure 02-Dissatisfaction W/ Reimbursement 03-Risk of Involuntary Termination 04-Other Reason for Withdrawal <u>INVOLUNTARY</u> 05-Fail to Meet Health/Safety 06-Fail to Meet Agreement <u>OTHER</u> 07-Provider Status Change 00-Active	
28. TERMINATION DATE: (L28)		29. INTERMEDIARY/CARRIER NO. <b>00320</b> (L31)		30. REMARKS	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE (L33)		DETERMINATION APPROVAL	



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered  
February 8, 2016

Ms. Brenda Schrupp, Administrator  
Walker Methodist Westwood Ridge II  
61 Thompson Avenue West  
West Saint Paul, Minnesota 55118

RE: Projects Numbered S5618003 & F5618004

Dear Ms. Schrupp:

On January 27, 2016, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

**Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.**

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

**Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;**

**Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;**

**Remedies - the type of remedies that will be imposed with the authorization of the**

**Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;**

**Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and**

**Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.**

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

#### **DEPARTMENT CONTACT**

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

**Susanne Reuss, Unit Supervisor  
Minnesota Department of Health  
Licensing and Certification Program  
Health Regulation Division  
P.O. Box 64900  
85 East Seventh Place, Suite 220  
St. Paul, Minnesota 55164-0900  
Telephone: (651) 201-3793  
Fax: 651-215-9697**

#### **OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES**

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by March 7, 2016, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by March 7, 2016 the following remedy will be imposed:

- Per instance civil money penalty. (42 CFR 488.430 through 488.444)

#### **ELECTRONIC PLAN OF CORRECTION (ePoC)**

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

#### **PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE**

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

#### **VERIFICATION OF SUBSTANTIAL COMPLIANCE**

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

#### **Original deficiencies not corrected**

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

#### **Original deficiencies not corrected and new deficiencies found during the revisit**

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

#### **Original deficiencies corrected but new deficiencies found during the revisit**

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

#### **FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY**

If substantial compliance with the regulations is not verified by April 27, 2016 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by July 27, 2016 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

### **INFORMAL DISPUTE RESOLUTION**

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

**Nursing Home Informal Dispute Process  
Minnesota Department of Health  
Health Regulation Division  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900**

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: [http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc\\_idr.cfm](http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm)

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

**Mr. Tom Linhoff, Supervisor  
Health Care Fire Inspections  
State Fire Marshal Division  
Email: [tom.linhoff@state.mn.us](mailto:tom.linhoff@state.mn.us)  
Telephone: (651) 201-7205  
Fax: (651) 215-0525**

Feel free to contact me if you have questions.

Sincerely,

Walker Methodist Westwood Ridge II

February 8, 2016

Page 6

A handwritten signature in cursive script that reads "Kate Johnston". The signature is written in black ink and is positioned above the typed contact information.

Kate JohnSTon, Program Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
85 East Seventh Place, Suite 220  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900  
kate.johnston@state.mn.us  
Telephone: (651) 201-3992 Fax: (651) 215-9697

Enclosure

cc: Licensing and Certification File



DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/08/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245618</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	<p>INITIAL COMMENTS</p> <p>Walker Methodist Westwood Ridge II has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.</p> <p>The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.</p>	F 000			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

F5618004

PRINTED: 02/18/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245618</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p><b>INITIAL COMMENTS</b></p> <p><b>FIRE SAFETY</b></p> <p>A Life Safety Code Initial Survey was conducted by the Minnesota Department of Public Safety - State Fire Marshal Division. At the time of this survey, WALKER METHODIST WESTWOOD RIDGE II was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 18 New Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES ( K-TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St Paul, MN 55101-5145, or</p> <p>By email to: Marian.Whitney@state.mn.us &lt;mailto:Marian.Whitney@state.mn.us&gt; and Angela.Kappenman@state.mn.us &lt;mailto:Angela.Kappenman@state.mn.us&gt;</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <p>1. A description of what has been, or will be, done to correct the deficiency.</p>	K 000		



LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE  
**Electronically Signed**

TITLE

(X6) DATE  
**02/17/2016**

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/18/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245618</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1  2. The actual, or proposed, completion date.  3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency  WALKER METHODIST WESTWOOD RIDGE II is a 1 story building with no basement. The facility was constructed in 2012 and was determined to be of Type V(111) construction.  The building is protected by a full fire sprinkler system. The facility has a fire alarm system with full corridor smoke detection and spaces open to the corridors that are monitored for automatic fire department notification.  The facility has a capacity of 37 beds and had a census of 34 at time of the survey.  The requirement at 42 CFR, Subpart 483.70(a) is NOT MET.	K 000			
K 027 SS=D	NFPA 101 LIFE SAFETY CODE STANDARD  Door openings in smoke barriers have at least a 20-minute fire protection rating or are at least 1¾-inch thick solid bonded wood core. Non-rated protective plates that do not exceed 48 inches from the bottom of the door are permitted. Horizontal sliding doors comply with 7.2.1.14. Swinging doors are arranged so that each door swings in an opposite direction. Doors are self-closing and rabbets, bevels or astragals are required at the meeting edges. Positive latching is not required. 18.3.7.5, 18.3.7.6, 18.3.7.8	K 027		3/1/16	

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/18/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245618</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 027	Continued From page 2  This STANDARD is not met as evidenced by: Based on observations and interview, the facility has failed to maintain smoke/fire barrier doors in accordance with LSC 19.3.7.5. This deficient practice could affect all residents.  Findings include:  On facility tour between between 10:00 AM and 1:00 PM on 01/27/2016, observation revealed that:  1. The smoke barrier doors at the kitchen have a gap in between the doors in excess of 1/8".  This deficient practice was verified by the maintenance director/Administrator at the time of the inspection.	K 027	The following actions will be completed to ensure compliance:  The smoke barrier doors at the kitchen will be adjusted so the gap does not exceed 1/8".  Whole house audit will be completed of all smoke barrier doors to ensure the gaps do not exceed 1/8".  Quarterly audits of life safety will be completed to ensure ongoing compliance.  Director of Environmental Services is responsible for completion.	
K 147 SS=F	NFPA 101 LIFE SAFETY CODE STANDARD  Electrical wiring and equipment is in accordance with NFPA 70, National Electrical Code. 9.1.2  This STANDARD is not met as evidenced by: Based on observation and interview, electrical installations are not in accordance with NFPA 70 "The National Electrical Code 1999 edition.	K 147	The following actions will be completed to ensure compliance:	3/1/16

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/18/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245618</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 147	<p>Continued From page 3 section 9.1.2. This deficiency could negatively effect the all patients, visitors and staff.</p> <p>Findings include: On facility tour between 10:00 AM and 01:00 PM on 01/27/2016, it was observed:</p> <ol style="list-style-type: none"> <li>1. Refrigerator was plugged into a power strip in the Administrator office.</li> <li>2. Multiple appliances were plugged into a power strip in the MDS office.</li> </ol> <p>This deficient practice was verified by the maintenance director/Administrator at the time of the inspection.</p>	K 147	<p>All appliances in Administrator's office and MDS office are now plugged into the wall.</p> <p>Whole house audit will be completed of all areas to ensure no appliances are plugged into power strips.</p> <p>Quarterly audits of life safety will be completed to ensure ongoing compliance.</p> <p>Director of Environmental Services is responsible for completion.</p>	



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically submitted  
February 8, 2016

Ms. Brenda Schrupp, Administrator  
Walker Methodist Westwood Ridge II  
61 Thompson Avenue West  
West Saint Paul, Minnesota 55118

Re: Enclosed State Nursing Home Licensing Orders - Project Number S5618003 & F5618004

Dear Ms. Schrupp:

The above facility was surveyed on January 25, 2016 through January 27, 2016 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules. At the time of the survey, the survey team from the Minnesota Department of Health, Health Regulation Division, noted one or more violations of these rules that are issued in accordance with Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a civil fine for each deficiency not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.

To assist in complying with the correction order(s), a "suggested method of correction" has been added. This provision is being suggested as one method that you can follow to correct the cited deficiency. Please remember that this provision is only a suggestion and you are not required to follow it. Failure to follow the suggested method will not result in the issuance of a penalty assessment. You are reminded, however, that regardless of the method used, correction of the deficiency within the established time frame is required. The "suggested method of correction" is for your information and assistance only.

You have agreed to participate in the electronic receipt of State licensure orders consistent with the Minnesota Department of Health Informational Bulletin 14-01, available at <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm> . The State licensing orders are delineated on the attached Minnesota Department of Health orders being submitted to you electronically. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes.

The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule number and the corresponding text of the state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction order. This column also includes the findings that are in violation of the state statute after the statement, "This Rule is not met as evidenced by." Following the surveyors findings are the Suggested Method of Correction and the Time Period For Correction.

PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.

THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES.

Although no plan of correction is necessary for State Statutes/Rules, please enter the word "corrected" in the box available for text. You must then indicate in the electronic State licensure process, under the heading completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health. We urge you to review these orders carefully, item by item, and if you find that any of the orders are not in accordance with your understanding at the time of the exit conference following the survey, you should immediately contact Susanne Reuss, Unit Supervisor at (651) 201-3793.

You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.

Please note it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,



Kate JohnsTon, Program Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
85 East Seventh Place, Suite 220  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900  
kate.johnston@state.mn.us  
Telephone: (651) 201-3992 Fax: (651) 215-9697

Enclosure(s)

cc: Original - Facility  
Licensing and Certification File

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>27996</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
--	--	---	---

NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Initial Comments</p> <p>*****ATTENTION*****</p> <p>NH LICENSING CORRECTION ORDER</p> <p>In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.</p> <p>Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected.</p> <p>You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.</p> <p>INITIAL COMMENTS: You have agreed to participate in the electronic receipt of State licensure orders consistent with the Minnesota Department of Health Informational Bulletin 14-01, available at <a href="http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm">http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm</a> The State licensing orders are delineated on the attached Minnesota</p>	2 000		

Minnesota Department of Health LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
---	-------	-----------



Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>27996</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
--	--	---	---

NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Continued From page 1</p> <p>Department of Health orders being submitted to you electronically. Although no plan of correction is necessary for State Statutes/Rules, please enter the word "corrected" in the box available for text. You must then indicate in the electronic State licensure process, under the heading completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health.</p> <p>On 1/25/16, 1/26/16 and 1/27/16 surveyors of this Department's staff, visited the above provider and the following correction orders are issued. Please indicate in your electronic plan of correction that you have reviewed these orders, and identify the date when they will be completed.</p> <p>Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes.</p> <p>The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction order. This column also includes the findings which are in violation of the state statute after the statement, "This Rule is not met as evidence by." Following the surveyors findings are the Suggested Method of Correction and Time period for Correction.</p> <p>PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.</p>	2 000		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>27996</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
--	--	---	---

NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	Continued From page 2	2 000		
21426	<p>MN St. Statute 144A.04 Subd. 3 Tuberculosis Prevention And Control</p> <p>(a) A nursing home provider must establish and maintain a comprehensive tuberculosis infection control program according to the most current tuberculosis infection control guidelines issued by the United States Centers for Disease Control and Prevention (CDC), Division of Tuberculosis Elimination, as published in CDC's Morbidity and Mortality Weekly Report (MMWR). This program must include a tuberculosis infection control plan that covers all paid and unpaid employees, contractors, students, residents, and volunteers. The Department of Health shall provide technical assistance regarding implementation of the guidelines.</p> <p>(b) Written compliance with this subdivision must be maintained by the nursing home.</p> <p>This MN Requirement is not met as evidenced by: Based on document review and interview, the facility failed to document the interpretation results of tuberculin skin test (TST) for 5 of 5 residents reviewed (R45, R50, R111, R129 and R204) and for 3 of 5 employee records (LPN-A, PTA-A, ST-A) reviewed per Centers for Disease</p>	21426		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>27996</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
--	--	---	---

NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
21426	<p>Continued From page 3</p> <p>Control and Prevention (CDC) recommendations. 5 of 5 employees (LPN-A, PTA-A, ST-A, NA-A, RN-A) and 5 of 5 residents (R45, R50, R111, R129, R204) failed to have the complete signs and symptom screening for TB.</p> <p>Findings include:</p> <p>Document review of TST results for R45, R50, R111, R129 and R204, employee records of licensed practical nurse (LPN)-A, physical therapy assistant (PTA)-A, speech therapist (ST)-A indicated the number of millimeter (mm) of induration as "0" mm but failed to indicate the interpretation of positive or negative according to the CDC's guidance for TST documentation.</p> <p>Document review of the facility individual resident tuberculosis Screening-Risk Assessment signs and symptoms form, failed to screen for chest pain or chills for R45, R50, R111, R129 and R204, and the employee records of licensed practical nurse (LPN)-A, physical therapy assistant (PTA)-A, speech therapist (ST)-A, nursing assistant (NA)-A or registered nurse (RN)-A failed to screen for chest pain or chills. The CDC's July 2013 document reads, "Persons with active TB disease may have one or more of the following symptoms: Prolonged cough (&gt;three weeks)</p> <ul style="list-style-type: none"> <li>Hemoptysis (coughing up blood)</li> <li>Weight loss</li> <li>Night sweats</li> <li>Fatigue</li> <li>Fever, chills</li> <li>Poor appetite</li> <li>Chest pain</li> <li>Other symptoms may be present, depending on the site of the disease.</li> </ul>	21426		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>27996</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
--	--	---	---

NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
21426	<p>Continued From page 4</p> <p>Active TB disease most commonly affects the lungs (pulmonary). However, TB disease can occur in other parts of the body (most commonly, pleural or lymphatic)."</p> <p>A review of the facility policy dated 10/24/1990, titled Tuberculin Skin Test-Resident, read "E. Document in millimeters the size of induration only. 1) If there is no induration, document that finding as 0 mm. 2) 5 or more millimeters induration is considered positive for high risk groups."</p> <p>A review of the facility policy dated 9/10/14, titled, Tuberculin Mantoux Employee and Volunteer, read, C. Document in millimeters the size of induration only. 1) If there is no induration, document that finding as 0 mm. 2) 5 or more millimeters induration is considered positive for high risk groups."</p> <p>During an interview with the director of nursing on 1/27/16, at 11:00 a.m. verified positive and negative interpretations were not documented on each individual because the facility policy read 0 mm is negative.</p> <p>SUGGESTED METHOD OF CORRECTION: The DON or designee could conduct resident and employee tuberculin skin testing and screening audits, interventions and monitoring to ensure residents/employees are free from communicable disease. The DON could ensure the staff were educated on the importance of indication of tuberculin testing. The DON or designee could randomly audit resident's and employees to ensure adequate risk assessments are conducted.</p> <p>TIME PERIOD FOR CORRECTION: Fourteen</p>	21426		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>27996</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/27/2016</b>
--	--	---	---

NAME OF PROVIDER OR SUPPLIER  <b>WALKER METHODIST WESTWOOD RIDGE II</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>61 THOMPSON AVENUE WEST WEST SAINT PAUL, MN 55118</b>
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
21426	Continued From page 5  (14) days.	21426		