



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically Delivered

July 3, 2024

Licensee
Blissful Home Care Corporation
5643 Northport Drive
Brooklyn Center, MN 55429

RE: Project Number(s) SL39888015

Dear Licensee:

This is your **official notice** that you have been **granted your assisted living facility license**. Your license effective and expiration dates remain the same as on your provisional license. Your updated status will be listed on the license certificate at renewal and **this letter serves as proof** in the meantime. If you have not received a letter from us with information regarding renewing your license within 60 days prior to your expiration date, please contact us at (651) 201-5273 or by email at Health.assistedliving@state.mn.us.

The Minnesota Department of Health completed an initial survey on June 5, 2024, for the purpose assessing compliance with state licensing statutes. At the time of the survey, the Minnesota Department of Health noted violations of the laws pursuant to Minnesota Statute, Chapter 144G.

The Department of Health concludes the licensee is in substantial compliance. State law requires the facility must take action to correct the state correction orders and document the actions taken to comply in the facility's records. The Department reserves the right to return to the facility at any time should the Department receive a complaint or deem it necessary to ensure the health, safety, and welfare of residents in your care.

STATE CORRECTION ORDERS

The enclosed State Form documents the state correction orders. The Department of Health documents state correction orders using federal software. Tag numbers are assigned to Minnesota state statutes for Home Care Providers. The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute number and the corresponding text of the state statute out of compliance are listed in the "Summary Statement of Deficiencies" column. This column also includes the findings that are in violation of the state statute after the statement, "This MN Requirement is not met as evidenced by . . ."

In accordance with Minn. Stat. § 144G.31 Subd. 4, MDH may assess fines based on the level and scope of the violations; **however, no immediate fines are assessed for this survey of your facility.**

DOCUMENTATION OF ACTION TO COMPLY

Per Minn. Stat. § 144G.30, Subd. 5(c), the licensee must document actions taken to comply with the correction orders within the time period outlined on the state form; however, plans of correction are not required to be submitted for approval.

The correction order documentation should include the following:

- Identify how the area(s) of noncompliance was corrected related to the resident(s)/employee(s) identified in the correction order.

- Identify how the area(s) of noncompliance was corrected for all of the provider's residents/employees that may be affected by the noncompliance.
- Identify what changes to your systems and practices were made to ensure compliance with the specific statute(s).

CORRECTION ORDER RECONSIDERATION PROCESS

In accordance with Minn. Stat. § 144G.32, Subd. 2, you may challenge the correction order issued, including the level and scope, and any fine assessed through the correction order reconsideration process. The request for reconsideration must be in writing and received by the Department of Health within 15 calendar days of the correction order receipt date.

A state correction order under Minn. Stat. § 144G.91, Subd. 8, Free from Maltreatment is associated with a maltreatment determination by the Office of Health Facility Complaints. If maltreatment is substantiated, you will receive a separate letter with the reconsideration process under Minn. Stat. § 626.557.

To submit a reconsideration request, please visit:

<https://forms.web.health.state.mn.us/form/HRDAppealsForm>

The MDH Health Regulation Division (HRD) values your feedback about your experience during the survey and/or investigation process. Please fill out this anonymous provider feedback questionnaire at your convenience at this link: **<https://forms.office.com/g/Bm5uQEPhVa>**. Your input is important to us and will enable MDH to improve its processes and communication with providers. If you have any questions regarding the questionnaire, please contact Susan Winkelmann at susan.winkelmann@state.mn.us or call 651-201-5952.

You are encouraged to retain this document for your records. It is your responsibility to share the information contained in the letter and state form with your organization's Governing Body.

If you have any questions, please contact me.

Sincerely,



Renee Anderson, Supervisor
State Rapid Response Team / State Evaluation Team
Email: renee.anderson@state.mn.us
Telephone: 651-201-5871 Fax: 1-800-337-9238 / 1-866-890-9290

JMD

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 000	Initial Comments *****ATTENTION***** ASSISTED LIVING PROVIDER LICENSING CORRECTION ORDER(S) In accordance with Minnesota Statutes, section 144G.08 to 144G.95, these correction orders are issued pursuant to a survey. Determination of whether violations are corrected requires compliance with all requirements provided at the Statute number indicated below. When Minnesota Statute contains several items, failure to comply with any of the items will be considered lack of compliance. INITIAL COMMENTS: SL39888015-0 On June 4, 2024, through June 5, 2024, the Minnesota Department of Health conducted a survey at the above provider, and the following correction orders are issued. At the time of the survey, there were two residents, both of whom received services under the provider's Assisted Living license.	0 000	Minnesota Department of Health is documenting the State Correction Orders using federal software. Tag numbers have been assigned to Minnesota State Statutes for Assisted Living License Providers. The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state Statute number and the corresponding text of the state Statute out of compliance is listed in the "Summary Statement of Deficiencies" column. This column also includes the findings which are in violation of the state requirement after the statement, "This Minnesota requirement is not met as evidenced by." Following the surveyors' findings is the Time Period for Correction. PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES,"PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE. THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES. The letter in the left column is used for tracking purposes and reflects the scope and level issued pursuant to 144G.31 subd. 1, 2, and 3.		
0 480 SS=F	144G.41 Subd 1 (13) (i) (B) Minimum requirements (13) offer to provide or make available at least the	0 480			

Minnesota Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 480	Continued From page 1 following services to residents: (B) food must be prepared and served according to the Minnesota Food Code, Minnesota Rules, chapter 4626; and This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure food was prepared and served according to the Minnesota Food Code. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all the residents). The findings include: Please refer to the document titled, Food and Beverage Establishment Inspection Report (FBEIR) dated June 5, 2024, for the specific Minnesota Food Code violations. The Inspection Report was provided to the licensee within 24 hours of the inspection. TIME PERIOD FOR CORRECTION: Please refer to the FBEIR for any compliance dates.	0 480			
0 800 SS=F	144G.45 Subd. 2 (a) (4) Fire protection and physical environment (4) keep the physical environment, including walls, floors, ceiling, all furnishings, grounds, systems, and equipment in a continuous state of	0 800			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 800	Continued From page 2 good repair and operation with regard to the health, safety, comfort, and well-being of the residents in accordance with a maintenance and repair program. This MN Requirement is not met as evidenced by: Based on observation and interview, the licensee failed to maintain the facility's physical environment in a continuous state of good repair and operation regarding the health, safety, and well-being of the residents. This had the potential to directly affect all residents, staff, and visitors. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death), and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has potential to affect a large portion or all of the residents). Findings include: During a facility tour on June 5, 2024, at 11:45 a.m., with housing manager (HM)-E and registered nurse (RN)-F, the surveyor made the following observations of facility hazards and disrepair: Two 4 inch by 4 inch holes were observed through the garage side drywall of the fire-resistant wall separating the garage from the assisted living. Fire-resistant walls are required to be maintained free of holes through the drywall membrane as approved at the time of construction to prevent the spread of fire from	0 800			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 800	Continued From page 3 one side of the wall to the other. On June 5, 2024, at 11:55 a.m., HM-E, and RN-F, verified the above listed observations while accompanying on the tour. TIME PERIOD FOR CORRECTION: Seven (7) days	0 800			
0 810 SS=F	144G.45 Subd. 2 (b)-(f) Fire protection and physical environment (b) Each assisted living facility shall develop and maintain fire safety and evacuation plans. The plans shall include but are not limited to: (1) location and number of resident sleeping rooms; (2) employee actions to be taken in the event of a fire or similar emergency; (3) fire protection procedures necessary for residents; and (4) procedures for resident movement, evacuation, or relocation during a fire or similar emergency including the identification of unique or unusual resident needs for movement or evacuation. (c) Employees of assisted living facilities shall receive training on the fire safety and evacuation plans upon hiring and at least twice per year thereafter. (d) Fire safety and evacuation plans shall be readily available at all times within the facility. (e) Residents who are capable of assisting in their own evacuation shall be trained on the proper actions to take in the event of a fire to include movement, evacuation, or relocation. The training shall be made available to residents at least once per year. (f) Evacuation drills are required for employees	0 810			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 810	Continued From page 4 twice per year per shift with at least one evacuation drill every other month. Evacuation of the residents is not required. Fire alarm system activation is not required to initiate the evacuation drill. This MN Requirement is not met as evidenced by: Based on observation, interview and record review, the licensee failed to develop the fire safety and evacuation plan with required content, make the plan readily available, provide required training and drills. This had the potential to directly affect all residents, staff, and visitors. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident 's health or safety) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has potential to affect a large portion or all of the residents). The findings include: On June 5, 2024, at 11:20 a.m., housing manager (HM)-E, provided documents on the fire safety and evacuation plan (FSEP), fire safety and evacuation training, and evacuation drills for the facility. FIRE SAFETY AND EVACUATION PLAN The licensee FSEP evacuation plan failed to include location and number of resident rooms. It was also observed an evacuation map was not located in a conspicuous location in the lower level for occupants to use for direction for	0 810			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 810	Continued From page 5 evacuation during a fire or similar emergency. Resident room numbers and locations are required to be included on the evacuation floor plan map and posted in a conspicuous location on each level for use by occupants to evacuate during a fire or similar emergency. During an interview on June 5, 2024, at 11:40 a.m., HM-E, and RN-F, stated the evacuation floor plan did not include resident room numbers as required and the evacuation floor plan was not posted in the lower level in a conspicuous location for use by occupants to evacuate during a fire or similar emergency. TIME PERIOD FOR CORRECTION: Seven (7) days	0 810			
0 820 SS=F	144G.45 Subd. 2 (g) Fire protection and physical environment (g) Existing construction or elements, including assisted living facilities that were registered as housing with services establishments under chapter 144D prior to August 1, 2021, shall be permitted to continue in use provided such use does not constitute a distinct hazard to life. Any existing elements that an authority having jurisdiction deems a distinct hazard to life must be corrected. The facility must document in the facility's records any actions taken to comply with a correction order, and must submit to the commissioner for review and approval prior to correction. This MN Requirement is not met as evidenced by:	0 820			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 820	Continued From page 6 Based on observation and interview, the licensee failed to provide facilities that were not a distinct hazard to life. This had the potential to directly affect all residents, visitors, and staff. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). Findings include: On a facility tour on June 5, 2024, at 12:30 p.m., with housing manager (HM)-E, and registered nurse (RN)-F, it was observed that an inappropriate plastic container was used to discard of used cigarette butts on the back wood deck. Cigarette butts are required to be disposed of in appropriate metal containers or containers manufactured and tested for the purpose of discarding used cigarette butts. These deficient conditions were visually verified by HM-E, and RN-F, accompanying on the tour. TIME PERIOD FOR CORRECTION: Two (2) days.	0 820			
01890 SS=D	144G.71 Subd. 20 Prescription drugs A prescription drug, prior to being set up for immediate or later administration, must be kept in the original container in which it was dispensed by the pharmacy bearing the original prescription label with legible information including the	01890			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION		STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
01890	Continued From page 7 expiration or beyond-use date of a time-dated drug. This MN Requirement is not met as evidenced by: Based on observation and interview, the licensee failed to dispose of expired medications and ensure medications were labeled correctly for one of two residents (R1). This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at an isolated scope (when one or a limited number of residents are affected or one or a limited number of staff are involved, or the situation has occurred only occasionally). The findings include: R1's service plan, dated March 28, 2024, indicated R1 received services including assistance with activities of daily living (ADLs), housekeeping, and medication management. On June 5, 2024, at 1:00 p.m., a review of the medication storage area indicated R1 had the following expired medications: tylenol 325 mg (for pain): expiration date February 27, 2024. On June 5, 2024, at 1:05 p.m., unlicensed personnel (ULP)-C stated they would notify the nurse if they noticed expired medication. On June 5, 2024, at 1:10 p.m., clinical nurse supervisor (CNS)-A stated expired medication should be removed by a nurse when the monthly	01890			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 39888	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 06/05/2024
NAME OF PROVIDER OR SUPPLIER BLISSFUL HOME CARE CORPORATION			STREET ADDRESS, CITY, STATE, ZIP CODE 5643 NORTHPORT DRIVE BROOKLYN CENTER, MN 55429		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
01890	Continued From page 8 medication shipment arrived. CNS-A stated that R-1 had new order for Tylenol that was not expired. The licensee's undated Medications Disposition or Disposal policy indicated, "will be destroyed within one month or less of the time they were discontinued". No further information was provided. TIME PERIOD FOR CORRECTION: Seven (7) days	01890			

Type: Full
Date: 06/04/24
Time: 12:19:29
Report: 1029241173

Food and Beverage Establishment Inspection Report

Page 1

Location:

Blissful Home Care Inc.
5643 Northport Drive
Brooklyn Center, MN55429
Hennepin County, 27

Establishment Info:

ID #: N039888
Risk:
Announced Inspection: Yes

License Categories:

Expires on: / /

Operator:

Phone #:
ID #:

The violations listed in this report include any previously issued orders and deficiencies identified during this inspection. Compliance dates are shown for each item.

The following orders were issued during this inspection.

7-200 Toxic Supplies and Applications

7-204.11

**** Priority 1 ****

MN Rule 4626.1620 Discontinue using chemical sanitizers, including chemical sanitizing solutions generated on site and other chemical antimicrobials on food-contact surfaces that do not meet the requirements specified in 40 CFR part 180, section 180.940, or part 180, subpart E, section 180.2020.

CHLORINE SOLUTION IN SPRAY BOTTLE BEYOND 200 PPM. CORRECTED DURING INSPECTION TO 100 PPM.

Comply By: 06/05/24

4-200 Equipment Design and Construction

4-204.112A

MN Rule 4626.0620A Provide a temperature measuring device located in the warmest part of mechanically refrigerated units and coolest part of hot food storage units that are capable of measuring air temperature or a simulated product temperature.

INTERNAL THERMOMETER FAR BACK IN INTERIOR CAVITY. MOVED DURING INSPECTION TO DOOR.

Comply By: 06/05/24

Surface and Equipment Sanitizers

CHLORINE: = >200PPM at Degrees Fahrenheit
Location: SPRAY BOTTLE
Violation Issued: Yes

CHLORINE: = 100 at Degrees Fahrenheit
Location: SPRAY BOTTLE
Violation Issued: No

Food and Equipment Temperatures

Type: Full
Date: 06/04/24
Time: 12:19:29
Report: 1029241173
Blissful Home Care Inc.

Food and Beverage Establishment
Inspection Report

Process/Item: MILK
Temperature: 31 Degrees Fahrenheit - Location: REFRIGERATOR (THAWING)
Violation Issued: No

Process/Item: SHELL EGG
Temperature: 35 Degrees Fahrenheit - Location: REFRIGERATOR (COLD HOLDING)
Violation Issued: No

Total Orders	In This Report	Priority 1	Priority 2	Priority 3
		1	0	1

Employee illness policy and reporting, vomit/fecal matter cleanup procedure, safe food temperatures, employee hygiene and hand washing, highly susceptible populations, and other foodborne illness risk factors discussed.

Kitchen is non-commercial in nature and food is provided for same day service. Taylor thermal stickers used to verify high temperature in Whirlpool NSF/ANSI 184. Old sticker showed a high temperature of 180°F.

Identified issues discussed with operator and corrected during inspection.


NOTE: Plans and specifications must be submitted for review and approval prior to new construction, remodeling or alterations.

I acknowledge receipt of the Minnesota Department of Health inspection report number 1029241173 of 06/04/24.

Certified Food Protection Manager

Certification Number: FM108341 Expires: 11/06/24

Inspection report reviewed with person in charge and emailed.

Signed: 
ENITE OGHENEKARO
LALD

Signed: Trevor McCliment
Trevor McCliment
Public Health Sanitarian
Metro District Office
651-201-3957
trevor.mccliment@state.mn.us

Report #: 1029241173

DEPARTMENT OF HEALTH

Minnesota Department of Health

Food, Pools, and Lodging Services

625 Robert Street North

St. Paul

No. of RF/PHI Categories Out

0

Date

06/04/24

No. of Repeat RF/PHI Categories Out

0

Time In

12:19:29

Legal Authority MN Rules Chapter 4626

Time Out

Blissful Home Care Inc.

Address

5643 Northport Drive

City/State

Brooklyn Center, MN

Zip Code

55429

Telephone

License/Permit #

N039888

Permit Holder

Purpose of Inspection

Full

Est Type

Risk Category

FOODBORNE ILLNESS RISK FACTORS AND PUBLIC HEALTH INTERVENTIONS

Circle designated compliance status (IN, OUT, N/O, N/A) for each numbered item

Mark "X" in appropriate box for COS and/or R

IN=in compliance

OUT= not in compliance

N/O= not observed

N/A= not applicable

COS=corrected on-site during inspection

R= repeat violation

Compliance Status

COS

R

Supervision

1

IN

OUT

PIC knowledgeable; duties & oversight

2

IN

OUT

N/A

Certified food protection manager, duties

Employee Health

3

IN

OUT

Mgmt/Staff;knowledge,responsibilities&reporting

4

IN

OUT

Proper use of reporting, restriction & exclusion

5

IN

OUT

Procedures for responding to vomiting & diarrheal events

Good Hygienic Practices

6

IN

OUT

N/O

Proper eating, tasting, drinking, or tobacco use

7

IN

OUT

N/O

No discharge from eyes, nose, & mouth

Preventing Contamination by Hands

8

IN

OUT

N/O

Hands clean & properly washed

9

IN

OUT

N/A

N/O

No bare hand contact with RTE foods or pre-approved alternate procedure properly followed

10

IN

OUT

Adequate handwashing sinks supplied/accessible

Approved Source

11

IN

OUT

Food obtained from approved source

12

IN

OUT

N/A

N/O

Food received at proper temperature

13

IN

OUT

Food in good condition, safe, & unadulterated

14

IN

OUT

N/A

N/O

Required records available; shellstock tags, parasite destruction

Protection from Contamination

15

IN

OUT

N/A

N/O

Food separated and protected

16

IN

OUT

N/A

Food contact surfaces: cleaned & sanitized

17

IN

OUT

Proper disposition of returned, previously served, reconditioned, & unsafe food

Compliance Status

COS

R

Time/Temperature Control for Safety

18

IN

OUT

N/A

N/O

Proper cooking time & temperature

19

IN

OUT

N/A

N/O

Proper reheating procedures for hot holding

20

IN

OUT

N/A

N/O

Proper cooling time & temperature

21

IN

OUT

N/A

N/O

Proper hot holding temperatures

22

IN

OUT

N/A

Proper cold holding temperatures

23

IN

OUT

N/A

N/O

Proper date marking & disposition

24

IN

OUT

N/A

N/O

Time as a public health control: procedures & records

Consumer Advisory

25

IN

OUT

N/A

Consumer advisory provided for raw/undercooked food

Highly Susceptible Populations

26

IN

OUT

N/A

Pasteurized foods used; prohibited foods not offered

Food and Color Additives and Toxic Substances

27

IN

OUT

N/A

Food additives: approved & properly used

28

IN

OUT

Toxic substances properly identified, stored, & used

Conformance with Approved Procedures

29

IN

OUT

N/A

Compliance with variance/specialized process/HACCP

Risk factors (RF) are improper practices or procedures identified as the most prevalent contributing factors of foodborne illness or injury. Public Health Interventions (PHI) are control measures to prevent foodborne illness or injury.

GOOD RETAIL PRACTICES

Good Retail Practices are preventative measures to control the addition of pathogens, chemicals, and physical objects into foods.

Mark "X" in box if numbered item is not in compliance

Mark "X" in appropriate box for COS and/or R

COS=corrected on-site during inspection

R= repeat violation

COS

R

Safe Food and Water

30

IN

OUT

N/A

Pasteurized eggs used where required

31

Water & ice obtained from an approved source

32

IN

OUT

N/A

Variance obtained for specialized processing methods

Food Temperature Control

33

Proper cooling methods used; adequate equipment for temperature control

34

IN

OUT

N/A

N/O

Plant food properly cooked for hot holding

35

IN

OUT

N/A

N/O

Approved thawing methods used

36

X

Thermometers provided & accurate

Food Identification

37

Food properly labeled; original container

Prevention of Food Contamination

38

Insects, rodents, & animals not present

39

Contamination prevented during food prep, storage & display

40

Personal cleanliness

41

Wiping cloths: properly used & stored

42

Washing fruits & vegetables

COS

R

Proper Use of Utensils

43

In-use utensils: properly stored

44

Utensils, equipment & linens: properly stored, dried, & handled

45

Single-use/single service articles: properly stored & used

46

Gloves used properly

Utensil Equipment and Vending

47

Food & non-food contact surfaces cleanable, properly designed, constructed, & used

48

Warewashing facilities: installed, maintained, & used; test strips

49

Non-food contact surfaces clean

Physical Facilities

50

Hot & cold water available; adequate pressure

51

Plumbing installed; proper backflow devices

52

Sewage & waste water properly disposed

53

Toilet facilities: properly constructed, supplied, & cleaned

54

Garbage & refuse properly disposed; facilities maintained

55

Physical facilities installed, maintained, & clean

56

Adequate ventilation & lighting; designated areas used

57

Compliance with MCIAA

58

Compliance with licensing & plan review

Food Recalls:

Person in Charge (Signature)

Date:

06/05/24

Inspector (Signature)

Trevor McCliment