



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically Delivered

April 8, 2026

Licensee
Kheycare LLC
9225 Clinton Avenue South
Bloomington, MN 55420

RE: Project Number(s) SL41095015

Dear Licensee:

This is your **official notice** that you have been **granted your assisted living facility license**. Your license effective and expiration dates remain the same as on your provisional license. Your updated status will be listed on the license certificate at renewal and **this letter serves as proof** in the meantime. If you have not received a letter from us with information regarding renewing your license within 60 days prior to your expiration date, please contact us at (651) 201-5273 or by email at Health.assistedliving@state.mn.us.

The Minnesota Department of Health completed an initial survey on March 5, 2026, for the purpose assessing compliance with state licensing statutes. At the time of the survey, the Minnesota Department of Health noted violations of the laws pursuant to Minnesota Statute, Chapter 144G.

The Department of Health concludes the licensee is in substantial compliance. State law requires the facility must take action to correct the state correction orders and document the actions taken to comply in the facility's records. The Department reserves the right to return to the facility at any time should the Department receive a complaint or deem it necessary to ensure the health, safety, and welfare of residents in your care.

STATE CORRECTION ORDERS

The enclosed State Form documents the state correction orders. The Department of Health documents state correction orders using federal software. Tag numbers are assigned to Minnesota state statutes for Home Care Providers. The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute number and the corresponding text of the state statute out of compliance are listed in the "Summary Statement of Deficiencies" column. This column also includes the findings that are in violation of the state statute after the statement, "This MN Requirement is not met as evidenced by . . ."

IMPOSITION OF FINES

In accordance with Minn. Stat. § 144G.31, Subd. 4, fines and enforcement actions may be imposed based on the level and scope of the violations and may be imposed immediately with no opportunity to correct the violation first as follows:

Level 1: no fines or enforcement;

Level 2: a fine of \$500 per violation, in addition to any enforcement mechanism authorized in § 144G.20;

Level 3: a fine of \$1,000 per incident, in addition to any enforcement mechanism authorized in § 144G.20;

Level 4: a fine of \$3,000 per incident, in addition to any enforcement mechanism authorized in § 144G.20;

Level 5: a fine of \$5,000 per violation, in addition to any enforcement mechanism authorized in § 144G.20.

Therefore, in accordance with Minn. Stat. §§ 144G.01 to 144G.9999, the following fines are assessed pursuant to this survey:

St - 0 - 0775 - 144g.45 Subd. 2. (a) - Fire Protection And Physical Environment - \$500.00

The total amount you are assessed is \$500.00. You will be invoiced approximately 30 days after receipt of this notice, subject to appeal.

DOCUMENTATION OF ACTION TO COMPLY

Per Minn. Stat. § 144G.30, Subd. 5(c), the licensee must document actions taken to comply with the correction orders within the time period outlined on the state form; however, plans of correction are not required to be submitted for approval.

The correction order documentation should include the following:

- Identify how the area(s) of noncompliance was corrected related to the resident(s)/employee(s) identified in the correction order.
- Identify how the area(s) of noncompliance was corrected for all of the provider's residents/employees that may be affected by the noncompliance.
- Identify what changes to your systems and practices were made to ensure compliance with the specific statute(s).

CORRECTION ORDER RECONSIDERATION PROCESS

In accordance with Minn. Stat. § 144G.32, Subd. 2, you may challenge the correction order issued, including the level and scope, and any fine assessed through the correction order reconsideration process. The request for reconsideration must be in writing and received by the Department of Health within 15 calendar days of the correction order receipt date.

To submit a reconsideration request, please visit:

<https://forms.web.health.state.mn.us/form/HRDAppealsForm>

REQUESTING A HEARING

Alternatively, in accordance with Minn. Stat. § 144G.31, Subd. 5(d), an assisted living provider that has been assessed a fine under this subdivision has a right to a reconsideration or a hearing under

this section and chapter 14. Pursuant to Minn. Stat. § 144G.20, Subd. 14 and Subd. 18, a request for a hearing must be in writing and received by MDH within 15 business days of the correction order receipt date. The request must contain a brief and plain statement describing each matter or issue contested and any new information you believe constitutes a defense or mitigating factor.

To submit a hearing request, please visit:

<https://forms.web.health.state.mn.us/form/HRDAppealsForm>.

To appeal fines via reconsideration, please follow the procedure outlined above. Please note that you may request a reconsideration or a hearing, but not both. If you wish to contest tags without fines in a reconsideration and tags with the fines at a hearing, please submit two separate appeals forms at the website listed above.

The MDH Health Regulation Division (HRD) values your feedback about your experience during the survey and/or investigation process. Please fill out this anonymous provider feedback questionnaire at your convenience at this link: **<https://forms.office.com/g/Bm5uQEPhVa>**. Your input is important to us and will enable MDH to improve its processes and communication with providers. If you have any questions regarding the questionnaire, please contact Susan Winkelmann at susan.winkelmann@state.mn.us or call 651-201-5952.

You are encouraged to retain this document for your records. It is your responsibility to share the information contained in the letter and state form with your organization's Governing Body.

If you have any questions, please contact me.

Sincerely,

A handwritten signature in black ink that reads "Renee L. Anderson". The signature is written in a cursive, flowing style.

Renee L. Anderson, Supervisor
State Evaluation Team
Email: Renee.L.Anderson@state.mn.us
Telephone: 651-201-5871 Fax: 1-866-890-9290

HHH

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 000	Initial Comments *****ATTENTION***** ASSISTED LIVING PROVIDER LICENSING CORRECTION ORDER(S) In accordance with Minnesota Statutes, section 144G.08 to 144G.95, these correction orders are issued pursuant to a survey. Determination of whether violations are corrected requires compliance with all requirements provided at the Statute number indicated below. When Minnesota Statute contains several items, failure to comply with any of the items will be considered lack of compliance. INITIAL COMMENTS: SL41095015-0 On March 3, 2026, through March 5, 2026, the Minnesota Department of Health conducted a full survey at the above provider and the following correction orders are issued. At the time of the survey, there was one resident; one resident receiving services under the Provisional Assisted Living Facility license.	0 000	Minnesota Department of Health is documenting the State Correction Orders using federal software. Tag numbers have been assigned to Minnesota State Statutes for Assisted Living Facilities. The assigned tag number appears in the far-left column entitled "ID Prefix Tag." The state Statute number and the corresponding text of the state Statute out of compliance is listed in the "Summary Statement of Deficiencies" column. This column also includes the findings which are in violation of the state requirement after the statement, "This Minnesota requirement is not met as evidenced by." Following the evaluators ' findings is the Time Period for Correction. PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES,"PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE. THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES. THE LETTER IN THE LEFT COLUMN IS USED FOR TRACKING PURPOSES AND REFLECTS THE SCOPE AND LEVEL ISSUED PURSUANT TO 144G.31 SUBDIVISION 1-3.		
0 480 SS=F	144G.41 Subdivision 1 Subd. 1a (a-b) Minimum requirements; required food services	0 480			

Minnesota Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 480	Continued From page 1 (a) Except as provided in paragraph (b), food must be prepared and served according to the Minnesota Food Code, Minnesota Rules, chapter 4626. (b) For an assisted living facility with a licensed capacity of ten or fewer residents: (1) notwithstanding Minnesota Rules, part 4626.0033, item A, the facility may share a certified food protection manager (CFPM) with one other facility located within a 60-mile radius and under common management provided the CFPM is present at each facility frequently enough to effectively administer, manage, and supervise each facility's food service operation; (2) notwithstanding Minnesota Rules, part 4626.0545, item A, kick plates that are not removable or cannot be rotated open are allowed unless the facility has been issued repeated correction orders for violations of Minnesota Rules, part 4626.1565 or 4626.1570; (3) notwithstanding Minnesota Rules, part 4626.0685, item A, the facility is not required to provide integral drainboards, utensil racks, or tables large enough to accommodate soiled and clean items that may accumulate during hours of operation provided soiled items do not contaminate clean items, surfaces, or food, and clean equipment and dishes are air dried in a manner that prevents contamination before storage; (4) notwithstanding Minnesota Rules, part 4626.1070, item A, the facility is not required to install a dedicated handwashing sink in its existing kitchen provided it designates one well of a two-compartment sink for use only as a handwashing sink; (5) notwithstanding Minnesota Rules, parts 4626.1325, 4626.1335, and 4626.1360, item A, existing floor, wall, and ceiling finishes are	0 480			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 480	Continued From page 2 allowed provided the facility keeps them clean and in good condition; (6) notwithstanding Minnesota Rules, part 4626.1375, shielded or shatter-resistant lightbulbs are not required, but if a light bulb breaks, the facility must discard all exposed food and fully clean all equipment, dishes, and surfaces to remove any glass particles; and (7) notwithstanding Minnesota Rules, part 4626.1390, toilet rooms are not required to be provided with a self-closing door. This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure food was prepared and served according to the Minnesota Food Code. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death), and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Food and Beverage Establishment Inspection Report (FBEIR) dated March 3, 2026, for the specific Minnesota Food Code violations. The Inspection Report was provided to the licensee within 24 hours of the inspection.	0 480			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 480	Continued From page 3	0 480			
0 660 SS=F	144G.42 Subd. 9 Tuberculosis prevention and control (a) The facility must establish and maintain a comprehensive tuberculosis infection control program according to the most current tuberculosis infection control guidelines issued by the United States Centers for Disease Control and Prevention (CDC), Division of Tuberculosis Elimination, as published in the CDC's Morbidity and Mortality Weekly Report. The program must include a tuberculosis infection control plan that covers all paid and unpaid employees, contractors, students, and regularly scheduled volunteers. The commissioner shall provide technical assistance regarding implementation of the guidelines. (b) The facility must maintain written evidence of compliance with this subdivision. This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to maintain a tuberculosis (TB) prevention and control program, based on the most current guidelines issued by the Centers for Disease Control and Prevention (CDC), to include baseline TB screening that included a two-step tuberculin skin test (TST) or other evidence of TB testing such as IGRA (a blood test) completed upon hire, or within 90 days prior to hire for two of two employees (licensed assisted living director/clinical nurse supervisor (LALD/CNS)-A and unlicensed personnel (ULP)-B).	0 660			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 660	Continued From page 4 This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death), and is issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: The Facility Risk Assessment dated July 1, 2025, indicated the annual conversion rate was low. LALD/CNS-A LALD/CNS-A was hired April 24, 2024, to oversee and manage the daily operations of the licensee, clinical leadership, staff supervision and provide direct care and services to residents residing in the facility. LALD/CNS-A's record included a Baseline Screening Tool for Healthcare Workers (HCW's) sheet, signed September 15, 2025. The record included a physician note, signed August 23, 2023, indicating LALD/CNS-A "had a negative chest X-ray today". The physician note further indicated a "history of positive tuberculin skin test and blood tests" and a self-reported a history of latent TB and completion of treatment. The record lacked clinical documentation of either a positive test or documentation of completion of treatment correlated to the "negative" chest X-ray. On March 3, 2026, at 11:45 a.m., LALD/CNS-A stated they did not receive a new TB blood test or TST within 90 days prior to current employment. LALD/CNS-A stated they received a chest X-ray	0 660			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 660	Continued From page 5 in the past and believed that was all that was required. ULP-B ULP-B was hired September 3, 2025, to provide direct care for residents. ULP-B's record included a Baseline Screening Tool for HCW's sheet, signed September 25, 2025. The screening form indicated ULP-B did not receive a TST or TB blood test in past 12 months. The record further included a negative chest X-ray signed September 25, 2025. The record lacked documentation of a negative TB test completed within 90 days prior to hire, or clinical documentation of a positive TB test (or documentation of completion of TB treatment) correlated to the negative chest X-ray. On March 5, 2026, at 4:43 p.m., LALD/CNS-A stated the licensee was not aware of current TB guidelines, but would reach out to the Minnesota Department of Health for guidance and become educated and compliant regarding employee TB requirements. The Minnesota Department of Health (MDH) guidelines, Regulations for Tuberculosis Control in Minnesota Health Care Settings, dated July 2013, and based on CDC guidelines indicated, Baseline TB screening consists of three components: 1. Assessing for current symptoms of active TB disease. 2. Assessing TB history; and 3. Testing for the presence of infection with Mycobacterium tuberculosis by administering either a two-step TST or single IGRA. In addition, "An employee may begin working with patients after a negative TB symptom screen (i.e.,	0 660			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 660	Continued From page 6 no symptoms of active TB disease) and a negative IGRA or TST (i.e., first step) dated within 90 days before hire. The second TST may be performed after the healthcare worker (HCW) starts working with patients." The MDH Assisted Living Resources and Frequently Asked Questions website updated December 13, 2024, included under Tuberculosis Screening, "Each facility must establish and maintain a comprehensive TB infection control program according to the most current tuberculosis infection control guidelines issued by the United States CDC, Division of Tuberculosis Elimination, as published in the CDC's Morbidity and Mortality Weekly Report. The program must include a tuberculosis infection control plan that covers all paid and unpaid employees, contractors, students, and regularly scheduled volunteers." The licensee's Tuberculosis Screening policy, effective date July 1, 2025, indicated the licensee would, "establish and maintain a comprehensive tuberculosis infection control program according to the most current tuberculosis infection control guidelines issued by the United States Centers for Disease Control and Prevention (CDC), Division of Tuberculosis Elimination, as published in the CDC's Morbidity and Mortality Weekly Report (MMWR)." No further information was provided. TIME PERIOD FOR CORRECTION: Twenty-one (21) days	0 660			
0 775 SS=F	144G.45 Subd. 2. (a) Fire protection and physical environment	0 775			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 775	Continued From page 7 Each assisted living facility must comply with the State Fire Code in Minnesota Rules, chapter 7511, and: This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated March 3, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Seven (7) days	0 775			
0 790 SS=F	144G.45 Subd. 2 (a) (2-3) Fire protection and physical environment (2) install and maintain portable fire extinguishers in accordance with the State Fire Code;	0 790			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 790	Continued From page 8 (3) install portable fire extinguishers having a minimum 2-A:10-B:C rating within Group R-3 occupancies, as defined by the State Fire Code, located so that the travel distance to the nearest fire extinguisher does not exceed 75 feet, and maintained in accordance with the State Fire Code; and This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated March 3, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Seven (7) days	0 790			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 800	Continued From page 9	0 800			
0 800 SS=C	144G.45 Subd. 2 (a) (4) Fire protection and physical environment (4) keep the physical environment, including walls, floors, ceiling, all furnishings, grounds, systems, and equipment in a continuous state of good repair and operation with regard to the health, safety, comfort, and well-being of the residents in accordance with a maintenance and repair program. This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level one violation (a violation that will cause only minimal impact on the resident and does not affect health or safety) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated March 3, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Twenty-one	0 800			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 800	Continued From page 10 (21) days	0 800			
0 810 SS=F	144G.45 Subd. 2 (b-f) Fire protection and physical environment (b) Each assisted living facility shall develop and maintain fire safety and evacuation plans. The plans shall include but are not limited to: (1) location and number of resident sleeping rooms; (2) staff actions to be taken in the event of a fire or similar emergency; (3) fire protection procedures necessary for residents; and (4) procedures for resident movement, evacuation, or relocation during a fire or similar emergency including the identification of unique or unusual resident needs for movement or evacuation. (c) Staff of assisted living facilities shall receive training on the fire safety and evacuation plans upon hiring and at least twice per year thereafter. (d) Fire safety and evacuation plans shall be readily available at all times within the facility. (e) Residents who are capable of assisting in their own evacuation shall be trained on the proper actions to take in the event of a fire to include movement, evacuation, or relocation. The training shall be made available to residents at least once per year. (f) Evacuation drills are required for staff twice per year per shift with at least one evacuation drill every other month. Evacuation of the residents is not required. Fire alarm system activation is not required to initiate the evacuation drill.	0 810			

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 41095	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/05/2026
NAME OF PROVIDER OR SUPPLIER KHEYRCARE LLC			STREET ADDRESS, CITY, STATE, ZIP CODE 9225 CLINTON AVENUE SOUTH BLOOMINGTON, MN 55420		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
0 810	Continued From page 11 This MN Requirement is not met as evidenced by: Based on observation, interview, and record review, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death) and was issued at a widespread scope (when problems are pervasive or represent a systemic failure that has affected or has the potential to affect a large portion or all of the residents). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated March 3, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Seven (7) days	0 810			



Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St. Paul, MN 55164
Phone: 651-201-4500

Food & Beverage Inspection Report

Page: 1

Establishment Info

Kheycare LLC
9225 Clinton Avenue South
Bloomington, MN 55420
Hennepin County
Parcel:

Phone:

License Info

License: HFID 41095

Risk:
License:
Expires on:
CFPM: ALI F EGAL
CFPM #: 63664; Exp: 12-03-2028

Inspection Info

Report Number: F1062261044
Inspection Type: Full - Single
Date: 3/3/2026 Time: 12:00 pm
Duration: minutes
Announced Inspection: Yes
Total Priority 1 Orders: 1
Total Priority 2 Orders: 0
Total Priority 3 Orders: 1
Delivery: Emailed

New Order: 2-100 Supervision

2-102.12DMN Priority Level: Priority 3 CFP#: 2

MN Rule 4626.0033D Post the certified food protection manager certificate.

COMMENT: FACILITY DOES NOT HAVE CFPM CERTIFICATE POSTED AT TIME OF INSPECTION. A CFPM IS EMPLOYED, BUT CERTIFICATE HAS NOT YET ARRIVED, PER STAFF. COMPLY WITH RULE ABOVE.

Comply By: 3/3/2026 Originally Issued On: 3/3/2026

! New Order: 3-300B Protection from Contamination: cross-contamination, eggs

3-302.11A(1) Priority Level: Priority 1 CFP#: 15

MN Rule 4626.0235A(1) Separate raw animal foods during storage, preparation, holding, and display from ready-to-eat foods to prevent cross-contamination.

COMMENT: OBSERVED RAW SHELL EGGS STORED IN REFRIGERATOR ABOVE READY-TO-EAT FOODS SUCH AS TOMATOES. ENSURE THAT RAW ANIMAL PROTEINS ARE NOT STORED ABOVE READY-TO-EAT FOODS IN ORDER TO MINIMIZE RISK OF CONTAMINATION OF RTE FOODS.

Comply By: 3/3/2026 Originally Issued On: 3/3/2026

Food & Beverage General Comment

INSPECTION COMPLETED ON BEHALF OF MARY BRUESS (HRD).

FACILITY USES RESIDENTIAL COMBINED REFRIGERATOR AND FREEZER UNIT. TWO BASIN SINK, ONE BASIN DESIGNATED FOR HANDWASHING. WOOD FLOORS, DRYWALL WALLS, LAMINATE COUNTERS. RESIDENTIAL DISHWASHER SANITIZES DISHES VIA HOT WATER.

DISCUSSED EMPLOYEE ILLNESS RECORDING, PROHIBITION OF KEEPING LEFTOVERS, EGG COOK TEMPS, ORGANIZATION OF HELD FOOD TO PREVENT CONTAMINATION, AND SANITIZER TESTING.

NOTE: All new food equipment must meet the applicable standards of the American National Standards Institute (ANSI). Plans and specifications must be submitted for review and approval prior to new construction, remodeling or alterations.

I acknowledge receipt of the Metro District Office inspection report number F1062261044 from 3/3/2026

Fardous Egal

Nicholas Streeter, RS

PIC

Public Health Sanitarian 2
nicholas.streeter@state.mn.us



Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St. Paul, MN 55164

Temperature Observations/Recordings

Page: 1

Establishment Info	Inspection Info
Kheycare LLC	Report Number: F1062261044
Bloomington	Inspection Type: Full
County/Group: Hennepin County	Date: 3/3/2026
	Time: 12:00 pm

Food Temperature: Product/Item/Unit: SOUR CREAM; Temperature Process: Cold-Holding

Location: FREEZER/FRIDGE UNIT at 34 Degrees F.

Comment:

Violation Issued?: No

Equipment Temperature: Product/Item/Unit: ; Temperature Process: Cold-Holding

Location: FREEZER/FRIDGE UNIT at 39 Degrees F.

Comment:

Violation Issued?: No



Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St. Paul, MN 55164

Sanitizer Observations/Recordings

Page: 1

Establishment Info

Inspection Info

Kheycare LLC
Bloomington
County/Group: Hennepin County

Report Number: F1062261044
Inspection Type: Full
Date: 3/3/2026
Time: 12:00 pm

Sanitizing Equipment: Product: Hot Water; **Sanitizing Process:** Dish Machine
Location: RESIDENTIAL WASHING UNIT **Equal To** 160 Degrees F.
Comment:
Violation Issued?: No

Physical Environment Inspection Report

ASSISTED LIVING | ASSISTED LIVING WITH DEMENTIA CARE

Project No: SL41095015-0	Date: 3/3/2026
Facility Name: Kheycare LLC	
Facility Address: 9255 Clinton Ave S Minneapolis MN 55420	

☒ **TAG IDENTIFICATION: 0775**

SCOPE/ SEVERITY: Level 2; Widespread

TIME PERIOD OF CORRECTION: Seven (7) days

1. Each assisted living facility must comply with the provisions of the Minnesota State Fire Code (MSFC) in Minnesota Rules chapter 7511. [Minn. Stat. 144G.45 subd. 2]
2. Lighted matches, cigarettes, cigars or other burning object shall not be discarded in such a manner that could cause ignition of other combustible material. [Minn. Stat. 144G.45 subd. 2; MSFC 310.7]

Comments: Cigarette ash was observed discarded on combustible material (cardboard) inside the garage. Discarded cigarette butts were also observed on the garage floor.

☒ **TAG IDENTIFICATION: 0790**

SCOPE/ SEVERITY: Level 2; Widespread

TIME PERIOD OF CORRECTION: Seven (7) days

1. Portable fire extinguishers installed and maintained to MN State Fire Code. [Minn. Stat. 144G.45 subd.2]

Comments: The fire extinguisher located on the lower level next to the stairs was low on pressure. The extinguisher provided in the laundry room should be serviced and have monthly staff inspections to ensure condition and operability.

☒ **TAG IDENTIFICATION: 0800**

SCOPE/ SEVERITY: Level 1; Widespread

TIME PERIOD OF CORRECTION: Twenty One (21) days

1. The physical environment, including walls, floors, ceiling, all furnishings, grounds, systems, and equipment are in a continuous state of good repair and operation with regard to the health, safety, comfort, and well-being of the residents in accordance with a maintenance and repair program. [Minn. Stat. 144G.45 subd.2]

Comments: Multiple deck boards on the exterior rear deck attached to the facility were rotten and deteriorated. The deteriorated condition of the deck components created a potential trip or fall hazard.

☒ **TAG IDENTIFICATION: 0810**

SCOPE/ SEVERITY: Level 2; Widespread

TIME PERIOD OF CORRECTION: Seven (7) days

-
1. Each assisted living facility shall develop and maintain fire safety and evacuation plans (FSEP) that include employee actions to be taken in the event of a fire or similar emergency. [Minn. Stat. 144G.45 subd.2]

Comments: The FSEP failed to provide specific employee actions to take in the event of a fire or similar emergency relative to the facility's building layout and environmental risks. The provided FSEP was from a third-party provider and had not been updated to the specific facility.