DEPARTMENT OF HEALTH

Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically Delivered

April 9, 2026

Licensee
Accessible Hearts Care LLC
726 Jefferson Street
Anoka, MN 55303

RE: Project Number SL41500015

Dear Licensee:

This is your **official notice** that you have been **granted your assisted living facility license.** Your license effective and expiration dates remain the same as on your provisional license. Your updated status will be listed on the license certificate at renewal and **this letter serves as proof** in the meantime. If you have not received a letter from us with information regarding renewing your license within 60 days prior to your expiration date, please contact us at (651) 201-5273 or by email at Health.assistedliving@state.mn.us.

The Minnesota Department of Health completed an initial survey on March 18, 2026, for the purpose assessing compliance with state licensing statutes. At the time of the survey, the Minnesota Department of Health noted a violation of the laws pursuant to Minnesota Statute, Chapter 144G.

The Department of Health concludes the licensee is in substantial compliance. State law requires the facility must take action to correct the state correction orders and document the actions taken to comply in the facility's records. The Department reserves the right to return to the facility at any time should the Department receive a complaint or deem it necessary to ensure the health, safety, and welfare of residents in your care.

STATE CORRECTION ORDERS
The enclosed State Form documents the state correction orders. The Department of Health documents state correction orders using federal software. Tag numbers are assigned to Minnesota state statutes for Home Care Providers. The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute number and the corresponding text of the state statute out of compliance are listed in the "Summary Statement of Deficiencies" column. This column also includes the findings that are in violation of the state statute after the statement, "This MN Requirement is not met as evidenced by . . ."

In accordance with Minn. Stat. § 144G.31 Subd. 4, MDH may assess fines based on the level and scope of the violations; **however, no immediate fines are assessed for this survey of your facility**.

DOCUMENTATION OF ACTION TO COMPLY
Per Minn. Stat. § 144G.30, Subd. 5(c), the licensee must document actions taken to comply with the correction orders within the time period outlined on the state form; however, plans of correction are not required to be submitted for approval.

The correction order documentation should include the following:

- Identify how the area(s) of noncompliance was corrected related to the resident(s)/employee(s)

identified in the correction order.
- Identify how the area(s) of noncompliance was corrected for all of the provider's residents/employees that may be affected by the noncompliance.
- Identify what changes to your systems and practices were made to ensure compliance with the specific statute(s).

CORRECTION ORDER RECONSIDERATION PROCESS

In accordance with Minn. Stat. § 144G.32, Subd. 2, you may challenge the correction order issued, including the level and scope, and any fine assessed through the correction order reconsideration process. The request for reconsideration must be in writing and received by the Department of Health within 15 calendar days of the correction order receipt date.

To submit a reconsideration request, please visit:
https://forms.web.health.state.mn.us/form/HRDAppealsForm

The MDH Health Regulation Division (HRD) values your feedback about your experience during the survey and/or investigation process. Please fill out this anonymous provider feedback questionnaire at your convenience at this link: **https://forms.office.com/g/Bm5uQEpHVa**. Your input is important to us and will enable MDH to improve its processes and communication with providers. If you have any questions regarding the questionnaire, please contact Susan Winkelmann at susan.winkelmann@state.mn.us or call 651-201-5952.

You are encouraged to retain this document for your records. It is your responsibility to share the information contained in the letter and state form with your organization's Governing Body.

If you have any questions, please contact me.

Sincerely,

Kelly Thorson

Kelly Thorson, Supervisor
State Evaluation Team
Email: Kelly.Thorson@state.mn.us
Telephone: 320-223-7336 Fax: 1-866-890-929

HHH

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	41500	A. BUILDING: _____ B. WING _____	03/18/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ACCESSIBLE HEARTS CARE LLC	726 JEFFERSON ST ANOKA, MN 55303

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 000	Initial Comments *****ATTENTION***** ASSISTED LIVING PROVIDER LICENSING CORRECTION ORDER(S) In accordance with Minnesota Statutes, section 144G.08 to 144G.95, these correction orders are issued pursuant to a survey. Determination of whether violations are corrected requires compliance with all requirements provided at the Statute number indicated below. When Minnesota Statute contains several items, failure to comply with any of the items will be considered lack of compliance. INITIAL COMMENTS: SL41500015 On March 16, 2026, through March 18, 2026, the Minnesota Department of Health conducted a full survey at the above provider and the following correction orders are issued. At the time of the survey, there was one resident; one receiving services under the Provisional Assisted Living Facility license.	0 000	Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota State Statutes for Assisted Living License Providers. The assigned tag number appears in the far-left column entitled "ID Prefix Tag." The state Statute number and the corresponding text of the state Statute out of compliance is listed in the "Summary Statement of Deficiencies" column. This column also includes the findings which are in violation of the state requirement after the statement, "This Minnesota requirement is not met as evidenced by." Following the surveyors' findings is the Time Period for Correction. PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES,"PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE. THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES. The letter in the left column is used for tracking purposes and reflects the scope and level issued pursuant to 144G.31 subd. 1, 2, and 3.	
0 775 SS=D	144G.45 Subd. 2. (a) Fire protection and physical environment Each assisted living facility must comply with the	0 775		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	41500	A. BUILDING: _____ B. WING _____	03/18/2026

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ACCESSIBLE HEARTS CARE LLC	726 JEFFERSON ST ANOKA, MN 55303

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
0 775	Continued From page 1 State Fire Code in Minnesota Rules, chapter 7511, and: This MN Requirement is not met as evidenced by: Based on observation, record review, and interview, the licensee failed to ensure the physical environment of the facility was maintained in compliance with the requirements of Minnesota Statute 144G. This practice resulted in a level two violation (a violation that did not harm a resident's health or safety but had the potential to have harmed a resident's health or safety, but was not likely to cause serious injury, impairment, or death), and was issued at an isolated scope (when one or a limited number of residents are affected or one or a limited number of staff are involved or the situation has occurred only occasionally). The findings include: Please refer to the document titled, Physical Environment Inspection Report (PEIR) dated March 16, 2026, for the specific violations related the physical environment under Minnesota Statute 144G. TIME PERIOD FOR CORRECTION: Seven (7) days	0 775		

Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St Paul, MN 55164
Phone: 651-201-4500

Food & Beverage Inspection Report

Establishment Info

ACCESSIBLE HEARTS CARE LLC
726 Jefferson Street Anoka
Anoka, MN 55303
Anoka County
Parcel:

Phone:

License Info

License: HFID 41500

Risk:
License:
Expires on:
CFPM: Rachael Kanyugi

CFPM #: 124417; Exp: 8/3/2027

Inspection Info

Report Number: F7963261039
Inspection Type: Full - Single
Date: 3/17/2026 Time: 2:49:19 PM
Duration: minutes
Announced Inspection: Yes
Total Priority 1 Orders: 0
Total Priority 2 Orders: 0
Total Priority 3 Orders: 0
Delivery: Emailed

No orders were issued for this inspection report.

Food & Beverage General Comment

MET WITH MDH NURSE SURVEYOR WENDY ROBARGE AND ESTABLISHMENT REPRESENTATIVE RACHAEL KANYUGI. DISCUSSED THE FOLLOWING-

-EMPLOYEE ILLNESS POLICY AND LOG
-REPORTABLE DISEASES
-VOMIT/FECAL CLEAN UP
-HIGHLY SUSCEPTIBLE POPULATION RESTRICTIONS
-TESTING OF DISHWASHER RINSE TEMPERATURE
-FOOD THERMOMETER
-SANITIZING OF SURFACES

THIS IS A RESIDENTIAL HOME USING SAME-DAY FOOD SERVICE. IT HAS A DISHWASHER TO WASH AND SANITIZE DISHES AND UTENSILS.

THE KITCHEN HAS PAINTED WOOD CABINETS, SOLID SURFACE COUNTERTOPS, PAINTED WALLS AND CEILING AND VINYL FLOORING.

NOTE: All new food equipment must meet the applicable standards of the American National Standards Institute (ANSI). Plans and specifications must be submitted for review and approval prior to new construction, remodeling or alterations.

I acknowledge receipt of the Metro District Office inspection report number F7963261039 from 3/17/2026

Rachael Kanyugi
PIC

Peggy Spadafore,
Public Health Sanitarian Supervisor
651-201-3979
peggy.spadafore@state.mn.us

Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St Paul, MN 55164

Temperature Observations/Recordings

Establishment Info

ACCESSIBLE HEARTS CARE LLC
Anoka
County/Group: Anoka County

Inspection Info

Report Number: F7963261039
Inspection Type: Full
Date: 3/17/2026
Time: 2:49:19 PM

Food Temperature: Product/Item/Unit: MILK**; Temperature Process:**
Location: REFRIGERATOR at 39 Degrees F.
Comment:
Violation Issued?: No

Metro District Office
Minnesota Department of Health
625 Robert St N, PO BOX 64975
St Paul, MN 55164

Sanitizer Observations/Recordings

Establishment Info

ACCESSIBLE HEARTS CARE LLC
Anoka
County/Group: Anoka County

Inspection Info

Report Number: F7963261039
Inspection Type: Full
Date: 3/17/2026
Time: 2:49:19 PM

Sanitizing Equipment: **Product:** Hot Water**; Sanitizing Process:**
Location: DISHWASHER RINSE **Equal To** 160 Degrees F.
Comment:
Violation Issued?: No

DEPARTMENT OF HEALTH

Physical Environment Inspection Report

ENGINEERING | ASSISTED LIVING

Project No: SL41500015-0	**Date:** March 18, 2026
Facility Name: ACCESSIBLE HEARTS CARE LLC	
Facility Address: 726 JEFFERSON STREET, ANOKA, MN 55303	

☒ **TAG IDENTIFICATION: 0775**

SCOPE/ SEVERITY: Level 2; Isolated **TIME PERIOD OF CORRECTION:** Seven (7) days

1. Each assisted living facility must comply with the provisions of the Minnesota State Fire Code (MSFC) in Minnesota Rules chapter 7511. [Minn. Stat. 144G.45 subd. 2]

2. Occupancy separation shall be provided in Group I and Group R occupancies. Existing wood lath and plaster in good condition or ½ inch gypsum wallboard is acceptable where one hour occupancy separations are required. [Minn. Stat. 144G.45 subd. 2; MSFC 1105.2]

   Comments: In the attached garage, the ceiling access panel was missing. The garage ceiling shall be maintained free of holes and sealed to prevent the passage of smoke or fire.

3. Extension cords and flexible cords shall not be a substitute for permanent wiring. [Minn. Stat. 144G.45 subd. 2; MSFC 604.5]

   Comments: An extension cord was used in the main floor living room to supply power.

4. Relocatable power taps (power strips) shall be directly connected to a permanently installed receptacle. [Minn. Stat. 144G.45 subd. 2; MSFC 604.4.2]

   Comments: Two power strips were daisy chained together in the main floor living room. This was corrected during the facility tour.