

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: BYP7
Facility ID: 00454

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245560
2. STATE VENDOR OR MEDICAID NO. (L2) 767842800
3. NAME AND ADDRESS OF FACILITY (L3) EDGEBROOK CARE CENTER (L4) 505 TROSKY ROAD WEST (L5) EDGERTON, MN (L6) 56128
4. TYPE OF ACTION: 7 (L8)
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)
6. DATE OF SURVEY 06/29/2017 (L34)
8. ACCREDITATION STATUS: (L10)
7. PROVIDER/SUPPLIER CATEGORY 02 (L7)
10. THE FACILITY IS CERTIFIED AS:
11. LTC PERIOD OF CERTIFICATION
12. Total Facility Beds 56 (L18)
13. Total Certified Beds 56 (L17)
14. LTC CERTIFIED BED BREAKDOWN
15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):
17. SURVEYOR SIGNATURE Kathryn Serie, Unit Supervisor Date: 07/26/2017 (L19)
18. STATE SURVEY AGENCY APPROVAL Shellae Dietrich, Certification Specialist Date: 07/27/2017 (L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY
20. COMPLIANCE WITH CIVIL RIGHTS ACT:
21. 1. Statement of Financial Solvency (HCFA-2572)
2. Ownership/Control Interest Disclosure Stmt (HCFA-1513)
3. Both of the Above:
22. ORIGINAL DATE OF PARTICIPATION 06/01/1991 (L24)
23. LTC AGREEMENT BEGINNING DATE (L41)
24. LTC AGREEMENT ENDING DATE (L25)
26. TERMINATION ACTION: 00 (L30)
25. LTC EXTENSION DATE: (L27)
27. ALTERNATIVE SANCTIONS
28. TERMINATION DATE: (L28)
29. INTERMEDIARY/CARRIER NO. 00140 (L31)
31. RO RECEIPT OF CMS-1539 (L32)
32. DETERMINATION OF APPROVAL DATE 07/18/2017 (L33)
30. REMARKS
Posted 07/28/2017 Co.
DETERMINATION APPROVAL



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

CMS Certification Number (CCN): 245560

July 26, 2017

Mr. Michael Redinger, Administrator
Edgebrook Care Center
505 Trosky Road West
Edgerton, MN 56128

Dear Mr. Redinger:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective June 22, 2017 the above facility is certified for or recommended for:

56 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 56 skilled nursing facility beds. You should advise our office of any changes in staffing, services, or organization, which might affect your certification status. If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in cursive script that reads "Anne Peterson".

Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
St. Paul, MN 55164-0900
anne.peterson@state.mn.us
Telephone #: 651-201-4206 Fax #: 651-215-9697

cc: Licensing and Certification File



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered

July 26, 2017

Mr. Michael Redinger, Administrator
Edgebrook Care Center
505 Trosky Road West
Edgerton, MN 56128

RE: Project Number S5560026

Dear Mr. Redinger:

On June 5, 2017, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on May 24, 2017. This survey found the most serious deficiencies to be a pattern of deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level E) whereby corrections were required.

On June 29, 2017, the Minnesota Department of Health completed a Post Certification Revisit (PCR) by review of your plan of correction and on July 5, 2017 the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on May 24, 2017. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of June 22, 2017. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on May 24, 2017, effective June 22, 2017 and therefore remedies outlined in our letter to you dated June 5, 2017, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in cursive script that reads "Anne Peterson".

Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
St. Paul, MN 55164-0900
anne.peterson@state.mn.us
Telephone #: 651-201-4206 Fax #: 651-215-9697

cc: Licensing and Certification File



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered

July 26, 2017

Mr. Michael Redinger, Administrator
Edgebrook Care Center
505 Trosky Road West
Edgerton, MN 56128

Re: Reinspection Results - Project Number S5560026

Dear Mr. Redinger:

On June 29, 2017 survey staff of the Minnesota Department of Health, Licensing and Certification Program completed a reinspection of your facility, to determine correction of orders found on the survey completed on May 24, 2017, with orders received by you on June 5, 2017.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,

A handwritten signature in cursive script that reads "Anne Peterson".

Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
St. Paul, MN 55164-0900
anne.peterson@state.mn.us
Telephone #: 651-201-4206 Fax #: 651-215-9697

cc: Licensing and Certification File

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: Byp7

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00454

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245560			3. NAME AND ADDRESS OF FACILITY (L3) EDGEBROOK CARE CENTER			4. TYPE OF ACTION: <u>2</u> (L8)		
2.STATE VENDOR OR MEDICAID NO. (L2) 767842800			(L4) 505 TROSKY ROAD WEST			1. Initial 2. Recertification		
			(L5) EDGERTON, MN (L6) 56128			3. Termination 4. CHOW		
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)			7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)					
6. DATE OF SURVEY 05/24/2017 (L34)			01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA			8. Full Survey After Complaint		
8. ACCREDITATION STATUS: ___ (L10)			02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF			FISCAL YEAR ENDING DATE: (L35)		
0 Unaccredited 1 TJC 2 AOA 3 Other			03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC			12/31		
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) :			10.THE FACILITY IS CERTIFIED AS:					
12.Total Facility Beds 56 (L18)			A. In Compliance With			And/Or Approved Waivers Of The Following Requirements:		
13.Total Certified Beds 56 (L17)			Program Requirements ___ 2. Technical Personnel ___ 6. Scope of Services Limit			___ 3. 24 Hour RN ___ 7. Medical Director		
			Compliance Based On:			___ 4. 7-Day RN (Rural SNF) ___ 8. Patient Room Size		
			___ 1. Acceptable POC			___ 5. Life Safety Code ___ 9. Beds/Room		
			X B. Not in Compliance with Program			* Code: B* (L12)		
			Requirements and/or Applied Waivers:					
14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS			
18 SNF (L37)	18/19 SNF (L38)	19 SNF (L39)	ICF (L42)	IID (L43)	1861 (e) (1) or 1861 (j) (1): (L15)			
	56							

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE _____ Date : _____

Lois Boerboom, HFE NE II **06/19/2017** (L19)

18. STATE SURVEY AGENCY APPROVAL _____ Date: _____

Kamala Fiske-Downing, Enforcement Specialist **07/18/2017** (L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY			20. COMPLIANCE WITH CIVIL RIGHTS ACT:			21. 1. Statement of Financial Solvency (HCFA-2572)		
___ 1. Facility is Eligible to Participate						2. Ownership/Control Interest Disclosure Stmt (HCFA-1513)		
___ 2. Facility is not Eligible (L21)						3. Both of the Above : _____		
22. ORIGINAL DATE OF PARTICIPATION 06/01/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		24. LTC AGREEMENT ENDING DATE (L25)		26. TERMINATION ACTION: (L30)		
						<u>00</u> <u>VOLUNTARY</u> <u>INVOLUNTARY</u>		
						01-Merger, Closure 05-Fail to Meet Health/Safety		
						02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement		
						03-Risk of Involuntary Termination <u>OTHER</u>		
						04-Other Reason for Withdrawal 07-Provider Status Change		
						00-Active		
25. LTC EXTENSION DATE: (L27)			27. ALTERNATIVE SANCTIONS					
			A. Suspension of Admissions: (L44)					
			B. Rescind Suspension Date: (L45)					
28. TERMINATION DATE: (L28)				29. INTERMEDIARY/CARRIER NO. 00140 (L31)		30. REMARKS		
31. RO RECEIPT OF CMS-1539 (L32)				32. DETERMINATION OF APPROVAL DATE (L33)		DETERMINATION APPROVAL		



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered
June 5, 2017

Mr. Michael Redinger, Administrator
Edgebrook Care Center
505 Trosky Road West
Edgerton, Minnesota 56128

RE: Project Number S5560026

Dear Mr. Redinger:

On May 24, 2017, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs. This survey found the most serious deficiencies in your facility to be a pattern of deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level E), as evidenced by the electronically delivered CMS-2567, whereby corrections are required.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

**Kathryn Serie, Unit Supervisor
Mankato Survey Team
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
1400 East Lyon Street
Marshall, Minnesota 56258-2529
Email: kathryn.serie@state.mn.us
Phone: (507) 476-4233
Fax: (507) 344-2723**

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by July 3, 2017, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that

the deficient practice will not recur;

- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

The state agency may, in lieu of a revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by August 24, 2017 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was

Edgebrook Care Center

June 5, 2017

Page 5

issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by November 24, 2017 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Fire Safety Supervisor
Health Care Fire Inspections
Minnesota Department of Public Safety
State Fire Marshal Division
445 Minnesota Street, Suite 145
St. Paul, Minnesota 55101-5145

Edgebrook Care Center
June 5, 2017
Page 6

Email: tom.linhoff@state.mn.us
Telephone: (651) 430-3012
Fax: (651) 215-0525

Feel free to contact me if you have questions related to this eNotice.

Sincerely,



Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: (651) 201-4112 Fax: (651) 215-9697
Email: Kamala.Fiske-Downing@state.mn.us

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	INITIAL COMMENTS On May 21, 22, 23, and 24, 2017, a standard survey was completed at your facility by the Minnesota Department of Health to determine if your facility was in compliance with requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities. The facility's plan of correction (POC) will serve as your allegation of compliance upon the Department's acceptance. Because you are enrolled in ePOC, your signature is not required at the bottom of the first page of the CMS-2567 form. Your electronic submission of the POC will be used as verification of compliance. Upon receipt of an acceptable electronic POC, an on-site revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.	F 000			
F 167 SS=C	483.10(g)(10)(i)(11) RIGHT TO SURVEY RESULTS - READILY ACCESSIBLE (g)(10) The resident has the right to- (i) Examine the results of the most recent survey of the facility conducted by Federal or State surveyors and any plan of correction in effect with respect to the facility; and (g)(11) The facility must-- (i) Post in a place readily accessible to residents, and family members and legal representatives of residents, the results of the most recent survey of the facility.	F 167		5/24/17	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

06/09/2017

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 167	<p>Continued From page 1</p> <p>(ii) Have reports with respect to any surveys, certifications, and complaint investigations made respecting the facility during the 3 preceding years, and any plan of correction in effect with respect to the facility, available for any individual to review upon request; and</p> <p>(iii) Post notice of the availability of such reports in areas of the facility that are prominent and accessible to the public.</p> <p>(iv) The facility shall not make available identifying information about complainants or residents. This REQUIREMENT is not met as evidenced by: Based on observation, interview and document review the facility failed to ensure the current survey results were readily accessible to residents and family members. This had the potential to affect all 50 residents, visitors and/or legal representatives who wished to review the results of the most recent survey.</p> <p>Findings include:</p> <p>During the initial tour of the facility on 5/21/17 (Sunday), at 2:16 p.m. noted a sign that indicated the following: the survey results and plans of correction for the past three years were available upon request. Contact the business office for details.</p> <p>During an interview on 5/21/17, at 3:10 p.m. registered nurse (RN)-B and licensed practical nurse (LPN)-A both verified the business office was closed and locked. LPN-A indicated she did not know where to located the survey results were but thought they may be in the business office. RN-B and LPN-C further verified the</p>	F 167	<p>Disclaimer: Preparation and execution of this response and plan of correction does not constitute an admission or agreement by the provider of the truth of the facts alleged or conclusions set forth in the statement of deficiencies. The plan of correction is prepared and/or executed solely because it is required by the provisions of federal and state law. For the purposes of any allegation that the center is not in substantial compliance with federal requirements of participation, this response and plan of correction constitutes the center's allegation of compliance in accordance with section 7305 of the State Operations Manual.</p> <p>Three years of survey results are posted in a readily accessible area. This was done on May 21st by the administrator. This has the potential to affect all residents.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 167	Continued From page 2 survey results were not readily available to residents or visitors unless they were requested. It was also confirmed that access to the survey results on a week-end were difficult.	F 167	The Administrator and/or DNS will ensure that three years of surveys are readily accessible and posted. Postings for survey will be audited monthly by the Administrator or DON for 3 months to ensure they are readily accessible. This will be reviewed at the monthly QAPI meeting for any further review and recommendations.		
F 280 SS=D	483.10(c)(2)(i-ii,iv,v)(3),483.21(b)(2) RIGHT TO PARTICIPATE PLANNING CARE-REVISE CP 483.10 (c)(2) The right to participate in the development and implementation of his or her person-centered plan of care, including but not limited to: (i) The right to participate in the planning process, including the right to identify individuals or roles to be included in the planning process, the right to request meetings and the right to request revisions to the person-centered plan of care. (ii) The right to participate in establishing the expected goals and outcomes of care, the type, amount, frequency, and duration of care, and any other factors related to the effectiveness of the plan of care. (iv) The right to receive the services and/or items included in the plan of care. (v) The right to see the care plan, including the right to sign after significant changes to the plan of care. (c)(3) The facility shall inform the resident of the right to participate in his or her treatment and	F 280		6/22/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 280	<p>Continued From page 3 shall support the resident in this right. The planning process must--</p> <p>(i) Facilitate the inclusion of the resident and/or resident representative.</p> <p>(ii) Include an assessment of the resident's strengths and needs.</p> <p>(iii) Incorporate the resident's personal and cultural preferences in developing goals of care.</p> <p>483.21 (b) Comprehensive Care Plans</p> <p>(2) A comprehensive care plan must be-</p> <p>(i) Developed within 7 days after completion of the comprehensive assessment.</p> <p>(ii) Prepared by an interdisciplinary team, that includes but is not limited to--</p> <p>(A) The attending physician.</p> <p>(B) A registered nurse with responsibility for the resident.</p> <p>(C) A nurse aide with responsibility for the resident.</p> <p>(D) A member of food and nutrition services staff.</p> <p>(E) To the extent practicable, the participation of the resident and the resident's representative(s). An explanation must be included in a resident's medical record if the participation of the resident and their resident representative is determined</p>	F 280			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 280	<p>Continued From page 4</p> <p>not practicable for the development of the resident's care plan.</p> <p>(F) Other appropriate staff or professionals in disciplines as determined by the resident's needs or as requested by the resident.</p> <p>(iii) Reviewed and revised by the interdisciplinary team after each assessment, including both the comprehensive and quarterly review assessments.</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on observation, interview, and document review, the facility failed to update and/or revise the plan of care to include the psychoactive medications for 3 of 3 residents (R13, R35, R19) reviewed for unnecessary medications.</p> <p>Findings include:</p> <p>R13 was admitted with diagnoses that included: Alzheimer's disease, psychosis, recurrent depressive disorder and insomnia.</p> <p>Review of the medication administration record (MAR) dated May 2017 identified R13 received psychoactive medications which included Celexa (anxiety), Remeron (for depressive disorder) and Zyprexa (for paranoid state).</p> <p>Review of the current care plan did not address R13's psychoactive medications. The care plan identified nonpharmacological interventions for the behavioral issues but did not identify the use of psychoactive medications.</p> <p>R35 was admitted on 1/16/17, with diagnoses including: anxiety disorder, recurrent depressive</p>	F 280	<p>R13, R19 and R35 care plans were reviewed and updated for the use of psychoactive medication on June 09th 2017 by DON.</p> <p>This has the potential to affect all residents who require the use of psychoactive medications.</p> <p>Education will be provided to licensed nurses on June 22 by DON or designee on the updating of care plans to include psychoactive medications in a timely manner. Care plans for all residents with psychoactive meds have been reviewed and updated on June 9th by DON or designee.</p> <p>Audits on care plan completion and inclusion of psychoactive medications will be done by the DNS/designee weekly for 4 weeks then monthly for 2 months. Results will be reviewed at the QAPI committee meeting for any further recommendations.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/12/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 280	<p>Continued From page 5</p> <p>disorder and dementia with behavioral disturbance.</p> <p>Review of the MAR dated May 2017 identified R35 had received psychoactive medications that included Trazodone (for anxiety disorder) and Risperidone (for dementia with behavioral disturbance).</p> <p>Review of the current care plan did not address R35's psychoactive medications. The care plan identified nonpharmacological interventions for the behavioral issues but did not identify the use of psychoactive medications.</p> <p>During interview with registered nurse (RN)-A on 5/23/17, at 1:15 p.m. she verified there were no pharmacological interventions integrated into either of R13's and R35's care plan related to behavioral issues so response to medications could be evaluated and monitored.</p> <p>.</p> <p>Review of the face sheet indicated R19 was admitted to the facility with diagnoses including: dementia with behavioral disturbance, unspecified psychosis and recurrent depressive disorder.</p> <p>Review of the medication administration record dated May 2017 identified R19 had received psychoactive medications that included Zoloft (antidepressant medication), Valium (antianxiety medication) and Seroquel (antipsychotic medication).</p> <p>Review of the current care plan did not address R19's psychoactive medications. The care plan identified nonpharmacological interventions for</p>	F 280			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES


PRINTED: 06/12/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 280	<p>Continued From page 6</p> <p>the behavioral issues but did not identify the use of psychoactive medications, the monitoring of these medications and expected resident response.</p> <p>During interview on 5/23/17, at 12:00 p.m. the director of nursing (DON) stated the psychoactive medications should have been identified on the care plans (R13, R35, R19) to monitor resident response as part of the behavioral plan of care.</p> <p>The policy and procedure titled Psychotropic Medications, revised 11/16 directed each resident's drug regimen must be free from unnecessary drugs and directed to monitor for side effects when administering psychotropic medications. A care plan policy related to psychoactive medications was not provided.</p>	F 280			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

75560025

PRINTED: 06/19/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ON-SITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety - State Fire Marshal Division. At the time of this survey, (Edgebrook Care Center) was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St Paul, MN 55101-5145, or</p> <p>By email to: Marian.Whitney@state.mn.us and</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

06/15/2017

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/19/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1 Angela.Kappenman@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. <p>Edgebrook Care Center is one-story in height, has a partial basement, and is fully sprinklered. The original building was built in 1968, with building additions in 1992 and 1997. All were determined to be of Type II(111) construction. Building 02 consists of the 2003 building addition, which includes a meeting room and offices. Building 02 is one-story in height, has no basement, is fully fire sprinkler protected and was determined to be of Type II(111) construction. Because the original building and the (3) addition are of the same type of construction and meet the construction type allowed for existing buildings, the facility was surveyed as one building.</p> <p>The building is protected by a full fire sprinkler system. The facility has a fire alarm system with full corridor smoke detection and spaces open to the corridors that is monitored for automatic fire department notification.</p> <p>The facility has a capacity of 56 beds and had a census of 50 at the time of the survey.</p> <p>The requirement at 42 CFR, Subpart 483.70(a) is</p>	K 000			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/19/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2	K 000			
K 351 SS=D	<p>NOT MET as evidenced by:</p> <p>NFPA 101 Sprinkler System - Installation</p> <p>Spinkler System - Installation 2012 EXISTING</p> <p>Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.</p> <p>In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers.</p> <p>In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems.</p> <p>19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1)</p> <p>This STANDARD is not met as evidenced by:</p> <p>Spinkler System - Installation 2012 EXISTING</p> <p>Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems.</p> <p>In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers.</p> <p>In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as</p>	K 351	<p>A fire sprinkler head was installed in the chair storage room off the dining room on 6/1/17.</p>	6/1/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/19/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 351	Continued From page 3 required by NFPA 13, Standard for Installation of Sprinkler Systems. 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) Findings Include: On facility tour between 11:00 AM and 03:00 PM on 5/24/2017, based on observation and interview revealed that the following include: Observation during the inspection found the chair storage room off the dining does not have a fire sprinkler head located inside. This deficient practice could affect the safety of all the residents, staff and visitors within the smoke compartment. This deficient practice was confirmed by the Facility Maintenance Director at the time of discovery.	K 351			
K 374 SS=E	NFPA 101 Subdivision of Building Spaces - Smoke Barrie Subdivision of Building Spaces - Smoke Barrier Doors 2012 EXISTING Doors in smoke barriers are 1-3/4-inch thick solid bonded wood-core doors or of construction that resists fire for 20 minutes. Nonrated protective plates of unlimited height are permitted. Doors are permitted to have fixed fire window assemblies per 8.5. Doors are self-closing or automatic-closing, do not require latching, and are not required to swing in the direction of egress travel. Door opening provides a minimum clear width of 32 inches for swinging or horizontal doors. 19.3.7.6, 19.3.7.8, 19.3.7.9	K 374		6/7/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 06/19/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245560	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 05/24/2017
NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 374	<p>Continued From page 4</p> <p>This STANDARD is not met as evidenced by: Subdivision of Building Spaces - Smoke Barrier Doors 2012 EXISTING</p> <p>Doors in smoke barriers are 1-3/4-inch thick solid bonded wood-core doors or of construction that resists fire for 20 minutes. Nonrated protective plates of unlimited height are permitted. Doors are permitted to have fixed fire window assemblies per 8.5. Doors are self-closing or automatic-closing, do not require latching, and are not required to swing in the direction of egress travel. Door opening provides a minimum clear width of 32 inches for swinging or horizontal doors. 19.3.7.6, 19.3.7.8, 19.3.7.9</p> <p>Findings Include:</p> <p>On facility tour between 11:00 AM and 03:00 PM on 5/24/2017, based on observation and interview revealed that the following include: Observation during the inspection found Smoke barrier doors in the North and east wings do not close when tested.</p> <p>This deficient practice could affect the safety of all the residents, staff and visitors within the smoke compartments.</p> <p>This deficient practice was confirmed by the Facility Maintenance Director at the time of discovery.</p>	K 374	<p>The smoke barrier doors were adjusted and corrected on 6/7/17.</p> <p>The Director of Maintenance or designee will complete a weekly audit for 4 weeks and then monthly for 3 months to ensure all smoke barrier doors close properly. Results of the audit will be shared with the QAPI Committee for review.</p>		



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered
June 5, 2017

Mr. Michael Redinger, Administrator
Edgebrook Care Center
505 Trosky Road West
Edgerton, Minnesota 56128

Re: Enclosed State Nursing Home Licensing Orders - Project Number S5560026

Dear Mr. Redinger:

The above facility was surveyed on May 21, 2017 through May 24, 2017 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules and Statutes. At the time of the survey, the survey team from the Minnesota Department of Health, Health Regulation Division, noted one or more violations of these rules or statutes that are issued in accordance with Minn. Stat. § 144.653 and/or Minn. Stat. § 144A.10. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a civil fine for each deficiency not corrected shall be assessed in accordance with a schedule of fines promulgated by rule and/or statute of the Minnesota Department of Health.

To assist in complying with the correction order(s), a "suggested method of correction" has been added. This provision is being suggested as one method that you can follow to correct the cited deficiency. Please remember that this provision is only a suggestion and you are not required to follow it. Failure to follow the suggested method will not result in the issuance of a penalty assessment. You are reminded, however, that regardless of the method used, correction of the order within the established time frame is required. The "suggested method of correction" is for your information and assistance only.

You have agreed to participate in the electronic receipt of State licensure orders consistent with the Minnesota Department of Health Informational Bulletin 14-01, available at <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm> . The State licensing orders are delineated on the Minnesota Department of Health State Form and are being delivered to you electronically. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes.

The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule number and the corresponding text of the state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction

Edgebrook Care Center

June 5, 2017

Page 2

order. This column also includes the findings that are in violation of the state statute or rule after the statement, "This MN Requirement is not met as evidenced by." Following the surveyors findings are the Suggested Method of Correction and the Time Period For Correction.

PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.

THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES.

Although no plan of correction is necessary for State Statutes/Rules, please enter the word "corrected" in the box available for text. You must then indicate in the electronic State licensure process, under the heading completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health. We urge you to review these orders carefully, item by item, and if you find that any of the orders are not in accordance with your understanding at the time of the exit conference following the survey, you should contact Kathryn Serie, Unit Supervisor at (507) 476-4233 or at Kathryn.serie@state.mn.us.

You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.

Please note it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,



Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: (651) 201-4112 Fax: (651) 215-9697
Email: Kamala.Fiske-Downing@state.mn.us

cc: Licensing and Certification File

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00454	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Initial Comments</p> <p>*****ATTENTION*****</p> <p>NH LICENSING CORRECTION ORDER</p> <p>In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.</p> <p>Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected.</p> <p>You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.</p> <p>INITIAL COMMENTS: You have agreed to participate in the electronic receipt of State licensure orders consistent with the Minnesota Department of Health Informational Bulletin 14-01, available at <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm> The State licensing orders are delineated on the attached Minnesota</p>	2 000		

Minnesota Department of Health
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Electronically Signed

TITLE

(X6) DATE
06/09/17

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00454	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Continued From page 1</p> <p>Department of Health orders being submitted to you electronically. Although no plan of correction is necessary for State Statutes/Rules, please enter the word "corrected" in the box available for text. You must then indicate in the electronic State licensure process, under the heading completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health.</p> <p>On May 21, 22, 23, and 24, 2017, surveyors of this Department's staff, visited the above provider and the following correction orders are issued. Please indicate in your electronic plan of correction that you have reviewed these orders, and identify the date when they will be completed.</p> <p>Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes.</p> <p>The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction order. This column also includes the findings which are in violation of the state statute after the statement, "This Rule is not met as evidence by." Following the surveyors findings are the Suggested Method of Correction and Time period for Correction.</p> <p>PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.</p>	2 000		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00454	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	Continued From page 2 THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES.	2 000		
2 570	<p>MN Rule 4658.0405 Subp. 4 Comprehensive Plan of Care; Revision</p> <p>Subp. 4. Revision. A comprehensive plan of care must be reviewed and revised by an interdisciplinary team that includes the attending physician, a registered nurse with responsibility for the resident, and other appropriate staff in disciplines as determined by the resident's needs, and, to the extent practicable, with the participation of the resident, the resident's legal guardian or chosen representative at least quarterly and within seven days of the revision of the comprehensive resident assessment required by part 4658.0400, subpart 3, item B.</p> <p>This MN Requirement is not met as evidenced by: Based on observation, interview, and document review, the facility failed to update and/or revise the plan of care to include the psychoactive medications for 3 of 3 residents (R13, R35, R19) reviewed for unnecessary medications.</p> <p>Findings include:</p> <p>R13 was admitted with diagnoses that included: Alzheimer's disease, psychosis, recurrent depressive disorder and insomnia.</p> <p>Review of the medication administration record (MAR) dated May 2017 identified R13 received psychoactive medications which included Celexa,</p>	2 570	Corrected	6/22/17

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00454	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 570	<p>Continued From page 3</p> <p>Remeron for depressive disorder and Zyprexa for paranoid state.</p> <p>Review of the current care plan did not address R13's psychoactive medications. The care plan identified nonpharmacological interventions for the behavioral issues but did not identify the use of psychoactive medications..</p> <p>R35 was admitted on 1/16/17, with diagnoses including: anxiety disorder, recurrent depressive disorder and dementia with behavioral disturbance.</p> <p>Review of the MAR dated May 2017 identified R35 had received psychoactive medications that included Trazodone for anxiety disorder and Risperidone for dementia with behavioral disturbance.</p> <p>Review of the current care plan did not address R35's psychoactive medications. The care plan identified nonpharmacological interventions for the behavioral issues but did not identify the use of psychoactive medications.</p> <p>During interview with registered nurse (RN)-A on 5/23/17, at 1:15 p.m. she verified there were no pharmacological interventions integrated into either of R13's and R35's care plan related to behavioral issues so response to medications could be evaluated and monitored.</p> <p>Review of the face sheet indicated R19 was admitted to the facility with diagnoses including: dementia with behavioral disturbance, unspecified psychosis and recurrent depressive disorder.</p> <p>Review of the medication administration record</p>	2 570		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00454	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 570	<p>Continued From page 4</p> <p>dated May 2017 identified R19 had received psychoactive medications that included Zoloft (antidepressant medication), Valium (antianxiety medication) and Seroquel (antipsychotic medication).</p> <p>Review of the current care plan did not address R19's psychoactive medications. The care plan identified nonpharmacological interventions for the behavioral issues but did not identify the use of psychoactive medications, the monitoring of these medications and expected resident response.</p> <p>During interview on 5/23/17, at 12:00 p.m. the director of nursing (DON) stated the psychoactive medications should have been identified on the care plans (R13, R35, R19) to monitor resident response as part of the behavioral plan of care.</p> <p>The policy and procedure titled Psychotropic Medications, revised 11/16 directed each resident's drug regimen must be free from unnecessary drugs and directed to monitor for side effects when administering psychotropic medications. A care plan policy related to psychoactive medications was not provided.</p> <p>SUGGESTED METHOD OF CORRECTION: The director of nursing (DON) or designee, could develop and implement policies and procedures related to care plan revisions. The DON or designee, could provide training for all nursing staff related to the timeliness of care plan revisions. The quality assessment and assurance (QAA) committee could perform random audits to ensure compliance.</p> <p>TIME PERIOD FOR CORRECTION: Twenty-one (21) days.</p>	2 570		

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00454	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 05/24/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER EDGEBROOK CARE CENTER	STREET ADDRESS, CITY, STATE, ZIP CODE 505 TROSKY ROAD WEST EDGERTON, MN 56128
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE