



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically Delivered
March 26, 2025

Administrator
Central Todd County Care Center
406 East Highway 71
Clarissa, MN 56440

RE: CCN: 245521
Cycle Start Date: February 26, 2025

Dear Administrator:

On March 24, 2025, the Minnesota Department of Public Safety, completed a revisit to verify that your facility had achieved and maintained compliance. Based on our review, we have determined that your facility has achieved substantial compliance; therefore no remedies will be imposed.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads 'Kamala Fiske-Downing'.

Kamala Fiske-Downing
Compliance Analyst | Federal Enforcement
Health Regulation Division
Minnesota Department of Health
Kamala.Fiske-Downing@state.mn.us
Office: 651-201-4112



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
March 5, 2025

Administrator
Central Todd County Care Center
406 East Highway 71
Clarissa, MN 56440

RE: CCN: 245521
Cycle Start Date: February 26, 2025

Dear Administrator:

On February 26, 2025, a survey was completed at your facility by the Minnesota Departments of Health and Public Safety, to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

ELECTRONIC PLAN OF CORRECTION (ePoC)

Within **ten (10) calendar days** after your receipt of this notice, you must submit an acceptable ePOC for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

Central Todd County Care Center

March 5, 2025

Page 2

The state agency may, in lieu of an onsite revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417);
- Civil money penalty (42 CFR 488.430 through 488.444).
- Termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by an "F" and/or an "E" tag), i.e., the plan of correction should be directed to:

Nikki Harvey, Regional Operations Supervisor

St. Cloud A District Office

Health Regulation Division

Minnesota Department of Health

4140 Thielman Lane

Saint Cloud, Minnesota 56301-4557

Email: nikki.harvey@state.mn.us

Office: (320) 223-7318 Mobile: (320) 216-5631

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of

the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by May 26, 2025 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by August 26, 2025 (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

INFORMAL DISPUTE RESOLUTION (IDR)

In accordance with 42 CFR 488.331 and Minnesota Statute 144A.10 subd 15, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to: <https://forms.web.health.state.mn.us/form/NHDisputeResolution>

This request must be sent within the same ten calendar days you have for submitting an ePoC for the cited deficiencies. Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

A copy of the Department's informal dispute resolution policies is posted on the MDH Information Bulletin website at: https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04_8.html

INDEPENDENT INFORMAL DISPUTE RESOLUTION (INDEPENDENT IDR)

In accordance with 42 CFR § 488.431 and Minnesota Statute 144A.10 subd 16, when a CMP subject to being collected and placed in an escrow account is imposed, you have one opportunity to question cited deficiencies through an Independent IDR process. You may also contest scope and severity assessments for deficiencies which resulted in a finding of SQC or immediate jeopardy. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:
<https://forms.web.health.state.mn.us/form/NHDisputeResolution>

Central Todd County Care Center

March 5, 2025

Page 4

A facility may not use both IDR and independent IDR for the same deficiency citation(s) arising from the same survey unless the IDR process was completed prior to the imposition of the CMP. This request must be sent within ten calendar days of receipt of this offer. An incomplete Independent IDR process will not delay the effective date of any enforcement action.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Travis Z. Ahrens
State Fire Safety Supervisor
Health Care & Correctional Facilities
MN Department of Public Safety-Fire Marshal Division
445 Minnesota St., Suite 145
St. Paul, MN 55101
Email: travis.ahrens@state.mn.us
Web: www.sfm.dps.mn.gov
Cell: 1-507-308-4189

Feel free to contact me if you have questions.

Sincerely,



Kamala Fiske-Downing
Compliance Analyst | Federal Enforcement
Health Regulation Division
Minnesota Department of Health
Kamala.Fiske-Downing@state.mn.us
Office: 651-201-4112

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/19/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 02/26/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
E 000	Initial Comments On 2/24/25 - 2/26/25, a survey for compliance with §483.73, Appendix Z, Emergency Preparedness Requirements for Long Term Care Facilities was conducted during a standard recertification survey. The facility was IN compliance. The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that the facility acknowledge receipt of the electronic documents.	E 000			
F 000	INITIAL COMMENTS On 2/24/25 - 2/26/25, a standard recertification survey was conducted at your facility. Complaint investigations were also conducted. Your facility was IN compliance with the requirements of 42 CFR 483, Subpart B, Requirements for Long Term Care Facilities. The following complaint was reviewed, and found in Compliance with no deficiency issued: H55217741C (MN110546) The facility is enrolled in ePOC, therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, the facility must acknowledge receipt of the electronic documents.	F 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Electronically Signed		03/05/2025

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/25/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	INITIAL COMMENTS Fire Safety An annual Life Safety Code survey was conducted on 02/25/2025, by the Minnesota Department of Public Safety, State Fire Marshal Division. At the time of this survey, Central Todd County Care Center was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99, Health Care Facilities Code. THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE. UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION. PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO: IF PARTICIPATING IN THE E-POC PROCESS, A PAPER COPY OF THE PLAN OF CORRECTION IS NOT REQUIRED.	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Electronically Signed		03/11/2025

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/25/2025	
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	Continued From page 1 Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR By email to: FM.HC.Inspections@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A detailed description of the corrective action taken or planned to correct the deficiency. 2. Address the measures that will be put in place to ensure the deficiency does not reoccur. 3. Indicate how the facility plans to monitor future performance to ensure solutions are sustained. 4. Identify who is responsible for the corrective actions and monitoring of compliance. 5. The actual or proposed date for completion of the remedy. Central Todd County Care Center is a 1-story building without a basement. The building was constructed at 4 different times. The original building was constructed in 1976 and was determined to be of Type V(111) construction. In 1985, an addition was added to the service wing on the south side and was determined to be of Type V(111). In 1992 an activities/ physical therapy addition was added to the east end of A Wing and was determined to be of Type V(111) construction. In 2002 additions were added to west end of D Wing, to the main entrance and			K 000			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/25/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 between E and D wings dining room, all of which are Type V(111) construction. An assisted living apartment building is attached to the B wing which is separated by a 2-hour fire barrier. The north end of E wing are apartments and separated from the nursing home with a 2-hour fire barrier. The building is divided into 4 smoke zones by 2 hour fire barriers. The building is fully fire sprinkler protected and has a fire alarm system with smoke detection in the corridors and spaces open to the corridors that is monitored for automatic fire department notification. The facility has a capacity of 45 beds and had a census of 40 at the time of the survey. The requirements at 42 CFR, Subpart 483.70(a) are NOT MET as evidenced by:	K 000			
K 321 SS=D	Hazardous Areas - Enclosure CFR(s): NFPA 101 Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS.	K 321		3/10/25	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/25/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 321	Continued From page 3 19.3.2.1, 19.3.5.9 Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain hazardous storage room doors per NFPA 101 (2012 edition), Life Safety Code, sections 19.3.2.1, 19.3.2.1.3, and 8.7.1.1. These deficient findings could have an isolated impact on the residents within the facility. Findings include: On 02/25/2025 at 10:55 AM, it was revealed by observation patient rooms D14 and D16 are being used for combustible storage and did not have a door closer on the doors. An interview with the Maintenance Director and Administrator verified these deficient findings at the time of discovery.	K 321			
K 353 SS=F	Sprinkler System - Maintenance and Testing CFR(s): NFPA 101 Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are	K 353	Empty resident rooms were being used to store hallway flooring supplies during a flooring replacement project. All excess items have been removed and placed in a proper storage room with door closure. Responsibility Maintenance Supervisor	3/11/25	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/25/2025	
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	Continued From page 4 inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available. a) Date sprinkler system last checked _____ b) Who provided system test _____ c) Water system supply source _____ Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This REQUIREMENT is not met as evidenced by: Based on observation, a review of available documentation, and staff interview, the facility failed to inspect and maintain the fire sprinkler system per NFPA 101 (2012 edition), Life Safety Code, section 9.7.5, and NFPA 25 (2011 edition), Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, sections 5.1.1.2, and 5.3.2.1. These deficient findings could have a widespread impact on the residents within the facility. Findings include: 1. On 02/25/2025 between 09:00 AM and 12:30 PM, it was revealed by observation that the five-year internal pipe inspection was not completed for the riser. The last five-year inspection was completed on 05/02/2019 and the facility could not provide documentation showing that it had been completed at the time of the			K 353	5-year internal pipe inspection was scheduled and completed 3/10/2025. Prescheduled 2030 inspection with service provider. Responsibility-Maintenance supervisor.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/11/2025
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245521	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/25/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 353	Continued From page 5 survey. 2. On 02/25/2025 between 09:00 AM and 12:30 PM, it was revealed by observation that the gauge on the fire sprinkler riser was dated 05/02/2019. An interview with the Maintenance Director and Administrator verified these deficient findings at the time of discovery.	K 353			



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered

March 5, 2025

Administrator
Central Todd County Care Center
406 East Highway 71
Clarissa, MN 56440

Re: Event ID: CG5011

Dear Administrator:

The above facility survey was completed on February 26, 2025 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules. At the time of the survey, the survey team from the Minnesota Department of Health - Health Regulation Division noted no violations of these rules promulgated under Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10.

Electronically posted is the Minnesota Department of Health order form stating that no violations were noted at the time of this survey. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Please disregard the heading of the fourth column which states, "Provider's Plan of Correction." This applies to Federal deficiencies only. There is no requirement to submit a Plan of Correction.

Please feel free to call me with any questions.

Sincerely,

A handwritten signature in black ink that reads 'Kamala Fiske-Downing'.

Kamala Fiske-Downing
Compliance Analyst | Federal Enforcement
Health Regulation Division
Minnesota Department of Health
Kamala.Fiske-Downing@state.mn.us
Office: 651-201-4112

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00761	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 02/26/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE	
2 000	Initial Comments *****ATTENTION***** NH LICENSING CORRECTION ORDER In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health. Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected. You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance. INITIAL COMMENTS: On 2/24/25 - 2/26/24, a licensing survey was conducted at your facility by surveyors from the Minnesota Department of Health (MDH). Your facility was found to be IN compliance with MN State Licensure. The following complaint was reviewed during the	2 000			

Minnesota Department of Health

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Electronically Signed

TITLE

(X6) DATE

03/05/25

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00761	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 02/26/2025
NAME OF PROVIDER OR SUPPLIER CENTRAL TODD COUNTY CARE CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 406 EAST HIGHWAY 71 CLARISSA, MN 56440		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
2 000	Continued From page 1 survey with no licensing orders issued. H55217741C (MN110546) - No Licensing Orders were issued Minnesota Department of Health is documenting the State Licensing Correction Orders using Federal software. The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of state form. Although no plan of correction is required, it is required that the facility acknowledge receipt of the electronic documents.	2 000			