

DEPARTMENT OF HEALTH AND HUMAN SERVICES

CENTERS FOR MEDICARE & MEDICAID SERVICES

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: I270

Facility ID: 00731

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245378		3. NAME AND ADDRESS OF FACILITY (L3) VALLEY VIEW MANOR				4. TYPE OF ACTION: <u>7</u> (L8)	
2.STATE VENDOR OR MEDICAID NO. (L2) 425340000		(L4) 200 EAST NINTH AVENUE				1. Initial 2. Recertification	
		(L5) LAMBERTON, MN				3. Termination 4. CHOW	
		(L6) 56152				5. Validation 6. Complaint	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)				7. On-Site Visit 9. Other	
		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA				8. Full Survey After Complaint	
6. DATE OF SURVEY 12/08/2014 (L34)		02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF				FISCAL YEAR ENDING DATE: (L35)	
8. ACCREDITATION STATUS: <u> </u> (L10)		03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC				09/30	
0 Unaccredited 1 TJC		04 SNF 08 OPT/SP 12 RHC 16 HOSPICE					
2 AOA 3 Other							

11. LTC PERIOD OF CERTIFICATION From (a): To (b):		10.THE FACILITY IS CERTIFIED AS:					
		X A. In Compliance With		And/Or Approved Waivers Of The Following Requirements:			
		Program Requirements		___ 2. Technical Personnel		___ 6. Scope of Services Limit	
		Compliance Based On:		___ 3. 24 Hour RN		___ 7. Medical Director	
		___1. Acceptable POC		___ 4. 7-Day RN (Rural SNF)		___ 8. Patient Room Size	
				___ 5. Life Safety Code		___ 9. Beds/Room	
12.Total Facility Beds 50 (L18)		B. Not in Compliance with Program		Requirements and/or Applied Waivers: * Code: A		(L12)	
13.Total Certified Beds 50 (L17)							

14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS		
18 SNF	18/19 SNF	19 SNF	ICF	IID	1861 (e) (1) or 1861 (j) (1): (L15)		
	50						
(L37)	(L38)	(L39)	(L42)	(L43)			

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE		Date :	18. STATE SURVEY AGENCY APPROVAL		Date:
<u>Kerry Queen, Deputy State Fire Marshall</u>		12/16/2014	<u>Kamala Fiske-Downing, Enforcement Specialist</u>		12/18/2014
		(L19)			(L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572)	
<input checked="" type="checkbox"/> 1. Facility is Eligible to Participate				2. Ownership/Control Interest Disclosure Stmt (HCFA-1513)	
<input type="checkbox"/> 2. Facility is not Eligible				3. Both of the Above : _____	
		(L21)			

22. ORIGINAL DATE OF PARTICIPATION		23. LTC AGREEMENT BEGINNING DATE		24. LTC AGREEMENT ENDING DATE		26. TERMINATION ACTION: (L30)	
12/01/1986						<u>VOLUNTARY</u> <u>00</u> <u>INVOLUNTARY</u>	
(L24)		(L41)		(L25)		01-Merger, Closure	
						05-Fail to Meet Health/Safety	
25. LTC EXTENSION DATE:		27. ALTERNATIVE SANCTIONS				06-Fail to Meet Agreement	
(L27)		A. Suspension of Admissions:				03-Risk of Involuntary Termination	
				(L44)		<u>OTHER</u>	
		B. Rescind Suspension Date:				04-Other Reason for Withdrawal	
				(L45)		07-Provider Status Change	
						00-Active	

28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO.		30. REMARKS	
		03001			
		(L28)		(L31)	

31. RO RECEIPT OF CMS-1539		32. DETERMINATION OF APPROVAL DATE		DETERMINATION APPROVAL	
		11/25/2014			
(L32)		(L33)			



Protecting, Maintaining and Improving the Health of Minnesotans

CMS Certification Number (CCN): 245378

December 18, 2014

Ms. Dawn Giese, Administrator
Valley View Manor
200 East Ninth Avenue
Lamberton, Minnesota 56152

Dear Ms. Giese:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective December 2, 2014 the above facility is certified for:

50 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 50 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Valley View Manor
December 18, 2014
Page 2

Sincerely,

A handwritten signature in cursive script that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Minnesota Department of Health
Telephone: (651) 201-4112
Fax: (651) 215-9697

cc: Licensing and Certification File



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
December 16, 2014

Ms. Dawn Giese, Administrator
Valley View Manor
200 East Ninth Avenue
Lamberton, Minnesota 56152

RE: Project Number S5378028

Dear Ms. Giese:

On November 7, 2014, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on October 30, 2014. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On December 8, 2014 the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on October 30, 2014. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of December 2, 2014. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on October 30, 2014, effective December 2, 2014 and therefore remedies outlined in our letter to you dated November 7, 2014, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads "Kamala Fiske-Downing". The signature is written in a cursive style.

Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Minnesota Department of Health
Telephone: (651) 201-4112

Valley View Manor
December 16, 2014
Page 2

Fax: (651) 215-9697

Post-Certification Revisit Report

Public reporting for this collection of information is estimated to average 10 minutes per response, including time for reviewing instructions, searching existing data sources, gathering and maintaining data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information including suggestions for reducing the burden, to CMS, Office of Financial Management, P.O. Box 26684, Baltimore, MD 21207; and to the Office of Management and Budget, Paperwork Reduction Project (0938-0390), Washington, D.C. 20503.

(Y1) Provider / Supplier / CLIA / Identification Number 245378	(Y2) Multiple Construction A. Building 01 - MAIN BUILDING 01 B. Wing	(Y3) Date of Revisit 12/8/2014
Name of Facility VALLEY VIEW MANOR	Street Address, City, State, Zip Code 200 EAST NINTH AVENUE LAMBERTON, MN 56152	

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date	(Y4) Item	(Y5) Date
ID Prefix _____ Reg. # NFPA 101 LSC K0062	Correction Completed 12/02/2014	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed
ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed	ID Prefix _____ Reg. # _____ LSC _____	Correction Completed

Reviewed By _____ State Agency	Reviewed By PS/KFD	Date: 12/16/2014	Signature of Surveyor: 19251	Date: 12/08/2014
Reviewed By _____ CMS RO	Reviewed By	Date:	Signature of Surveyor:	Date:

Followup to Survey Completed on: 10/28/2014	Check for any Uncorrected Deficiencies. Was a Summary of Uncorrected Deficiencies (CMS-2567) Sent to the Facility? <table style="float: right;"> <tr> <td>YES</td> <td>NO</td> </tr> </table>	YES	NO
YES	NO		

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: I270
Facility ID: 00731

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245378 2.STATE VENDOR OR MEDICAID NO. (L2) 425340000	3. NAME AND ADDRESS OF FACILITY (L3) VALLEY VIEW MANOR (L4) 200 EAST NINTH AVENUE (L5) LAMBERTON, MN (L6) 56152	4. TYPE OF ACTION: <u>2</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint FISCAL YEAR ENDING DATE: (L35) 09/30															
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9) 6. DATE OF SURVEY 10/30/2014 (L34) 8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other	7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE																
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) : 12.Total Facility Beds 50 (L18) 13.Total Certified Beds 50 (L17)	10.THE FACILITY IS CERTIFIED AS: A. In Compliance With Program Requirements Compliance Based On: <u> </u> 1. Acceptable POC X B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: B* (L12) And/Or Approved Waivers Of The Following Requirements: <u> </u> 2. Technical Personnel <u> </u> 6. Scope of Services Limit <u> </u> 3. 24 Hour RN <u> </u> 7. Medical Director <u> </u> 4. 7-Day RN (Rural SNF) <u> </u> 8. Patient Room Size <u> </u> 5. Life Safety Code <u> </u> 9. Beds/Room																
14. LTC CERTIFIED BED BREAKDOWN <table style="width:100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">18 SNF</td> <td style="text-align: center;">18/19 SNF</td> <td style="text-align: center;">19 SNF</td> <td style="text-align: center;">ICF</td> <td style="text-align: center;">IID</td> </tr> <tr> <td></td> <td style="text-align: center;">50</td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;">(L37)</td> <td style="text-align: center;">(L38)</td> <td style="text-align: center;">(L39)</td> <td style="text-align: center;">(L42)</td> <td style="text-align: center;">(L43)</td> </tr> </table>	18 SNF	18/19 SNF	19 SNF	ICF	IID		50				(L37)	(L38)	(L39)	(L42)	(L43)	15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)	
18 SNF	18/19 SNF	19 SNF	ICF	IID													
	50																
(L37)	(L38)	(L39)	(L42)	(L43)													
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):																	
17. SURVEYOR SIGNATURE <u>Jodi Johnson, HFE NE II</u> Date : 11/12/2014 (L19)	18. STATE SURVEY AGENCY APPROVAL <u>Kamala Fiske-Downing, Enforcement Specialist</u> 11/14/2014 (L20)																

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY <input type="checkbox"/> 1. Facility is Eligible to Participate <input type="checkbox"/> 2. Facility is not Eligible (L21)	20. COMPLIANCE WITH CIVIL RIGHTS ACT: _____	21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____
22. ORIGINAL DATE OF PARTICIPATION 12/01/1986 (L24)	23. LTC AGREEMENT BEGINNING DATE (L41)	24. LTC AGREEMENT ENDING DATE (L25)
25. LTC EXTENSION DATE: (L27)	27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)	
28. TERMINATION DATE: (L28)	29. INTERMEDIARY/CARRIER NO. 03001 (L31)	
31. RO RECEIPT OF CMS-1539 (L32)	32. DETERMINATION OF APPROVAL DATE (L33)	
26. TERMINATION ACTION: (L30) VOLUNTARY <u>00</u> 01-Merger, Closure INVOLUNTARY 02-Dissatisfaction W/ Reimbursement 05-Fail to Meet Health/Safety 03-Risk of Involuntary Termination 06-Fail to Meet Agreement 04-Other Reason for Withdrawal OTHER 07-Provider Status Change 00-Active		
30. REMARKS DETERMINATION APPROVAL		



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
November 7, 2014

Ms. Dawn Giese, Administrator
Valley View Manor
200 East Ninth Avenue
Lamberton, Minnesota 56152

RE: Project Number S5378028

Dear Ms. Giese:

On October 30, 2014, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Kathryn Serie, Unit Supervisor
Minnesota Department of Health
1400 E. Lyon Street
Marshall, Minnesota 56258
Kathryn.serie@state.mn.us
Office: (507) 476-4233
Fax: (507) 537-7194

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by December 9, 2014, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by December 9, 2014 the following remedy will be imposed:

- Per instance civil money penalties. (42 CFR 488.430 through 488.444)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and

sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;

- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the

level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by January 30, 2015 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by April 30, 2015 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Division of Compliance Monitoring
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at:

Valley View Manor

November 7, 2014

Page 5

http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at:

<http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Patrick Sheehan, Supervisor
Health Care Fire Inspections
State Fire Marshal Division
pat.sheehan@state.mn.us
Telephone: (651) 201-7205
Fax: (651) 215-0525

Feel free to contact me if you have questions.

Sincerely,



Kamala Fiske-Downing, Program Specialist
Licensing and Certification Program
Division of Compliance Monitoring
Minnesota Department of Health
Telephone: (651) 201-4112
Fax: (651) 215-9697

Enclosure

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/06/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245378	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 10/30/2014
NAME OF PROVIDER OR SUPPLIER VALLEY VIEW MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 200 EAST NINTH AVENUE LAMBERTON, MN 56152		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	INITIAL COMMENTS The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.	F 000			
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE			TITLE	(X6) DATE	

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES


F9378025

PRINTED: 11/13/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245378	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 10/28/2014
--	---	---	---

NAME OF PROVIDER OR SUPPLIER VALLEY VIEW MANOR	STREET ADDRESS, CITY, STATE, ZIP CODE 200 EAST NINTH AVENUE LAMBERTON, MN 56152
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division, on October 28, 2014. At the time of this survey, Valley View Manor was found not to be in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) 101 Life Safety Code (LSC), Chapter 19 Existing Health Care Occupancies.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota Street, Suite 145 St. Paul, MN 55101-5145, or</p>	K 000		
-------	---	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 11/11/2014
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/13/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245378	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 10/28/2014
NAME OF PROVIDER OR SUPPLIER VALLEY VIEW MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 200 EAST NINTH AVENUE LAMBERTON, MN 56152	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>By eMail to: Marian.Whitney@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. <p>Valley View Manor was constructed as follows: The original building was constructed in 1972, is one-story, has no basement, is fully fire sprinkler protected and is of Type II(000) construction; The 1st Addition was constructed in 1976, is one-story, has no basement, is fully fire sprinkler protected and is of Type V(111) construction; The 2nd Addition was constructed in 1989, is one-story, has no basement, is fully fire sprinkler protected and is of Type II(000) construction; The 3rd Addition was constructed in 1999, is one-story, has a partial basement, is fully fire sprinkler protected and is of Type II(000) construction.</p> <p>The nursing home is separated from an assisted living facility by a 2-hour fire wall assembly, with an opening protective consisting of a labeled, 90-minute self-closing, positive latching fire door assembly.</p> <p>The facility has a fire alarm system with smoke detection at all smoke barrier doors. The 1999</p>	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/13/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245378	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 10/28/2014
NAME OF PROVIDER OR SUPPLIER VALLEY VIEW MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 200 EAST NINTH AVENUE LAMBERTON, MN 56152		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 addition has a full corridor smoke detection system. The entire system is monitored for automatic fire department notification. The facility has a capacity of 55 beds and had a census of 48 at time of the survey.	K 000			
K 062 SS=F	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD Required automatic sprinkler systems are continuously maintained in reliable operating condition and are inspected and tested periodically. 19.7.6, 4.6.12, NFPA 13, NFPA 25, 9.7.5 This STANDARD is not met as evidenced by: Based on documentation review, observation and interview with staff, the facility has failed to properly inspect and maintain the automatic sprinkler system in accordance with NFPA 101 LSC (00) section 19.7.6, 4.6.12. This deficient practice does not ensure that the fire sprinkler system is functioning properly and is fully operational in the event of a fire and could negatively affect all 48 residents, staff and visitors. Findings include: On facility tour between 12:30 PM and 3:00 PM on 10/28/2014, a review of documentation and observation, revealed the facility had several areas that the sprinkler heads were not in compliance with NFPA 13(99) and NFPA 25(98).	K 062	The preparation of the following plan of correction for this deficiency does not constitute and should not be interpreted as an admission nor an agreement by the facility of the truth of the facts alleged or conclusions set forth in the statement of the deficiencies. The plan of correction prepared for this deficiency was executed solely because provisions of state and federal law require it. Without waiving the foregoing statement, the facility states with respect to: 1. Contact made with vendor Simplex Grinnell for supplies and labor to move/remove sprinkler heads that are within 6 ft of each other and to drop down sprinkler heads that do not clear obstructions 10-30-14 2. Received quote from vendor Simplex	12/2/14	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 11/13/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245378	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 10/28/2014
NAME OF PROVIDER OR SUPPLIER VALLEY VIEW MANOR			STREET ADDRESS, CITY, STATE, ZIP CODE 200 EAST NINTH AVENUE LAMBERTON, MN 56152	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 062	Continued From page 3 1. These areas sprinkler heads were within 6 ft. of each other. a. The Bathing area b. The Conference room doorway c. The Chapel d. The Beauty shop 2. These areas sprinkler heads need to be dropped down. a. The Chapel b. The Conference room c. The Administration offices This deficient practice was verified by the Maintenance Supervisor.	K 062	Grinnell and confirmed order for work to be done 11-7-14 3. Vendor Simplex Grinnell to do required work to be in compliance with NFPA 13(99) and NFPA 25(98) The ED and Maintenance Director are responsible for teh POC	