

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: KU1N
Facility ID: 00406

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245553		3. NAME AND ADDRESS OF FACILITY (L3) PARKVIEW MANOR NURSING HOME			4. TYPE OF ACTION: <u>2</u> (L8)	
2.STATE VENDOR OR MEDICAID NO. (L2) 104740000		(L4) 308 SHERMAN AVENUE			1. Initial 3. Termination 5. Validation 7. On-Site Visit	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		(L5) ELLSWORTH, MN (L6) 56129			2. Recertification 4. CHOW 6. Complaint 9. Other	
6. DATE OF SURVEY 03/02/2017 (L34)		7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)			8. Full Survey After Complaint	
8. ACCREDITATION STATUS: <u> </u> (L10)		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA			FISCAL YEAR ENDING DATE: (L35)	
0 Unaccredited 1 TJC 2 AOA 3 Other		02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF			09/30	
11. LTC PERIOD OF CERTIFICATION		03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC				
From (a) : To (b) :		04 SNF 08 OPT/SP 12 RHC 16 HOSPICE				
12.Total Facility Beds 37 (L18)		10.THE FACILITY IS CERTIFIED AS:				
13.Total Certified Beds 37 (L17)		A. In Compliance With			And/Or Approved Waivers Of The Following Requirements: _____	
		Program Requirements _____ 2. Technical Personnel _____ 6. Scope of Services Limit				
		Compliance Based On:			_____ 3. 24 Hour RN _____ 7. Medical Director	
		_____ 1. Acceptable POC			_____ 4. 7-Day RN (Rural SNF) _____ 8. Patient Room Size	
		X B. Not in Compliance with Program			_____ 5. Life Safety Code _____ 9. Beds/Room	
		Requirements and/or Applied Waivers:			* Code: B (L12)	
14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS	
18 SNF 18/19 SNF 19 SNF ICF IID					1861 (e) (1) or 1861 (j) (1): (L15)	
37						
(L37) (L38) (L39) (L42) (L43)						

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE		Date :	18. STATE SURVEY AGENCY APPROVAL		Date:
<u>Wendy Willson, HFE NE II</u>		03/28/2017	<u>Kate JohnsTon, Program Specialist</u>		05/09/2017
		(L19)			(L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____	
_____ 1. Facility is Eligible to Participate					
_____ 2. Facility is not Eligible (L21)					
22. ORIGINAL DATE OF PARTICIPATION 03/01/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		26. TERMINATION ACTION: (L30)	
		24. LTC AGREEMENT ENDING DATE (L25)		VOLUNTARY <u>00</u> INVOLUNTARY	
				01-Merger, Closure 05-Fail to Meet Health/Safety	
				02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS		03-Risk of Involuntary Termination OTHER	
		A. Suspension of Admissions: (L44)		04-Other Reason for Withdrawal 07-Provider Status Change	
		B. Rescind Suspension Date: (L45)		00-Active	
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 03001 (L28)		30. REMARKS	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE (L33)		DETERMINATION APPROVAL	



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered

March 14, 2017

Mr. Michael Werner, Administrator
Parkview Manor Nursing Home
308 Sherman Avenue
Ellsworth, MN 56129

RE: Project Number S5553027

Dear Mr. Werner:

On March 7, 2017, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Kathryn Serie, Unit Supervisor

Health Regulation Division

Minnesota Department of Health

1400 E. Lyon Street

Marshall, Minnesota 56258

Email: Kathryn.serie@state.mn.us

Office: (507) 476-4233

Fax: (507) 344-2723

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by April 16, 2017, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by April 16, 2017 the following remedy will be imposed:

- Per instance civil money penalty. (42 CFR 488.430 through 488.444)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have

- been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by June 2, 2017 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the

identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by September 2, 2017 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Fire Safety Supervisor
Health Care Fire Inspections
Minnesota Department of Public Safety
State Fire Marshal Division
445 Minnesota Street, Suite 145
St. Paul, Minnesota 55101-5145

Parkview Manor Nursing Home

March 14, 2017

Page 6

Email: tom.linhoff@state.mn.us

Telephone: (651) 430-3012

Fax: (651) 215-0525

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in cursive script that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing

Minnesota Department of Health

Licensing and Certification Program

Program Assurance Unit

Health Regulation Division

Telephone: (651) 201-4112 Fax: (651) 215-9697

Email: Kamala.Fiske-Downing@state.mn.us

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/09/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 03/02/2017
--	---	--	---

NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>Parkview Manor Nursing Home has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.</p> <p>The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.</p>	F 000		
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 03/28/2017
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES


F5553025

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
--	---	---	---

NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division. At the time of this survey, Parkview Manor Nursing Home was found not to be in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care Occupancies.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota Street, Suite 145 St. Paul, MN 55101-5145, or</p>	K 000		
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 03/23/2017
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 By email to: Marian.Whitney@state.mn.us <mailto:Marian.Whitney@state.mn.us> and Angela.Kappenman@state.mn.us <mailto:Angela.Kappenman@state.mn.us> THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. Parkview Manor Nursing Home was constructed as follows: The original building was constructed in 1970, is one-story in height, has no basement, is fully fire sprinkler protected, and was determined to be of Type I (332) construction; The 1st Addition was constructed in 1980, is one-story in height, has no basement, and is fully fire sprinkler protected, and was determined to be of Type I (332) construction; The 2nd Addition was constructed in 1993. It consists of a Resident Room Addition and is one-story in height, has no basement, is fully fire sprinkler protected, and was determined to be of Type II (111) construction. The original 1970 building of Type I (332) construction is separated from the 1993 Addition	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 of Type II (111) construction by a 2-hour fire wall assembly, with opening protectives consisting of a factory labeled, self-closing, positive latching, 90-minute fire rated double door assembly. The 1980 Addition consists solely of an attached Generator Room, which is separated from the Nursing Home by a 2-hour fire wall, with no communicating openings. This room is accessible only from the building exterior. The facility has a fire alarm system with smoke detection located at smoke barrier doors and in spaces open to the corridors, which are monitored for automatic fire department notification. Additionally, all Resident Rooms are equipped with automatic smoke alarms. The facility has a capacity of 37 beds and had a census of 31 at time of the survey. The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by:	K 000		
K 346 SS=E	NFPA 101 Fire Alarm System - Out of Service Fire Alarm - Out of Service Where required fire alarm system is out of services for more than 4 hours in a 24-hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the fire alarm system has been returned to service. 9.6.1.6 This STANDARD is not met as evidenced by: Based on documentation review and interview, the Facility failed to provide a current and accurate Fire Alarm Out of Service Policy. The deficient practice could affect 37 out of 37	K 346	1. Downloaded the current Fire Alarm System-Out of Service policy from the MN Fire Marshal website. Updated the contact information to make it current (staff/Fire	3/23/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 346	Continued From page 3 residents. Fire Alarm - Out of Service Where required fire alarm system is out of services for more than 4 hours in a 24-hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the fire alarm system has been returned to service. 9.6.1.6 FINDINGS INCLUDE: On facility tour between 11:00 AM and 2:00 PM on 03/7/2017, documentation review revealed that the Out of Service Policy for the Fire Alarm System does not have current Staff/Fire Marshal contact information. This deficient practice was verified by the Facility Maintenance Director.	K 346	Marshal). 2. 3/16/17 3. Sam Quam, Administrator, is responsible for keeping contact information current in the policy.	
K 354 SS=E	NFPA 101 Sprinkler System - Out of Service Sprinkler System - Out of Service Where the sprinkler system is impaired, the extent and duration of the impairment has been determined, areas or buildings involved are inspected and risks are determined, recommendations are submitted to management or designated representative, and the fire department and other authorities having jurisdiction have been notified. Where the sprinkler system is out of service for more than 10 hours in a 24-hour period, the building or portion of the building affected are evacuated or an approved fire watch is provided until the sprinkler	K 354		3/23/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 354	Continued From page 4 system has been returned to service. 18.3.5.1, 19.3.5.1, 9.7.5, 15.5.2 (NFPA 25) This STANDARD is not met as evidenced by: Based on documentation review and interview, the Facility failed to provide a current and accurate Fire Sprinkler Out of Service Policy. The deficient practice could affect 37 out of 37 residents. Sprinkler System - Out of Service Where the sprinkler system is impaired, the extent and duration of the impairment has been determined, areas or buildings involved are inspected and risks are determined, recommendations are submitted to management or designated representative, and the fire department and other authorities having jurisdiction have been notified. Where the sprinkler system is out of service for more than 10 hours in a 24-hour period, the building or portion of the building affected are evacuated or an approved fire watch is provided until the sprinkler system has been returned to service. 18.3.5.1, 19.3.5.1, 9.7.5, 15.5.2 (NFPA 25) FINDINGS INCLUDE: On facility tour between 11:00 AM and 2:00 PM on 03/07/2017, documentation review revealed that the Out of Service Policy for the Fire Sprinkler System does not have current Staff/ Fire Marshal contact information and the 10 hour out of service time needs to be updated. This deficient practice was verified by the Facility Maintenance Director.	K 354	1. Downloaded the current Sprinkler System-Out of Service policy from the MN State Fire Marshal website. Updated the contact information to make it current (staff/Fire Marshal), and updated the out-of-service time from 4 hours to 10 hours. 2. 3/16/17 3. Sam Quam, Administrator, is responsible for keeping the contact information and out-of-service time current.	
K 363	NFPA 101 Corridor - Doors	K 363		3/23/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 363 SS=F	Continued From page 5 Corridor - Doors 2012 EXISTING Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas shall be substantial doors, such as those constructed of 1-3/4 inch solid-bonded core wood, or capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke compartments are only required to resist the passage of smoke. Doors shall be provided with a means suitable for keeping the door closed. There is no impediment to the closing of the doors. Clearance between bottom of door and floor covering is not exceeding 1 inch. Roller latches are prohibited by CMS regulations on corridor doors and rooms containing flammable or combustible materials. Powered doors complying with 7.2.1.9 are permissible. Hold open devices that release when the door is pushed or pulled are permitted. Nonrated protective plates of unlimited height are permitted. Dutch doors meeting 19.3.6.3.6 are permitted. Door frames shall be labeled and made of steel or other materials in compliance with 8.3, unless the smoke compartment is sprinklered. Fixed fire window assemblies are allowed per 8.3. In sprinklered compartments there are no restrictions in area or fire resistance of glass or frames in window assemblies. 19.3.6.3, 42 CFR Parts 403, 418, 460, 482, 483, and 485 Show in REMARKS details of doors such as fire protection ratings, automatics closing devices, etc. This STANDARD is not met as evidenced by: Based on observation and interview, the Facility failed to ensure doors protecting corridor openings were in operable condition. This	K 363	1. Parkview Manor will conduct an annual Fire and Smoke Door Inspection to comply with NFPA 80. The Director of	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 363	Continued From page 6 deficient practice could affect 37 of the 37 residents. Corridor - Doors 2012 EXISTING Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas shall be substantial doors, such as those constructed of 1-3/4 inch solid-bonded core wood, or capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke compartments are only required to resist the passage of smoke. Doors shall be provided with a means suitable for keeping the door closed. There is no impediment to the closing of the doors. Clearance between bottom of door and floor covering is not exceeding 1 inch. Roller latches are prohibited by CMS regulations on corridor doors and rooms containing flammable or combustible materials. Powered doors complying with 7.2.1.9 are permissible. Hold open devices that release when the door is pushed or pulled are permitted. Nonrated protective plates of unlimited height are permitted. Dutch doors meeting 19.3.6.3.6 are permitted. Door frames shall be labeled and made of steel or other materials in compliance with 8.3, unless the smoke compartment is sprinklered. Fixed fire window assemblies are allowed per 8.3. In sprinklered compartments there are no restrictions in area or fire resistance of glass or frames in window assemblies. 19.3.6.3, 42 CFR Parts 403, 418, 460, 482, 483, and 485 Show in REMARKS details of doors such as fire protection ratings, automatics closing devices, etc.	K 363	Maintenance will conduct the inspection, investigating the doors for "fire protection ratings, auto-closing device functionality, etc." The Director of Maintenance will document his inspection on a formatted spreadsheet that covers all inspection areas required in NFPA 80. Changes will be made to doors if negative findings are found during the annual inspection. 2. 3/21/17 3. Sam Quam, Administrator, is responsible for make sure the Annual Fire and Smoke Door Inspection occur and that the findings are accurate.	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 363	Continued From page 7 FINDINGS INCLUDE: On facility tour between 10:00 AM and 2:00 PM on 03/07/2017, documentation review revealed that not all the required information is being documented during the Annual Fire and Smoke Door Inspection per NFPA 80. This deficient practice was verified by the Facility Maintenance Director.	K 363		
K 711 SS=E	NFPA 101 Evacuation and Relocation Plan Evacuation and Relocation Plan There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. Employees are periodically instructed and kept informed with their duties under the plan, and a copy of the plan is readily available with telephone operator or with security. The plan addresses the basic response required of staff per 18/19.7.2.1.2 and provides for all of the fire safety plan components per 18/19.2.2. 18.7.1.1 through 18.7.1.3, 18.7.2.1.2, 18.7.2.2, 18.7.2.3, 19.7.1.1 through 19.7.1.3, 19.7.2.1.2, 19.7.2.2, 19.7.2.3 This STANDARD is not met as evidenced by: Based on documentation review and interview, the Facility failed to maintain a Evacuation and Relocation Plan according to the 2012 Life Safety Code. This deficient practice could affect 37 of the 37 residents Evacuation and Relocation Plan There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. Employees are periodically instructed and kept	K 711	1. Downloaded the "Fire Safety" and "Evacuation" plan from the MN State Fire Marshal website. The policies and procedures were customized to accommodate the specifications of Parkview Manor. In addition, NFPA LSC 2012 K-tags were downloaded, printed, and put into the Parkview Manor Safety and Fire handbook. 2. 3/21/17 3. Sam Quam, Administrator, is	3/23/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 711	Continued From page 8 informed with their duties under the plan, and a copy of the plan is readily available with telephone operator or with security. The plan addresses the basic response required of staff per 18/19.7.2.1.2 and provides for all of the fire safety plan components per 18/19.2.2, 18.7.1.1 through 18.7.1.3, 18.7.2.1.2, 18.7.2.2, 18.7.2.3, 19.7.1.1 through 19.7.1.3, 19.7.2.1.2, 19.7.2.2, 19.7.2.3 FINDINGS INCLUDE: On facility tour between 10:00 AM and 2:00 PM on 03/07/2017, documentation review revealed the Facility Fire Emergency Plan needs to be updated to include all the requirements in the 2012 Life Safety Code. (NFPA 101, 19.7.2.2)	K 711	responsible for keeping these policies and procedures accurate and in compliance with NFPA 101.	
K 918 SS=F	NFPA 101 Electrical Systems - Essential Electric System Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test	K 918		3/23/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 918	<p>Continued From page 9</p> <p>under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked and readily identifiable. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>This STANDARD is not met as evidenced by: Based on documentation review and interview, the Facility failed to provide complete written records of generator maintenance and testing. This deficient practice could affect 37 of 37 residents.</p> <p>Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36</p>	K 918	<p>1. Cummins, Inc. is contracted to complete full-service annual generator maintenance for the next 3 years. They will do their first preventative maintenance in April. In addition, the proper Emergency Generator Load Test documentation was downloaded from the MN Fire Marshal website. This worksheet has all of the requirements set forth for monthly/weekly generator tests. All paper work should be in order.</p> <p>2. 3/21/17</p> <p>3. Sam Quam, Administrator, is responsible for making sure Cummins, Inc. performs preventative annual maintenance on our generator. He will ensure the Maintenance Director is filling out proper paperwork for monthly/weekly generator testing.</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 918	<p>Continued From page 10</p> <p>months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked and readily identifiable. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>FINDINGS INCLUDE:</p> <p>On facility tour between 10:00 AM and 2:00 PM on 03/07/2017, documentation reviewed revealed:</p> <p>1.) Documentation review revealed that the results of a annual maintenance program on the generator and transfer switch could not be located.</p> <p>2.) Documentation review revealed that not all the required information is being documented during the Month Emergency Generator Load Test. The transfer time of how long it takes the emergency generator to assume power and the amount of time the generator is cooling down after the Monthly 30 Minute Load Test is not being recorded.</p>	K 918		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 03/24/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245553	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 03/07/2017
NAME OF PROVIDER OR SUPPLIER PARKVIEW MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 308 SHERMAN AVENUE ELLSWORTH, MN 56129	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 918	Continued From page 11 3.) During documentation review, it was revealed that weekly generator documentation could not be located for 2016/2017. This deficient practice was verified by the Facility Maintenance Director.	K 918		