DEPARTMENT OF HEALTH AND HUMAN SERVICES

CENTERS FOR MEDICARE & MEDICAID SERVICES

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: O2U7 PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY Facility ID: 00956 1. MEDICARE/MEDICAID PROVIDER NO. 3. NAME AND ADDRESS OF FACILITY 4. TYPE OF ACTION: 7 (L8) (L3) GOOD SAMARITAN SOCIETY - WOODLAND (L1)245488 1. Initial 2. Recertification (L4) 100 BUFFALO HILLS LANE 2.STATE VENDOR OR MEDICAID NO. 4. CHOW 3. Termination (L6) 56401 502043300 (L2)(L5) BRAINERD, MN 5. Validation 6. Complaint 7. On-Site Visit 9. Other 5. EFFECTIVE DATE CHANGE OF OWNERSHIP 7. PROVIDER/SUPPLIER CATEGORY 02 (L7)8. Full Survey After Complaint (L9) 05 HHA 13 PTIP 01 Hospital 09 ESRD 22 CLIA 04/15/2016 6. DATE OF SURVEY (L34) 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF FISCAL YEAR ENDING DATE: (L35)8. ACCREDITATION STATUS: 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC (L10) 12 RHC 16 HOSPICE 06/30 0 Unaccredited 1 TJC 04 SNF 08 OPT/SP 2 AOA 3 Other 11. LTC PERIOD OF CERTIFICATION 10.THE FACILITY IS CERTIFIED AS: X A. In Compliance With And/Or Approved Waivers Of The Following Requirements: From (a): ____ 2. Technical Personnel То (b): Program Requirements Scope of Services Limit Compliance Based On: ___ 3. 24 Hour RN 7. Medical Director 4. 7-Day RN (Rural SNF) 1. Acceptable POC 8. Patient Room Size 12. Total Facility Beds 42 (L18) ___ 5. Life Safety Code ___ 9. Beds/Room 13. Total Certified Beds 42 (L17) B. Not in Compliance with Program Requirements and/or Applied Waivers: (L12)14. LTC CERTIFIED BED BREAKDOWN 15. FACILITY MEETS 18 SNF 18/19 SNF 19 SNF ICF IID (L15)1861 (e) (1) or 1861 (j) (1): 42 (L37) (L38) (L39) (L42)(L43)16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE): 17. SURVEYOR SIGNATURE Date : 18. STATE SURVEY AGENCY APPROVAL James Anderson DSFM 05/19/2016 Mark Weath, Enforcement Specialist 03/17/2017 (L20) PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY 19. DETERMINATION OF ELIGIBILITY 20. COMPLIANCE WITH CIVIL 1. Statement of Financial Solvency (HCFA-2572) Ownership/Control Interest Disclosure Stmt (HCFA-1513) RIGHTS ACT: X 1. Facility is Eligible to Participate 3. Both of the Above: Facility is not Eligible (L21) 22. ORIGINAL DATE 23. LTC AGREEMENT 24. LTC AGREEMENT 26. TERMINATION ACTION: (L30) 00 OF PARTICIPATION BEGINNING DATE ENDING DATE **VOLUNTARY** INVOLUNTARY 07/01/1987 01-Merger, Closure 05-Fail to Meet Health/Safety 02-Dissatisfaction W/ Reimbursement 06-Fail to Meet Agreement (L24)(L41)(L25)03-Risk of Involuntary Termination 25. LTC EXTENSION DATE: 27. ALTERNATIVE SANCTIONS 04-Other Reason for Withdrawal A. Suspension of Admissions: 07-Provider Status Change (L44)00-Active (L27)B. Rescind Suspension Date: (L45)28. TERMINATION DATE: 29. INTERMEDIARY/CARRIER NO. 30. REMARKS 00140 (L28) (L31)31. RO RECEIPT OF CMS-1539 32. DETERMINATION OF APPROVAL DATE

(L33)

DETERMINATION APPROVAL

05/04/2016

(L32)



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

CMS Certification Number (CCN): 245488

May 19, 2016

Ms. Jennifer Grams, Administrator Good Samaritan Society - Woodland 100 Buffalo Hills Lane Brainerd, Minnesota 56401

Dear Ms. Grams:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective April 8, 2016 the above facility is certified for:

42 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 42 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

Mark Meath

Mark Meath, Enforcement Specialist Program Assurance Unit Licensing and Certification Program Health Regulation Division

Email: mark.meath@state.mn.us

Telephone: (651) 201-4118 Fax: (651) 215-9697



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered May 19, 2016

Ms. Jennifer Grams, Administrator Good Samaritan Society - Woodland 100 Buffalo Hills Lane Brainerd, Minnesota 56401

RE: Project Number F5488025

Dear Ms. Grams:

On March 30, 2016, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on March 23, 2016. This survey found the most serious deficiencies to be isolated deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level D), whereby corrections were required.

On April 15, 2016, the Minnesota Department of Public Safety completed a Post Certification Revisit (PCR) to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on March 23, 2016. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of April 8, 2016. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on March 23, 2016, effective April 8, 2016 and therefore remedies outlined in our letter to you dated March 30, 2016, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

Mark Meath

Mark Meath, Enforcement Specialist Program Assurance Unit Licensing and Certification Program Health Regulation Division Minnesota Department of Health

Email: mark.meath@state.mn.us

Telephone: (651) 201-4118 Fax: (651) 215-9697

		POST-0	CERTI	FICATIO)N RI	EVISIT F	REPO	RT		
	DER / SUPPLIER / CLIA /	MULTIPLE CON							DATE	OF REVISIT
IDENTIFICATION NUMBER 245488 A. Building 01 - 100 MAIN BUILDING B. Wing							Y	4/15/2	2016 _{Y3}	
NAME (OF FACILITY				STRE	ET ADDRESS, (CITY, STATE	, ZIP CODE		
GOOD	SAMARITAN SOCIETY	/ - WOODLAND)		100 B	UFFALO HILLS	LANE			
					BRAIN	NERD, MN 5640	1			
prograr correct provision	port is completed by a common to show those deficient and the date such common number and the identity report form).	encies previouslorrective action	y reported was accon	on the CMS-29 oplished. Each	567, Staten deficien	ement of Deficion cy should be fu	iencies and ully identifie	I Plan of Corre ed using either	ection, that the regul	at have been lation or LSC
ITI	EM	DATE	ITEM	1		DATE	ITEM			DATE
Υ	4	Y5	Y4			Y5	Y4			Y5
ID Prefix	X	Correction	ID Prefix			Correction	ID Prefix			Correction
Reg. #	NFPA 101	Completed	Reg. #	NFPA 101		Completed	Reg. #	NFPA 101		Completed
	1/0054	_		1/0050		_				=
LSC	K0051	04/08/2016	LSC	K0056		04/08/2016	LSC	K0154		04/08/2016
ID Prefix	X	Correction	ID Prefix			Correction	ID Prefix			Correction
Reg. #	NFPA 101	Completed	Reg. #			Completed	Reg. #			- Completed
LSC	K0155	04/08/2016	LSC			-	LSC			-
ID Prefix	×	Correction	ID Prefix			Correction	ID Prefix			Correction
						=				_
Reg. #		Completed	Reg. #			Completed	Reg. #			Completed
LSC	<u>-</u>	_	LSC			=	LSC			=
ID Prefix	X	Correction	ID Prefix			Correction	ID Prefix			Correction
Reg. #		Completed	Reg. #			Completed	Reg. #			Completed
LSC		<u> </u>	LSC			- -	LSC			_
ID Prefix	×	Correction	ID Prefix			Correction	ID Prefix			Correction
Reg. #		 Completed	Reg. #			Completed	Reg. #			Completed

FOLLOWUP TO SURVEY COMPLETED ON

REVIEWED BY

REVIEWED BY

(INITIALS)

(INITIALS)

LSC

REVIEWED BY

REVIEWED BY CMS RO

3/23/2016

STATE AGENCY

TITLE

SIGNATURE OF SURVEYOR

CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY?

LSC

DATE

DATE

LSC

YES NO

DATE

DATE

DEPARTMENT OF HEALTH AND HUMAN SERVICES

CENTERS FOR MEDICARE & MEDICAID SERVICES

ID: O2U7

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL PART 1- TO BE COMPLETED BY THE STATE SURVEY AGENCY

]	PART I -	TO BE COMPI	LETED BY T	HE STAT	TE SURVEY	AGENCY		Fac	eility ID: 00956
1. MEDICARE/MEDICAID P (L1) 245488 2.STATE VENDOR OR MED (L2) 502043300			3. NAME AND ADDRESS OF FACILITY (L3) GOOD SAMARITAN SOCIETY - WO (L4) 100 BUFFALO HILLS LANE (L5) BRAINERD, MN		OODLAND (L6) 56401		3. Termination 5. Validation		2. Recertification 4. CHOW 6. Complaint	
5. EFFECTIVE DATE CHAN (L9)	GE OF OWNER	SHIP	7. PROVIDER/SU 01 Hospital	JPPLIER CATEG	ORY 09 ESRD	<u>02</u> (L7) 13 PTIP	22 CLIA		9. Other	
	03/25/2016 JS: 1 TJC 3 Other	(L34) _ (L10)	02 SNF/NF/Dual 03 SNF/NF/Distinct 04 SNF	06 PRTF 07 X-Ray 08 OPT/SP	10 NF 11 ICF/IID 12 RHC	14 CORF 15 ASC 16 HOSPICE			EAR ENDING	DATE: (L35)
11LTC PERIOD OF CERTIF From (a): To (b): 12. Total Facility Beds 13. Total Certified Beds	42	(L18) (L17)	Compliance1. Ac X B. Not in Com	equirements e Based On: cceptable POC	gram	2. Tech 3. 24 F 4. 7-Da 5. Life	ved Waivers Of T inical Personnel Iour RN ay RN (Rural SN Safety Code B*	6. 7. F) 8.	g Requirements Scope of Servi Medical Direc Patient Room S Beds/Room	ces Limit tor
14. LTC CERTIFIED BED BR	EAKDOWN		Requirements	and/or Applied v	varvers.	* Code:		(L12)		
	19 SNF 42	19 SNF	ICF	IID		1861 (e) (1) or			(L15)	
(L37) (I	238)	(L39)	(L42)	(L43)						
16. STATE SURVEY AGENC	CY REMARKS (I	IF APPLICA	ABLE SHOW LTC CA	ANCELLATION I	DATE):					
17. SURVEYOR SIGNATUR	Е		Date :				RVEY AGENCY			Date:
Theresa Gullingrud,	HFE NEII		04/11/2016 (L19)			orcement S			05/03/2016 (L20	
	PART II -	TO BE	COMPLETED I	BY HCFA RE	GIONAI	OFFICE OF	R SINGLE S	TATE AG	ENCY	`
19. DETERMINATION OF E _X 1. Facility is Elig 2. Facility is no	gible to Participat	e (L21)		IPLIANCE WITH	I CIVIL	2. (statement of Finar Ownership/Contro Both of the Above	l Interest Disc		CFA-1513)
22. ORIGINAL DATE	23 17	ΓC AGREE!	MENT 2/	4. LTC AGREEM	MENIT	26 TERMINA	TION ACTION:		(L3	30)
OF PARTICIPATION 07/01/1987		BEGINNING		ENDING DAT		VOLUNTARY 01-Merger, Clos	_00	_	INVOLUNTA	
(L24)	(1	L41)		(L25)			on W/ Reimburse		06-Fail to Me	et Agreement
25. LTC EXTENSION DATE			VE SANCTIONS n of Admissions:	(L44)		03-Risk of Involution 04-Other Reason	untary Termination for Withdrawal	n	OTHER 07-Provider S 00-Active	Status Change
I)	.27) В	. Rescind Su	uspension Date:	(L45)						
28. TERMINATION DATE:		29	. INTERMEDIARY/	CARRIER NO.		30. REMARKS				
			00140							
	(L2	8)	-		(L31)					
31. RO RECEIPT OF CMS-15	39	32	. DETERMINATION	I OF APPROVAL	DATE					
	(L3:	2)			(L33)	DETERMIN	ATION APPF	ROVAL		



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered March 30, 2016

Ms. Jennifer Grams, Administrator Good Samaritan Society - Woodland 100 Buffalo Hills Lane Brainerd, Minnesota 56401

RE: Project Number S5488026

Dear Ms. Grams:

On March 25, 2016, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs. This survey found the most serious deficiencies in your facility to be isolated deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level D), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

<u>Opportunity to Correct</u> - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

<u>Electronic Plan of Correction</u> - when a plan of correction will be due and the information to be contained in that document;

<u>Remedies</u> - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

<u>Potential Consequences</u> - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

<u>Informal Dispute Resolution</u> - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Lyla Burkman, Unit Supervisor
Bemidji Survey Team
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health

Email: Lyla.burkman@state.mn.us

Phone: (218) 308-2104 Fax: (218) 308-2122

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by May 2, 2016, the Department of Health will impose the following remedy:

State Monitoring. (42 CFR 488.422)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;

- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

The state agency may, in lieu of a revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by June 23, 2016 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the

result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by September 23, 2016 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process Minnesota Department of Health Health Regulation Division P.O. Box 64900 St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.


Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Fire Safety Supervisor Health Care Fire Inspections Minnesota Department of Public Safety State Fire Marshal Division Email: tom.linhoff@state.mn.us Telephone: (651) 430-3012

Fax: (651) 215-0525

Feel free to contact me if you have questions related to this eNotice.

Sincerely,



Mark Meath, Enforcement Specialist Program Assurance Unit Licensing and Certification Program Health Regulation Division Minnesota Department of Health Email: mark.meath@state.mn.us Telephone: (651) 201-4118

Fax: (651) 215-9697

PRINTED: 03/30/2016 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:			IPLE CONSTRUCTION NG		(X3) DATE SURVEY COMPLETED	
	245488		B. WING _		03/25/2016	
	PROVIDER OR SUPPLIER AMARITAN SOCIETY	- WOODLAND		STREET ADDRESS, CITY, STATE, ZIP CODE 100 BUFFALO HILLS LANE BRAINERD, MN 56401	•	
(X4) ID PREFIX TAG	(EACH DEFICIENC)	ATEMENT OF DEFICIENCIES Y MUST BE PRECEDED BY FULL SC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD CROSS-REFERENCED TO THE APPRODEFICIENCY)	D BE	(X5) COMPLETION DATE
F 000	found to be in compof 42 CFR Part 483 Requirements for L The facility is enroll signature is not requage of the CMS-2 correction is require	ociety Woodland has been bliance with the requirements	F 00	,		
LABORATOR	Y DIRECTOR'S OR PROVID	DER/SUPPLIER REPRESENTATIVE'S SIGI	JATI IRF	TITLE		(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION (X3) DATE SURVEY COMPLETED AND PLAN OF CORRECTION IDENTIFICATION NUMBER: A. BUILDING 01 - 100 MAIN BUILDING 245488 B. WING 03/23/2016 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 100 BUFFALO HILLS LANE **GOOD SAMARITAN SOCIETY - WOODLAND BRAINERD, MN 56401** PROVIDER'S PLAN OF CORRECTION SUMMARY STATEMENT OF DEFICIENCIES (X5) COMPLETION ID (X4) ID (EACH CORRECTIVE ACTION SHOULD BE (EACH DEFICIENCY MUST BE PRECEDED BY FULL PREFIX PRÉFIX DATE CROSS-REFERENCED TO THE APPROPRIATE REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG DEFICIENCY) K 000 K 000 INITIAL COMMENTS **FIRE SAFETY** THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 WILL BE USED AS VERIFICATION OF COMPLIANCE. UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION. A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, At the time of this survey. Good Samaritan Society. Woodland was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR. Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC). Chapter 19 Existing Health Care. PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY **DEFICIENCIES (K TAGS) TO:** HEALTH CARE FIRE INSPECTIONS STATE FIRE MARSHAL DIVISION 445 MINNESOTA STREET, SUITE 145 ST. PAUL, MN 55101-5145, or By e-mail to both: Marian.Whitney@state.mn.us (X6) DATE LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE TITLE

Electronically Signed

04/08/2016

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

Facility ID: 00956

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - WOODLAND SUMMARY STATEMENT OF DEFICIENCES PREFIX REQUIATORY OR LSC IDENTIFYING INFORMATION) K 000 Continued From page 1 and Angela. Kappenman@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST receive the deficiency. 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. Good Samaritan Society. Woodland is a 1-story building without a basement. The building was constructed in 1982 and was determined to be of Type V(111) construction. The building is separated from the apartment building with a 2-hour fire barrier and is divided into 3 smoke zones with 1-hour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barrier and is divided into 3 smoke zones with 1-inour fire barriers. The building is fully sprinkler protected in accordance with NFPA 72 "The National Fire Alarm Code" 1999 edition. Hazardous areas have automatic fire detection that are on the fire alarm system in accordance with the Minnesots State Fire Code	STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA AND PLAN OF CORRECTION IDENTIFICATION NUMBER:		1 ' '	TIPLE CONSTRUCTION NG 01 - 100 MAIN BUILDING	COMPLETED	
GOOD SAMARITAN SOCIETY - WOODLAND (X4) ID SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST ISE PRECEDED BY FULL TAG) K 000 Continued From page 1 and Angela. Kappenman@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. Good Samaritan Society, Woodland is a 1-story building without a basement. The building was constructed in 1982 and was determined to be of Type V(111) construction. The building wish a 2-hour fire barriers. The building is fully sprinkler protected in accordance with NFPA 13 Standard for the Installation of Sprinkler Systems 1999 edition. The building has a fire alarm system with smoke detection in the corridors that is monitored for automatic fire department notification installed in accordance with NFPA 12 Fire Falarm Code* 1999 edition. Hazardous areas have automatic fire detection that are on the fire falarm System in			245488	B. WING		03/23/2016
FREFIX TAG REGULATORY OR LSC IDENTIFYING INFORMATION) REGULATORY OR LSC IDENTIFYING INFORMATION) Continued From page 1 and Angela. Kappenman@state.mn.us HEPLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency Good Samaritan Society, Woodland is a 1-story building without a basement. The building was constructed in 1982 and was determined to be of Type V(111) construction. The building with a 2-hour fire barrier and is divided into 3 smoke zones with 1-hour fire barriers. The building is fully sprinkler protected in accordance with NFPA 13 Standard for the Installation of Sprinkler Systems 1999 edition. The building has a fire alarm system with smoke detection in the corridors and spaces open to the corridors that is monitored for automatic fire department notification installed in accordance with NFPA 72 "The National Fire Alarm Code" 1999 edition. Hazardous areas have automatic fire detection that are on the fire lealarm system in					100 BUFFALO HILLS LANE	DE
and Angela.Kappenman@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency Good Samaritan Society, Woodland is a 1-story building without a basement. The building was constructed in 1982 and was determined to be of Type V(111) construction. The building is separated from the apartment building with a 2-hour fire barrier and is divided into 3 smoke zones with 1-hour fire barriers. The building is fully sprinkler protected in accordance with NFPA 13 Standard for the Installation of Sprinkler Systems 1999 edition. The building has a fire alarm system with smoke detection in the corridors and spaces open to the corridors that is monitored for automatic fire department notification installed in accordance with NFPA 72 "The National Fire Alarm Code" 1999 edition. Hazardous areas have automatic fire detection that are on the fire alarm system in	PRÉFIX	(EACH DEFICIENC	Y MUST BE PRECEDED BY FULL	PREFIX	(EACH CORRECTIVE ACTION S CROSS-REFERENCED TO THE A	SHOULD BE COMPLETION
2007 edition.	K 000	and Angela.Kappenma THE PLAN OF CO DEFICIENCY MUS FOLLOWING INFO 1. A description of to correct the defice 2. The actual, or proposed in the corporation of the cor	PRRECTION FOR EACH ST INCLUDE ALL OF THE DRMATION: what has been, or will be, done iency. roposed, completion date. or title of the person rection and monitoring to ence of the deficiency society, Woodland is a 1-story pasement. The building was 2 and was determined to be of ruction. The building is a partment building with a and is divided into 3 smoke fire barriers. y sprinkler protected in FPA 13 Standard for the haler Systems 1999 edition. fire alarm system with smoke rridors and spaces open to the onitored for automatic fire ation installed in accordance a National Fire Alarm Code" ardous areas have automatic are on the fire alarm system in	KO		

Facility ID: 00956

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

OF DEFICIENCIES OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:			COMPLET	
	245488	B. WING		03/23/2	2016
		1			
(EACH DEFICIENC	CY MUST BE PRECEDED BY FULL	ID PREFIX TAG	(EACH CORRECTIVE ACTION SHOULD	BE CO	(X5) MPLETION DATE
The facility has a consus of 40 at th	capacity of 42 beds and had a e time of the survey.	K 000			
NOT MET as evid NFPA 101 LIFE S. A fire alarm syster components approaccordance with Nand NFPA 72, Nat provide effective voluiding. Fire alar transmission path Initiation of the fire means and by any alarm, detection of Manual alarm box egress near each boxes in patient sirequired at exits if located at all nurs notification is proving signals. In critical sufficient. The fire alarm automatical the event of fire. Tactivates required records are maint 18.3.4, 19.3.4, 9.6 This STANDARD Based on observing revealed that the fire manually actuated throughout the fact NFPA 101 "The Li	enced by: AFETY CODE STANDARD is installed with systems and oved for the purpose in AFPA 70, National Electric Code ional Fire Alarm Code to varning of fire in any part of the m system wiring or other is are monitored for integrity. It is alarm system is by manual in required sprinkler system evice, or detection system. It is are provided in the path of required exit. Manual alarm deeping areas shall not be in manual alarm boxes are estations. Occupant inded by audible and visual care areas, visual alarms are estalarm system transmits the layto notify emergency forces in the fire alarm automatically control functions. System alined and readily available. It is not met as evidenced by: ation and staff interview it was facility failed to correctly install it alarm-initiating devices stility in accordance with the fe Safety Code" 2000 edition	K 051	appropriate location which did not be any manual actuated alarm prior to Fire Marshall leaving the building. 2. This issue was fixed on the day	ore block the	8/16
	PROVIDER OR SUPPLIEF SUMMARY ST (EACH DEFICIENCY REGULATORY OR Continued From p The facility has a census of 40 at th The requirement a NOT MET as evid NFPA 101 LIFE S. A fire alarm syster components appro- accordance with N and NFPA 72, Nat provide effective v building. Fire alar transmission path Initiation of the fire means and by any alarm, detection d Manual alarm box egress near each boxes in patient si required at exits if located at all nurs notification is prov signals. In critical sufficient. The fire alarm automatical the event of fire. T activates required records are maint 18.3.4, 19.3.4, 9.6 This STANDARD Based on observe revealed that the formanually actuated throughout the fact NFPA 101 "The Li (LSC) sections 19 National Fire Alari	PROVIDER OR SUPPLIER AMARITAN SOCIETY - WOODLAND SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) Continued From page 2 The facility has a capacity of 42 beds and had a census of 40 at the time of the survey. The requirement at 42 CR, Subpart 483.70(a) is NOT MET as evidenced by:	A BUILDING 245488 PROVIDER OR SUPPLIER AMARITAN SOCIETY - WOODLAND SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) Continued From page 2 The facility has a capacity of 42 beds and had a census of 40 at the time of the survey. The requirement at 42 CR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system is installed with systems and components approved for the purpose in accordance with NFPA 70, National Electric Code and NFPA 72, National Fire Alarm Code to provide effective warning of fire in any part of the building. Fire alarm system wiring or other transmission paths are monitored for integrity. Initiation of the fire alarm system is by manual means and by any required sprinkler system alarm, detection device, or detection system. Manual alarm boxes are provided in the path of egress near each required exit. Manual alarm boxes in patient sleeping areas shall not be required at exits if manual alarm boxes are located at all nurse's stations. Occupant notification is provided by audible and visual signals. In critical care areas, visual alarms are sufficient. The fire alarm system transmits the alarm automatically to notify emergency forces in the event of fire. The fire alarm automatically activates required control functions. System records are maintained and readily available. 18.3.4, 19.3.4, 9.6 This STANDARD is not met as evidenced by: Based on observation and staff interview it was revealed that the facility failed to correctly install manually actuated alarm-initiating devices throughout the facility in accordance with the NFPA 101 "The Life Safety Code" 2000 edition (LSC) sections 19.3.4.2 and 9.6.2, NFPA 72 National Fire Alarm Code (99), Sections 2-8.1	A BUILDING 01 - 100 MAIN BUILDING 245488 BROWIDER OR SUPPLIER AMARITAN SOCIETY - WOODLAND SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY WISE TER PRECEDED BY PILL REGULATORY OR LSC IDENTIFYING INFORMATION) Continued From page 2 The facility has a capacity of 42 beds and had a census of 40 at the time of the survey. Continued From page 1 The requirement at 42 CR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system is installed with systems and components approved for the purpose in accordance with NFPA 70, National Electric Code and NFPA 72, National Fire Alarm Code to provide effective warning of fire in any part of the building. Fire alarm system is by manual means and by any required sprinkler system alarm, detection device, or detection system. Manual alarm boxes are nortification is provided by audible and visual signals. In critical care areas, visual alarms are sufficient. The fire alarm system transmits the alarm automatically to notify emergency forces in the event of fire. The fire alarm automatically activates required control functions. System records are maintained and readily available. 18.3.4, 19.3.4, 9.6 This STANDARD is not met as evidenced by: Based on observation and staff interview it was revealed that the facility in accordance with the NFPA 101 "The Life Safety Code" 2000 edition (LSC) sections 19.3.4.2 and 6 s.2, NFPA 72 National Fire Alarm Code (99), Sections 2-8.1 This issue was fixed on the day survey on 3/2/3/16.	A BUILDING 01 - 100 MAIN BUILDING 245488 B. WING STREET ADDRESS, CITY, STATE, ZIP CODE 100 BUFFALO HILLS LANE BRAINERD, MIN 56401 SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION) Continued From page 2 The facility has a capacity of 42 beds and had a census of 40 at the time of the survey. The requirement at 42 CR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD A fire alarm system is installed with systems and components approved for the purpose in accordance with NFPA 70, National Electric Code and NFPA 72, National Fire Alarm Code to provide effective warning of fire in any part of the building. Fire alarm system wiring or other transmission paths are monitored for integrity. Initiation of the fire alarm system wiring or other transmission paths are monitored for integrity. Initiation of the fire alarm system is by manual means and by any required sprinkler system alarm, detection device, or detection system. Manual alarm boxes in pathent sleeping areas shall not be required at exits if manual alarm boxes are located at all nurse's stations. Occupant notification is provided by audible and visual signals. In critical care areas, visual alarms are sufficient. The fire alarm system transmits the alarm automatically to notify emergency forces in the event of fire. The fire alarm sustematically activates required control functions. System records are maintained and readily available. 1. Decoration was moved to a more appropriate location which did not block any manual actuated alarm prior to the Fire Marshall leaving the building. 1. Decoration was moved to a more appropriate location which did not block any manual actuated alarm prior to the Fire Marshall leaving the building. 2. This issue was fixed on the day of the survey on 3/23/16.

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - 100 MAIN BUILDING				COMPLETED	
		245488	B. WING			03/2	23/2016	
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - WOODLAND				10	REET ADDRESS, CITY, STATE, ZIP CODE O BUFFALO HILLS LANE RAINERD, MN 56401	1 00/20/2010		
(X4) ID PREFIX TAG	(EACH DEFICIENC	ATEMENT OF DEFICIENCIES Y MUST BE PRECEDED BY FULL LSC IDENTIFYING INFORMATION)	ID PREFI TAG		PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD CROSS-REFERENCED TO THE APPROPR DEFICIENCY)	BE	(X5) COMPLETION DATE	
	ability to initiate the emergency actions notification in the enegatively affecting an undetermined in Findings include: On facility tour betwo3/23/2016, observanually actuated in at the front entrainstantaneous according to the Maintenance Super NFPA 101 LIFE SAWhere required by facilities shall be prapproved, supervisin accordance with	lition could adversely affect the efire alarm system and delay and emergency forces event of an emergency, thus a 40 of 40 residents, as well as number of staff, and visitors. Ween 10:30 AM to 2:30 PM on vation revealed that the alarm-initiating device located ance was blocked from full and less by floor decorations. WEETY CODE STANDARD The section 19.1.6, Health care rotected throughout by an seed automatic sprinkler system section 9.7. Required sprinkler	KO		3. Larry Frasier, Environmental Ser Director. Audit completed on all oth stations was completed on 3/24/16 ensure they are not being blocked.	ner pull	4/8/16	
	systems are equipped with water flow and tamper switches which are electrically interconnected to the building fire alarm. In Type I and II construction, alternative protection measures shall be permitted to be substituted for sprinkler protection in specific areas where State or local regulations prohibit sprinklers. 19.3.5, 19.3.5.1, NPFA 13 This STANDARD is not met as evidenced by: Based on observations, the automatic sprinkler system is not installed and maintained in accordance with NFPA 13 the Standard for the Installation of Sprinkler Systems 1999 edition. The failure to maintain the sprinkler system in compliance with NFPA 13 (99) could allow system				1. a) On 3/24/16 contracted Fire a Safety Consultant who came to out facility and after reviewing all sprink hand determined we had all the hear required. A spare sprinkler head be purchased in order to keep sprinkler	ur ders on ads ox was		

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:			E CONSTRUCTION 01 - 100 MAIN BUILDING	COMPLETED	
		245488	B, WING			03/2	3/2016
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - WOODLAND				10	TREET ADDRESS, CITY, STATE, ZIP CODE 00 BUFFALO HILLS LANE RAINERD, MN 56401		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)		ID PREFI TAG		PROVIDER'S PLAN OF CORRECTIO (EACH CORRECTIVE ACTION SHOULD CROSS-REFERENCED TO THE APPROP DEFICIENCY)	BE	(X5) COMPLETION DATE
K 056	the fire protection of an emergency tresidents, as well staff, and visitors. Findings include: On facility tour bet 03/23/2016, obser deficient condition sprinkler system: 1. The current sprin the care center spares of every tyllocated throughou as being missing is sidewall head loca 210 degree uprighmechanical room heads located in the care center sprinkler head local to the corridor are located within deflector, and the the medication roof has a cabinet that sprinkler deflector. This deficient con	service causing a decrease in system capability in the event hat could affect 40 of 40 as an undetermined number of ween 10:30 AM to 2:30 PM on vations reveled the following s affecting the facility's fire are sprinkler head box located did not contain at least two pe and style of sprinkler head the facility. The heads noted included the 210 degree ated by the sprinkler riser, the at head located in the with the sprinkler riser, and the he east and west day rooms. In ring is missing from the ated in the cedar lounge. In the cedar lounge. In the sprinkler head that is located in the sprinkler head that is located in the sprinkler head that is located in the main nurses station is located within 6 inches of the dition was verified by the	K	056	heads organized to be easy to dist b) The escutcheon ring that was missing in the cedar lounge was re c) Contracted Fire and Safety Consultant and it is scheduled to n the sprinkler heads that are too clo the cabinets in cedar lounge and n room. 2. a) 3/24/16 b) 3/24/16 c) The fire sprinkler heads are scheduled to be moved by 4/20/16 3. Larry Frasier, Environmental Sc Director An audit on 3/24/16 was completed to ensure all other escurings were in place.	eplaced. nove use to ned	
K 154	Maintenance Sup- NFPA 101 LIFE S	ervisor. AFETY CODE STANDARD	K	154			4/8/16

FORM CMS-2567(02-99) Previous Versions Obsolete

Facility ID: 00956

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	' '	PLE CONSTRUCTION G 01 - 100 MAIN BUILDING	COMPLETED			
		245488	B. WING		03/2	23/2016		
	PROVIDER OR SUPPLIER			STREET ADDRESS, CITY, STATE, ZIP CODE 100 BUFFALO HILLS LANE BRAINERD, MN 56401				
(X4) ID PREFIX TAG	(EACH DEFICIENC	ATEMENT OF DEFICIENCIES Y MUST BE PRECEDED BY FULL LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTIO (EACH CORRECTIVE ACTION SHOULD CROSS-REFERENCED TO THE APPROP DEFICIENCY)	BE	(X5) COMPLETION DATE		
K 154 SS=B	Where a required out of service for n period, the authori and the building is watch system is prunprotected by the system has been in This STANDARD. Based on a record facility has failed to acceptable written be followed in the sprinkler system h for four or more hot deficient practice for early response would affect the savisitors and staff. Findings include: On facility tour bet 03/23/2016, observor available documents.	automatic sprinkler system is nore than 4 hours in a 24-hour ty having jurisdiction is notified, evacuated or an approved fire rovided for all parties left shutdown until the sprinkler eturned to service. 9.7.6.1 is not met as evidenced by: direview and staff interview, the provide a complete and policy containing procedures to event that the automatic fire as to be placed out-of-service ours in a 24 hour period. This could affect the facility's ability and notification of a fire and afety of 40 of 40 residents,	K 154	1. Correct contact information was to policy. This updated copy of our sprinkler out of the service policy we placed in our Emergency Plan bine 3/23/16. 2. Information was updated on 3/2 3. Larry Frasier, Environmental Schirector. A 6 month audit will be completed to ensure the correct information is up to date.	r fire vas ders on 23/16.			
K 155 SS=B	facility could not pi fire sprinkler syste contained current This deficient cond Maintenance Supe NFPA 101 LIFE SA Where a required service for more the	Supervisor, it was found that the rovide a complete automatic m out of service policy that contact information. dition was verified by the ervisor. AFETY CODE STANDARD fire alarm system is out of nan 4 hours in a 24-hour period, g jurisdiction is notified, and the ted or an approved fire watch is	K 15	5		4/8/16		

Event ID: O2U721

PRINTED: 04/11/2016 FORM APPROVED OMB NO. 0938-0391

		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	l ` ′	TIPLE CONSTRUCTION NG 01 - 100 Main Building		E SURVEY PLETED
		245488	B. WING		03/	23/2016
NAME OF PROVIDER OR SUPPLIER GOOD SAMARITAN SOCIETY - WOODLAND				STREET ADDRESS, CITY, STATE, ZIP CODE 100 BUFFALO HILLS LANE BRAINERD, MN 56401		
(X4) ID PREFIX TAG	(EACH DEFICIENC)	ATEMENT OF DEFICIENCIES Y MUST BE PRECEDED BY FULL SC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECT ((EACH CORRECTIVE ACTION SHOU CROSS-REFERENCED TO THE APPRO DEFICIENCY)	LD BE	(X5) COMPLETION DATE
K 155	shutdown until the returned to service. This STANDARD is Based on a record facility has failed to acceptable written be followed in the ealarm system has to four or more hours deficient practice of for early response awould affect the savisitors and staff. Findings include: On facility tour betwo 3/23/2016, observor available documenthe Maintenance Spacility could not proupdated automatic service policy that conformation.	ties left unprotected by the fire alarm system has been 9.6.1.8 s not met as evidenced by: I review and staff interview, the provide a complete and policy containing procedures to event that the automatic fire o be placed out-of-service for in a 24 hour period. This ould affect the facility's ability and notification of a fire and fety of all 40 of 40 residents, ween 10:30 AM to 2:30 PM on vations made during a review entation and an interview with upervisor, it was found that the ovide an complete and fire alarm system out of contained current contact	K 1	1. Correct contact information vadded to policy. This updated cofire sprinkler out of service policy placed into our Emergency Plan 2. Information was updated on 3 3. Larry Frasier, Environmental Director. A 6 month audit will be completed to ensure the correct information is up to date.	py of our was binders. 3/23/16. Services	

Facility ID: 00956



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered March 30, 2016

Ms.. Jennifer Grams, Administrator Good Samaritan Society - Woodland 100 Buffalo Hills Lane Brainerd, Minnesota 56401

Re: Enclosed State Nursing Home Licensing Orders - Project Number S5488026

Dear Ms.. Grams:

The above facility was surveyed on March 22, 2016 through March 25, 2016 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules. At the time of the survey, the survey team from the Minnesota Department of Health, Health Regulation Division, noted one or more violations of these rules that are issued in accordance with Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a civil fine for each deficiency not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.

To assist in complying with the correction order(s), a "suggested method of correction" has been added. This provision is being suggested as one method that you can follow to correct the cited deficiency. Please remember that this provision is <u>only a suggestion</u> and you are not required to follow it. Failure to follow the suggested method will not result in the issuance of a penalty assessment. You are reminded, however, that regardless of the method used, correction of the deficiency within the established time frame is required. The "suggested method of correction" is for your information and assistance only.

You have agreed to participate in the electronic receipt of State licensure orders consistent with the Minnesota Department of Health Informational Bulletin 14-01, available at http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm. The State licensing orders are delineated on the attached Minnesota Department of Health orders being submitted to you electronically. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Tag numbers have been assigned to Minnesota state statutes/rules for Nursing Homes.

The assigned tag number appears in the far left column entitled "ID Prefix Tag." The state statute/rule number and the corresponding text of the state statute/rule out of compliance is listed in the "Summary Statement of Deficiencies" column and replaces the "To Comply" portion of the correction

order. This column also includes the findings that are in violation of the state statute after the statement, "This Rule is not met as evidenced by." Following the surveyors findings are the Suggested Method of Correction and the Time Period For Correction.

PLEASE DISREGARD THE HEADING OF THE FOURTH COLUMN WHICH STATES, "PROVIDER'S PLAN OF CORRECTION." THIS APPLIES TO FEDERAL DEFICIENCIES ONLY. THIS WILL APPEAR ON EACH PAGE.

THERE IS NO REQUIREMENT TO SUBMIT A PLAN OF CORRECTION FOR VIOLATIONS OF MINNESOTA STATE STATUTES/RULES.

Although no plan of correction is necessary for State Statutes/Rules, please enter the word "corrected" in the box available for text. You must then indicate in the electronic State licensure process, under the heading completion date, the date your orders will be corrected prior to electronically submitting to the Minnesota Department of Health. We urge you to review these orders carefully, item by item, and if you find that any of the orders are not in accordance with your understanding at the time of the exit conference following the survey, you should immediately contact Lyla Burkman at (218) 308-2104 or email: lyla.burkman@state.mn.us.

You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.

Please note it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

Mark Meath

Mark Meath, Enforcement Specialist Program Assurance Unit Licensing and Certification Program Health Regulation Division Minnesota Department of Health Email: mark.meath@state.mn.us Telephone: (651) 201-4118

Fax: (651) 215-9697

PRINTED: 03/30/2016 FORM APPROVED Minnesota Department of Health STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION (X3) DATE SURVEY AND PLAN OF CORRECTION **IDENTIFICATION NUMBER:** COMPLETED A. BUILDING: ___ B. WING 00956 03/25/2016 NAME OF PROVIDER OR SUPPLIER STREET ADDRESS, CITY, STATE, ZIP CODE 100 BUFFALO HILLS LANE **GOOD SAMARITAN SOCIETY - WOODLAND BRAINERD, MN 56401** SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION (X4) ID (X5) COMPLETE (EACH DEFICIENCY MUST BE PRECEDED BY FULL (EACH CORRECTIVE ACTION SHOULD BE PRÉFIX PREFIX DATE REGULATORY OR LSC IDENTIFYING INFORMATION) CROSS-REFERENCED TO THE APPROPRIATE TAG TAG DEFICIENCY) 2 000 Initial Comments 2 000 *****ATTENTION***** NH LICENSING CORRECTION ORDER In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health. Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected. You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.

Minnesota Department of Health

INITIAL COMMENTS:

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that the facility acknowledge receipt of the electronic documents.

TITLE (X6) DATE