



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
December 31, 2021

CMS Certification Number (CCN): 245127

Administrator
Mille Lacs Health System
200 North Elm Street
Onamia, MN 56359

Dear Administrator:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective November 30, 2021 the above facility is certified for:

57 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 57 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status. If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and/or Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink that reads 'Kamala Fiske-Downing'.

Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: (651) 201-4112 Fax: (651) 215-9697
Email: Kamala.Fiske-Downing@state.mn.us



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
December 31, 2021

Administrator
Mille Lacs Health System
200 North Elm Street
Onamia, MN 56359

RE: CCN: 245127
Cycle Start Date: September 9, 2021

Dear Administrator:

On November 24, 2021, we notified you a remedy was imposed. On November 23rd and November 30, 2021 the Minnesota Department(s) of Health and Public Safety completed a revisit to verify that your facility had achieved and maintained compliance. We have determined that your facility has achieved substantial compliance as of November 30, 2021.

As authorized by CMS the remedy of:

- Mandatory denial of payment for new Medicare and Medicaid admissions effective December 9, 2021 Deny did not go into effect. (42 CFR 488.417 (b))

In our letter of November 24, 2021, in accordance with Federal law, as specified in the Act at § 1819(f)(2)(B)(iii)(I)(b) and § 1919(f)(2)(B)(iii)(I)(b), we notified you that your facility was prohibited from conducting a Nursing Aide Training and/or Competency Evaluation Program (NATCEP) for two years from December 9, 2021 due to denial of payment for new admissions. Since your facility attained substantial compliance on November 30, 2021, the original triggering remedy, denial of payment for new admissions, did not go into effect. Therefore, the NATCEP prohibition is rescinded. However, this does not apply to or affect any previously imposed NATCEP loss.

The CMS Region V Office may notify you of their determination regarding any imposed remedies.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads 'Kamala Fiske-Downing'.

Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program

Mille Lacs Health System

December 31, 2021

Page 2

Program Assurance Unit

Health Regulation Division

Telephone: (651) 201-4112 Fax: (651) 215-9697

Email: Kamala.Fiske-Downing@state.mn.us

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: QH2Q
Facility ID: 00374

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245127
2. STATE VENDOR OR MEDICAID NO. (L2) 190247401
3. NAME AND ADDRESS OF FACILITY (L3) MILLE LACS HEALTH SYSTEM
(L4) 200 NORTH ELM STREET (L5) ONAMIA, MN (L6) 56359
4. TYPE OF ACTION: 2 (L8)
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)
6. DATE OF SURVEY 09/09/2021 (L34)
7. PROVIDER/SUPPLIER CATEGORY 02 (L7)
8. ACCREDITATION STATUS: (L10)
10. THE FACILITY IS CERTIFIED AS:
11. LTC PERIOD OF CERTIFICATION
12. Total Facility Beds 57 (L18)
13. Total Certified Beds 57 (L17)
14. LTC CERTIFIED BED BREAKDOWN
15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):
17. SURVEYOR SIGNATURE Austin Fry, HFE NE II Date: 10/26/2021 (L19)
18. STATE SURVEY AGENCY APPROVAL Kamala Fiske-Downing, Enforcement Specialist Date: 11/01/2021 (L20)

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY
20. COMPLIANCE WITH CIVIL RIGHTS ACT:
21. 1. Statement of Financial Solvency (HCFA-2572)
2. Ownership/Control Interest Disclosure Stmt (HCFA-1513)
3. Both of the Above :
22. ORIGINAL DATE OF PARTICIPATION 03/20/1967 (L24)
23. LTC AGREEMENT BEGINNING DATE (L41)
24. LTC AGREEMENT ENDING DATE (L25)
26. TERMINATION ACTION: 00 (L30)
27. ALTERNATIVE SANCTIONS
28. TERMINATION DATE: (L28)
29. INTERMEDIARY/CARRIER NO. 00131 (L31)
30. REMARKS
31. RO RECEIPT OF CMS-1539 (L32)
32. DETERMINATION OF APPROVAL DATE (L33)
DETERMINATION APPROVAL



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
September 30, 2021

Administrator
Mille Lacs Health System
200 North Elm Street
Onamia, MN 56359

RE: CCN: 245127
Cycle Start Date: September 9, 2021

Dear Administrator:

On September 9, 2021, a survey was completed at your facility by the Minnesota Departments of Health and Public Safety, to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

ELECTRONIC PLAN OF CORRECTION (ePoC)

Within **ten (10) calendar days** after your receipt of this notice, you must submit an acceptable ePOC for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

The state agency may, in lieu of an onsite revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417);
- Civil money penalty (42 CFR 488.430 through 488.444).
- Termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by an "F" tag) and emergency preparedness deficiencies (those preceded by an "E" tag), i.e., the plan of correction should be directed to:

Karen Aldinger, Unit Supervisor
St. Cloud A District Office
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
3333 Division Street, Suite 212
Saint Cloud, Minnesota 56301-4557
Email: karen.aldinger@state.mn.us
Office: (651) 201-3794 Mobile: (320) 249-2805

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of

the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by December 9, 2021 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by March 9, 2022 (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

INFORMAL DISPUTE RESOLUTION (IDR) / INDEPENDENT INFORMAL DISPUTE RESOLUTION (IIDR)

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: https://mdhprovidercontent.web.health.state.mn.us/lrc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at:

https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04_8.html

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

William Abderhalden, Fire Safety Supervisor
Deputy State Fire Marshal
Health Care/Corrections Supervisor – Interim
Minnesota Department of Public Safety
445 Minnesota Street, Suite 145
St. Paul, MN 55101-5145
Cell: (507) 361-6204
Email: william.abderhalden@state.mn.us
Fax: (651) 215-0525

Feel free to contact me if you have questions.

Sincerely,



Joanne Simon, Enforcement Specialist
Minnesota Department of Health
Program Assurance Unit
Health Regulation Division
Telephone: 651-201-4161 Fax: 651-215-9697
Email: joanne.simon@state.mn.us

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 09/09/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments On 9/7/21 to 9/9/21, a survey for compliance with Appendix Z, Emergency Preparedness Requirements, §483.73(b)(6) was conducted during a standard recertification survey. The facility was NOT in compliance. The facility's plan of correction (POC) will serve as your allegation of compliance upon the Department's acceptance. Because you are enrolled in ePOC, your signature is not required at the bottom of the first page of the CMS-2567 form. Upon receipt of an acceptable electronic POC, an onsite revisit of your facility may be conducted to validate substantial compliance with the regulation has been attained.	E 000			
E 041 SS=C	Hospital CAH and LTC Emergency Power CFR(s): 483.73(e) §482.15(e) Condition for Participation: (e) Emergency and standby power systems. The hospital must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section and in the policies and procedures plan set forth in paragraphs (b)(1)(i) and (ii) of this section. §483.73(e), §485.625(e) (e) Emergency and standby power systems. The [LTC facility and the CAH] must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section. §482.15(e)(1), §483.73(e)(1), §485.625(e)(1) Emergency generator location. The generator	E 041		10/5/21	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

10/05/2021

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 09/09/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 041	<p>Continued From page 1</p> <p>must be located in accordance with the location requirements found in the Health Care Facilities Code (NFPA 99 and Tentative Interim Amendments TIA 12-2, TIA 12-3, TIA 12-4, TIA 12-5, and TIA 12-6), Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12-1, TIA 12-2, TIA 12-3, and TIA 12-4), and NFPA 110, when a new structure is built or when an existing structure or building is renovated.</p> <p>482.15(e)(2), §483.73(e)(2), §485.625(e)(2) Emergency generator inspection and testing. The [hospital, CAH and LTC facility] must implement the emergency power system inspection, testing, and [maintenance] requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code.</p> <p>482.15(e)(3), §483.73(e)(3), §485.625(e)(3) Emergency generator fuel. [Hospitals, CAHs and LTC facilities] that maintain an onsite fuel source to power emergency generators must have a plan for how it will keep emergency power systems operational during the emergency, unless it evacuates.</p> <p>*[For hospitals at §482.15(h), LTC at §483.73(g), and CAHs §485.625(g):] The standards incorporated by reference in this section are approved for incorporation by reference by the Director of the Office of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. You may obtain the material from the sources listed below. You may inspect a copy at the CMS Information Resource Center, 7500 Security Boulevard, Baltimore, MD or at the National Archives and Records Administration (NARA). For information on the</p>	E 041			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 09/09/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 041	<p>Continued From page 2</p> <p>availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html.</p> <p>If any changes in this edition of the Code are incorporated by reference, CMS will publish a document in the Federal Register to announce the changes.</p> <p>(1) National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169, www.nfpa.org, 1.617.770.3000.</p> <p>(i) NFPA 99, Health Care Facilities Code, 2012 edition, issued August 11, 2011.</p> <p>(ii) Technical interim amendment (TIA) 12-2 to NFPA 99, issued August 11, 2011.</p> <p>(iii) TIA 12-3 to NFPA 99, issued August 9, 2012.</p> <p>(iv) TIA 12-4 to NFPA 99, issued March 7, 2013.</p> <p>(v) TIA 12-5 to NFPA 99, issued August 1, 2013.</p> <p>(vi) TIA 12-6 to NFPA 99, issued March 3, 2014.</p> <p>(vii) NFPA 101, Life Safety Code, 2012 edition, issued August 11, 2011.</p> <p>(viii) TIA 12-1 to NFPA 101, issued August 11, 2011.</p> <p>(ix) TIA 12-2 to NFPA 101, issued October 30, 2012.</p> <p>(x) TIA 12-3 to NFPA 101, issued October 22, 2013.</p> <p>(xi) TIA 12-4 to NFPA 101, issued October 22, 2013.</p> <p>(xiii) NFPA 110, Standard for Emergency and Standby Power Systems, 2010 edition, including TIAs to chapter 7, issued August 6, 2009..</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on interview and document review, the facility failed to test and inspect the generator per 2012 edition of the Life Safety Code NFPA 101 section 9.1.3.1 and NFPA 99 (2012 edition),</p>	E 041	E041 Hospital CAH and LTC Emergency Power. Acknowledge.		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 09/09/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 041	Continued From page 3 Health Care Facilities Code, sections 6.4.4.1.1.4, and NFPA 110 the Standard for Emergency and Standby Power Systems, section 8.4..1 and 8.4.2.1. This had potential to affect all residents residing in the facility at the time of the survey. Findings include: 1) On 09/08/2021 between 09:00 AM to 02:00 PM, it was revealed that a monthly for July 2021 was not completed on the generator. 2) On 09/08/2021 between 09:00 AM to 02:00 PM, it was revealed that weekly generator inspections were not completed between 05/02/2021 to 05/15/2021. This deficient conditions was verified by the Facilities Manager and Facilities Supervisor.	E 041			
F 000	INITIAL COMMENTS On 9/7/21 to 9/9/21, a standard recertification survey was completed at this facility by surveyors from the Minnesota Department of Health (MDH). In addition, multiple complaint investigations were completed at the time of the survey. Mille Lacs Health System was found in compliance with 42 CFR Part 483, Requirements for Long Term Care Facilities. The following complaints were found to be unsubstantiated: H5127020C (MN76074) H5127021C (MN76192) H5127022C (MN76270) The facility is enrolled in ePOC and therefore a	F 000			

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/08/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED C 09/09/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	Continued From page 4 signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that the facility acknowledge receipt of the electronic documents.	F 000			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>An annual Life Safety Code survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division. At the time of this survey, Mille Lacs Health Center was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99, Health Care Facilities Code.</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>IF PARTICIPATING IN THE E-POC PROCESS, A PAPER COPY OF THE PLAN OF CORRECTION IS NOT REQUIRED.</p> <p>Healthcare Fire Inspections</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

10/05/2021

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1 State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR</p> <p>By email to: FM.HC.Inspections@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A detailed description of the corrective action taken or planned to correct the deficiency. 2. Address the measures that will be put in place to ensure the deficiency does not reoccur. 3. Indicate how the facility plans to monitor future performance to ensure solutions are sustained. 4. Identify who is responsible for the corrective actions and monitoring of compliance. 5. The actual or proposed date for completion of the remedy. <p>Inspected as one building: Mille Lacs Health Center is a 1-story building with no basement. The original building was constructed in 1961 with an addition constructed in 1971. The 1961 building is of type II(111) construction and the 1971 building is type II(111) construction. Therefore, the nursing home was inspected as one building. From 2002-2004 the facility under went a complete renovation. A hospital, properly separated, is connected to the nursing home.</p>	K 000			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 The building is fully sprinkler protected. The facility has a complete fire alarm system with smoke detection in the corridors and spaces open to the corridor, that is monitored for automatic fire department notification. The facility has a capacity of 57 beds and had a census of 36 at the time of the survey.	K 000			
K 345 SS=F	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: Fire Alarm System - Testing and Maintenance CFR(s): NFPA 101 Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 This REQUIREMENT is not met as evidenced by: Based on a review of the available documentation and staff interview, the facility failed to inspect the fire alarm system as required by NFPA 101 (2012 edition), Life Safety Code, section 9.6.1.5 and NFPA 72 (2010 edition), The National Fire Alarm, and Signaling Code, section 14.3.1. This deficient condition could have a widespread impact on the residents within the facility. Findings include: On 09/08/2021, between 9:00 AM to 2:00 PM, it	K 345	K345: Fire Alarm System Testing and Maintenance: Annual fire alarm system contract has been amended to include semiannual fire alarm inspection. The inspection will be completed by November 30, 2021. Facilities Manager will be responsible for ensuring semiannual inspections are completed.	11/30/21	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 345	Continued From page 3 was revealed the facility did not perform a semi-annual inspection of the fire alarm system as required.	K 345			
K 712 SS=F	<p>This deficient condition was verified by the Facilities Manager and Facilities Supervisor.</p> <p>Fire Drills CFR(s): NFPA 101</p> <p>Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7 This REQUIREMENT is not met as evidenced by: Based on a review of the available documentation and staff interview, the facility failed to conduct fire drills at least quarterly on each shift under varied conditions as required by the NFPA 101 (2012 edition), Life Safety Code, sections 19.7.1.4 through 19.7.1.7. These deficient conditions could have a widespread impact on the residents within the facility.</p> <p>Findings include:</p> <p>On 09/08/2021 between 9:00 AM to 2:00 PM, it was revealed the facility did not perform the following fire drills and DACT testing:</p>	K 712	<p>K712 Fire Drills: Fire drill outlook calendar appointments have been modified to ensure these are completed in accordance with referenced LSC sections on 10/1/2021. The appointments have been placed on both the Facilities Manager and Facilities Supervisor calendars. In addition, drill timing has been adjusted so there is a minimum of 60 minutes between drills from previous quarter. Transmission reports will be requested upon completion of the fire drills. Fire drills are reported to both the Disaster and Safety Committees. The Facilities Manager will be responsible for</p>	10/1/21	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 712	Continued From page 4 1) Fire drills were not performed for the following timeframes. -All of the First Quarter of 2021 -Second shift of the Second Quarter of 2021 -First and Second Shift of the Third Quarter of 2021 -Second and Third Shift of the Fourth Quarter of 2020 2) Fire drill reports did not document the integrity of the alarm transmission 8 of 12 months. 3) Drill times did not vary when drills were completed in the nursing home.	K 712	ensure fire drills are completed.		
K 761 SS=F	These deficient conditions were verified by the Facilities Manager and Facilities Supervisor. Maintenance, Inspection & Testing - Doors CFR(s): NFPA 101 Maintenance, Inspection & Testing - Doors Fire doors assemblies are inspected and tested annually in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives. Non-rated doors, including corridor doors to patient rooms and smoke barrier doors, are routinely inspected as part of the facility maintenance program. Individuals performing the door inspections and testing possess knowledge, training or experience that demonstrates ability. Written records of inspection and testing are maintained and are available for review. 19.7.6, 8.3.3.1 (LSC) 5.2, 5.2.3 (2010 NFPA 80) This REQUIREMENT is not met as evidenced by: Based on a review of the available	K 761	K761 Maintenance, Inspection &	9/8/21	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 761	Continued From page 5 documentation and staff interview, the facility failed to conduct inspections of all fire-rated doors assemblies as required by NFPA 101 (2012 edition), Life Safety Code, sections 7.2.1.15.2 & 7.2.1.15.4 and NFPA 80 (2010 edition), Standard for Fire Doors and Other Opening Protectives section 5.2.4.2. This deficient condition could have a widespread impact on the residents within the facility. Findings include: On 09/08/2021, between 9:00 AM to 2:00 PM, it was revealed that the facility's door inspection could not be located at the time of the survey. This deficient condition was verified by the Facilities Manager and Facilities Supervisor.	K 761	Testing-Doors: Maintenance, Inspection and Testing of fire doors was reviewed with maintenance staff. Fire door inspections were completed in July 2021. Staff have been trained on the requirement to complete annual fire door inspections within 365 days of the previous year's inspection. The Facilities Manager will ensure fire doors inspections are completed at the required interval.		
K 901 SS=F	Fundamentals - Building System Categories CFR(s): NFPA 101 Fundamentals - Building System Categories Building systems are designed to meet Category 1 through 4 requirements as detailed in NFPA 99. Categories are determined by a formal and documented risk assessment procedure performed by qualified personnel. Chapter 4 (NFPA 99) This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to conduct a risk assessment of the building's fundamental systems of category 1 through 4 requirements as	K 901	K901 Fundamentals-Building System Categories: NFPA 99 risk assessment were completed on 9/30/2021. A recurring outlook appointment has been placed on	9/30/21	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 901	Continued From page 6 detailed in NFPA 99 (2012 Edition), Health Care Facilities Code Chapter 4 . This deficient condition could have a widespread impact on the residents within the facility. Findings include: On 09/08/2021 between 09:00 AM to 2:00 PM, it was revealed the required risk assessment was not completed in its entirety per NFPA 99. This deficient condition was verified by the Facilities Manager and Facilities Supervisor.	K 901	Facilities Manager and Facilities Supervisor calendars to ensure these are completed annually. The Facilities Manager will be responsible for ensuring these are completed.		
K 914 SS=F	Electrical Systems - Maintenance and Testing CFR(s): NFPA 101 Electrical Systems - Maintenance and Testing Hospital-grade receptacles at patient bed locations and where deep sedation or general anesthesia is administered, are tested after initial installation, replacement or servicing. Additional testing is performed at intervals defined by documented performance data. Receptacles not listed as hospital-grade at these locations are tested at intervals not exceeding 12 months. Line isolation monitors (LIM), if installed, are tested at intervals of less than or equal to 1 month by actuating the LIM test switch per 6.3.2.6.3.6, which activates both visual and audible alarm. For LIM circuits with automated self-testing, this manual test is performed at intervals less than or equal to 12 months. LIM circuits are tested per 6.3.3.2 after any repair or renovation to the electric distribution system. Records are maintained of required tests and associated repairs or modifications, containing date, room or area tested, and results. 6.3.4 (NFPA 99)	K 914		10/31/21	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 914	Continued From page 7 This REQUIREMENT is not met as evidenced by: Based on a review of the available documentation and staff interview, the facility failed to conduct the maintenance of the electrical system in accordance with NFPA 99 (2012 edition), Health Care Facilities Code, section 6.3.3.2 and 6.3.4.1.3. This deficient condition could have a widespread impact on the residents within the facility. Findings include: On 09/08/2021 between 09:00 AM to 2:00 PM, it was revealed the receptacle inspection was last completed in 2020, and the repairs could not be verified or that the receptacles were re-inspected after repairs were made. The facility does have hospital-grade receptacles. This deficient condition was verified by the Facilities Manager and Facilities Supervisor.	K 914	K914 Electrical Systems Maintenance & Testing: Maintenance staff have begun annual inspection as of 10/1/21, and expect to complete these inspections by 10/31/21. The recurring work request will be updated with the required completion date for 2022 upon completion of these inspections. The Facilities Manager will be responsible for ensuring completion of these inspections.		
K 918 SS=F	Electrical Systems - Essential Electric System CFR(s): NFPA 101 Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40	K 918		10/4/21	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	<p>Continued From page 8</p> <p>day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked, readily identifiable, and separate from normal power circuits. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations.</p> <p>6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on a review of available documentation and staff interview, the facility failed to test and inspect the generator per NFPA 101 (2012 edition, Life Safety Code, section 9.1.3.1 and NFPA 99 (2012 edition), Health Care Facilities Code, sections 6.4.4.1.1.4, and NFPA 110 (2010 edition), the Standard for Emergency and Standby Power Systems, section 8.4..1 and 8.4.2.1. This deficient condition could have a widespread impact on the residents within the facility.</p> <p>Findings include:</p> <p>1) On 09/08/2021, between 9:00 AM to 2:00 PM, it was revealed that a monthly run test for July</p>	K 918	<p>K918 Electrical Systems-Essential Electric System Maintenance and Testing: Maintenance staff were trained on 10/4/2021 on weekly and monthly generator check requirements. The weekly recurring work request has been updated to include the timing requirements. The Facilities Manager or Facilities Supervisor will review and initial generator monthly and weekly logs monthly to ensure these are completed.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 10/26/2021
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245127	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/08/2021
NAME OF PROVIDER OR SUPPLIER MILLE LACS HEALTH SYSTEM			STREET ADDRESS, CITY, STATE, ZIP CODE 200 NORTH ELM STREET ONAMIA, MN 56359		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	Continued From page 9 2021 was not completed on the generator. 2) On 09/08/2021, between 9:00 AM to 2:00 PM, it was revealed that weekly generator inspections were not completed between 05/02/2021 to 05/15/2021. This deficient condition was verified by the Facilities Manager and Facilities Supervisor.	K 918			