





PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

CMS Certification Number (CCN): 245556

March 3, 2016

Mr. Blake Boche, Administrator  
Presbyterian Homes Of Bloomington  
9889 Penn Avenue South  
Bloomington, Minnesota 55431

Dear Mr. Boche:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program the Minnesota Department of Human Services that your facility is recertified in the Medicaid program.

Effective January 26, 2016 the above facility is certified for:

98 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 98 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath".

Mark Meath, Enforcement Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
Email: mark.meath@state.mn.us  
Telephone: (651) 201-4118 Fax: (651) 215-9697



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered

March 3, 2016

Mr. Blake Boche, Administrator  
Presbyterian Homes Of Bloomington  
9889 Penn Avenue South  
Bloomington, Minnesota 55431

RE: Project Number F5556025

Dear Mr. Boche:

On January 23, 2016, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on January 5, 2016. This survey found the most serious deficiencies to be a pattern of deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level E), whereby corrections were required.

On March 2, 2016 the Minnesota Department of Public Safety completed a Post Certification Revisit (PCR) to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on January 5, 2016. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of January 26, 2016. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on January 5, 2016, effective January 26, 2016 and therefore remedies outlined in our letter to you dated January 23, 2016, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath".

Mark Meath, Enforcement Specialist  
Program Assurance Unit  
Licensing and Certification Program  
Health Regulation Division  
Minnesota Department of Health  
Email: mark.meath@state.mn.us  
Telephone: (651) 201-4118 Fax: (651) 215-9697

## POST-CERTIFICATION REVISIT REPORT

PROVIDER / SUPPLIER / CLIA / IDENTIFICATION NUMBER 245556	Y1	MULTIPLE CONSTRUCTION A. Building 1N - NEW BUILDING B. Wing	Y2	DATE OF REVISIT 3/2/2016	Y3
NAME OF FACILITY PRESBYTERIAN HOMES OF BLOOMINGTON			STREET ADDRESS, CITY, STATE, ZIP CODE 9889 PENN AVENUE SOUTH BLOOMINGTON, MN 55431		

This report is completed by a qualified State surveyor for the Medicare, Medicaid and/or Clinical Laboratory Improvement Amendments program, to show those deficiencies previously reported on the CMS-2567, Statement of Deficiencies and Plan of Correction, that have been corrected and the date such corrective action was accomplished. Each deficiency should be fully identified using either the regulation or LSC provision number and the identification prefix code previously shown on the CMS-2567 (prefix codes shown to the left of each requirement on the survey report form).

ITEM Y4	DATE Y5	ITEM Y4	DATE Y5	ITEM Y4	DATE Y5
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # NFPA 101	Completed	Reg. # NFPA 101	Completed	Reg. # _____	Completed
LSC K0050	01/26/2016	LSC K0056	01/22/2016	LSC _____	_____
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____	_____	LSC _____	_____	LSC _____	_____
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____	_____	LSC _____	_____	LSC _____	_____
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____	_____	LSC _____	_____	LSC _____	_____
ID Prefix _____	Correction	ID Prefix _____	Correction	ID Prefix _____	Correction
Reg. # _____	Completed	Reg. # _____	Completed	Reg. # _____	Completed
LSC _____	_____	LSC _____	_____	LSC _____	_____

REVIEWED BY STATE AGENCY <input checked="" type="checkbox"/>	REVIEWED BY (INITIALS) TL/mm	DATE 03/02/2016	SIGNATURE OF SURVEYOR 37009	DATE 03/02/2016
REVIEWED BY CMS RO <input type="checkbox"/>	REVIEWED BY (INITIALS)	DATE	TITLE	DATE
FOLLOWUP TO SURVEY COMPLETED ON 1/5/2016		<input type="checkbox"/> CHECK FOR ANY UNCORRECTED DEFICIENCIES. WAS A SUMMARY OF UNCORRECTED DEFICIENCIES (CMS-2567) SENT TO THE FACILITY? <input type="checkbox"/> YES <input type="checkbox"/> NO		





PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered

January 23, 2016

Mr. Blake Boche, Administrator  
Presbyterian Homes Of Bloomington  
9889 Penn Avenue South  
Bloomington, Minnesota 55431

RE: Project Number S5556028 and F5556025

Dear Mr. Boche:

On January 7, 2016, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs. This survey found the most serious deficiencies in your facility to be a pattern of deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level E), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

**Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.**

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

**Opportunity to Correct** - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

**Electronic Plan of Correction** - when a plan of correction will be due and the information to be contained in that document;

**Remedies** - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

**Potential Consequences** - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

**Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.**

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

**DEPARTMENT CONTACT**

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

**Gayle Lantto, Unit Supervisor**  
**Metro D Survey Team**  
**Licensing and Certification Program**  
**Health Regulation Division**  
**Minnesota Department of Health**  
**Email: [gayle.lantto@state.mn.us](mailto:gayle.lantto@state.mn.us)**

**Phone: (651) 201-3794**

**Fax: (651) 215-9697**

**OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES**

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by February 14, 2016, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

**ELECTRONIC PLAN OF CORRECTION (ePoC)**

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;

- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

The state agency may, in lieu of a revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

#### **PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE**

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.



## **VERIFICATION OF SUBSTANTIAL COMPLIANCE**

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

### **Original deficiencies not corrected**

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

### **Original deficiencies not corrected and new deficiencies found during the revisit**

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

### **Original deficiencies corrected but new deficiencies found during the revisit**

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

## **FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY**

If substantial compliance with the regulations is not verified by April 5, 2016 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the

Presbyterian Homes Of Bloomington

January 23, 2016

Page 5

result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by July 5, 2016 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

### **INFORMAL DISPUTE RESOLUTION**

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process  
Minnesota Department of Health  
Health Regulation Division  
P.O. Box 64900  
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: [http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc\\_idr.cfm](http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm)

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Tom Linhoff, Fire Safety Supervisor  
Health Care Fire Inspections  
Minnesota Department of Public Safety  
State Fire Marshal Division  
Email: [tom.linhoff@state.mn.us](mailto:tom.linhoff@state.mn.us)

Phone: (651) 430-3012

Fax: (651) 215-0525


Presbyterian Homes Of Bloomington

January 23, 2016

Page 6

Feel free to contact me if you have questions related to this eNotice.

Sincerely,

A handwritten signature in black ink that reads "Mark Meath". The signature is written in a cursive style with a prominent initial "M".

Mark Meath, Enforcement Specialist

Program Assurance Unit

Licensing and Certification Program

Health Regulation Division

Minnesota Department of Health

Email: [mark.meath@state.mn.us](mailto:mark.meath@state.mn.us)

Telephone: (651) 201-4118

Fax: (651) 215-9697

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/21/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245556</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>01/07/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>PRESBYTERIAN HOMES OF BLOOMINGTON</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>9889 PENN AVENUE SOUTH BLOOMINGTON, MN 55431</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 000	INITIAL COMMENTS  The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.	F 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

01/26/2016

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES


F556025

PRINTED: 02/01/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245556</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>1N - NEW BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/05/2016</b>
--	---	---	---

NAME OF PROVIDER OR SUPPLIER  <b>PRESBYTERIAN HOMES OF BLOOMINGTON</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>9889 PENN AVENUE SOUTH BLOOMINGTON, MN 55431</b>
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p><b>INITIAL COMMENTS</b></p> <p><b>FIRE SAFETY</b></p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ON-SITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, Fire Marshal Division on January 5, 2016. At the time of this survey, Presbyterian Homes of Bloomington Care Center was found not in substantial compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 18 New Health Care.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES ( K-TAGS) TO:</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR</p>	K 000		
-------	---	-------	---	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE  Electronically Signed	TITLE	(X6) DATE <b>01/28/2016</b>
--	-------	--------------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/01/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245556</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>1N - NEW BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/05/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>PRESBYTERIAN HOMES OF BLOOMINGTON</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>9889 PENN AVENUE SOUTH BLOOMINGTON, MN 55431</b>	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 By email to: Marian.Whitney@state.mn.us  THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:  1. A description of what has been, or will be, done to correct the deficiency.  2. The actual, or proposed, completion date.  3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency.  This 3-story building was determined to be of Type II(222) construction. It has a full basement and is fully fire sprinklered. The facility has a fire alarm system with smoke detection in resident rooms, corridors and spaces open to the corridor that is monitored for automatic fire department notification. The facility has a capacity of 98 beds and had a census of 86 beds at the time of the survey.	K 000		
K 050 SS=D	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 LIFE SAFETY CODE STANDARD  Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Responsibility for planning and conducting drills is assigned only to competent persons who are qualified to exercise leadership. Where drills are conducted between 9 PM and 6 AM a coded	K 050		1/26/16

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/01/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245556</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>1N - NEW BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/05/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>PRESBYTERIAN HOMES OF BLOOMINGTON</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>9889 PENN AVENUE SOUTH BLOOMINGTON, MN 55431</b>	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 050	Continued From page 2 announcement may be used instead of audible alarms. 18.7.1.2  This STANDARD is not met as evidenced by: Based on review of reports, records and staff interview, it was determined that the facility failed to vary the times of the fire drills in the last 12-month period. This deficient practice could affect how staff react in the event of a fire. Improper reaction by staff would affect the safety of all residents.  Findings include:  On facility tour between between 11:00 AM and 2:00 PM on 01/05/2016, a record review revealed that the facility conducted the Day-Shift fire drills in 2015 between the hours of 10:30 AM, 10:30 AM, 8:00 AM, 10:30 AM not varied times as required.  This deficient practice was verified by the Maintenance Director at the time of the inspection.	K 050	A review was conducted of all fire drills scheduled for 2016 calendar year. Fire drills have been schedule with varied times and days of the week to meet requirement as of 1/26/2016. The policy was reviewed and is current. Audits of the monthly drills and responses will be reviewed quarterly as part of the facility QA committee. Care Center Administrator is person responsible for ongoing monitoring and compliance.	
K 056 SS=E	NFPA 101 LIFE SAFETY CODE STANDARD  There is an automatic sprinkler system, installed in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems, with approved components, devices, and equipment, to provide complete coverage of all portions of the facility. The system is maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems. There is a reliable, adequate water supply for the system. The system is equipped	K 056		1/22/16

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/01/2016  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>245556</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>1N - NEW BUILDING</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>01/05/2016</b>
NAME OF PROVIDER OR SUPPLIER  <b>PRESBYTERIAN HOMES OF BLOOMINGTON</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>9889 PENN AVENUE SOUTH BLOOMINGTON, MN 55431</b>	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 056	Continued From page 3 with waterflow and tamper switches which are connected to the fire alarm system. 18.3.5.  This STANDARD is not met as evidenced by: Based on observations and staff interview, it was revealed that the automatic fire sprinkler system is not maintained in accordance with NFPA 25 Standard for Inspection, Testing and Maintenance of a Water-Based Fire protection System, 1998 edition section 6-3.6. This deficient practice may allow a fire to grow which will negatively impact 20 residents.  Findings include:  During the facility tour between the hours of 11:00 AM and 2:00 PM on 01/05/2016, it was observed in Bridgeway North stairwell that the bottom stairwell had no sprinkler head.  The deficient practice was verified by the Maintenance Supervisor at the time of inspection.	K 056	Work was completed on 1/22/2016 to install automatic sprinkler head as required. Care Center Administrator is person responsible for ongoing monitoring for compliance.	