

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: ZTMI
Facility ID: 00302

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245572		3. NAME AND ADDRESS OF FACILITY (L3) COLONIAL MANOR NURSING HOME			4. TYPE OF ACTION: <u>7</u> (L8)	
2.STATE VENDOR OR MEDICAID NO. (L2) 075487000		(L4) 403 COLONIAL AVENUE			1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other	
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9)		7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7)			8. Full Survey After Complaint	
6. DATE OF SURVEY 08/25/2017 (L34)		01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA			FISCAL YEAR ENDING DATE: (L35)	
8. ACCREDITATION STATUS: ___ (L10)		02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF			12/31	
0 Unaccredited 1 TJC 2 AOA 3 Other		03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC				
		04 SNF 08 OPT/SP 12 RHC 16 HOSPICE				
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) :		10.THE FACILITY IS CERTIFIED AS: X A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements ___ 2. Technical Personnel ___ 6. Scope of Services Limit Compliance Based On: ___ 3. 24 Hour RN ___ 7. Medical Director ___ 1. Acceptable POC ___ 4. 7-Day RN (Rural SNF) ___ 8. Patient Room Size ___ 5. Life Safety Code ___ 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: A* (L12)				
12.Total Facility Beds 37 (L18)						
13.Total Certified Beds 37 (L17)						
14. LTC CERTIFIED BED BREAKDOWN					15. FACILITY MEETS	
18 SNF 18/19 SNF 19 SNF ICF IID		1861 (e) (1) or 1861 (j) (1): (L15)				
37						
(L37) (L38) (L39) (L42) (L43)						

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE Larry Gannon, SFM (L19)		Date : 9/19/2017	18. STATE SURVEY AGENCY APPROVAL Kamala Fiske-Downing, Enforcement Specialist (L20)		Date: 9/19/2017
---	--	-------------------------	--	--	------------------------

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY ___ 1. Facility is Eligible to Participate ___ 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT:		21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____	
22. ORIGINAL DATE OF PARTICIPATION 05/01/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41)		24. LTC AGREEMENT ENDING DATE (L25)	
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)			
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 00322 (L28)		30. REMARKS Posted 08/14/2017 Co. DETERMINATION APPROVAL	
31. RO RECEIPT OF CMS-1539 (L32)		32. DETERMINATION OF APPROVAL DATE (L33)			



Protecting, Maintaining and Improving the Health of All Minnesotans

CMS Certification Number (CCN): 245572

September 18, 2017

Ms. Patrice Goette, Administrator
Colonial Manor Nursing Home
403 Colonial Avenue
Lakefield, MN 56150

Dear Ms. Goette:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective July 31, 2017 the above facility is certified for:

37 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 37 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink that reads 'Kamala Fiske-Downing'.

Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: (651) 201-4112 Fax: (651) 215-9697
Email: kamala.fiske-downing@state.mn.us

cc: Licensing and Certification File



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered

September 19, 2017

Ms. Patrice Goette, Administrator
Colonial Manor Nursing Home
403 Colonial Avenue
Lakefield, MN 56150

RE: Project Numbers S5572027, F5572026

Dear Ms. Goette:

On July 11, 2017, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for a standard survey, completed on June 29, 2017. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On August 25, 2017 the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on June 29, 2017. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of July 31, 2017. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on June 29, 2017, effective July 31, 2017 and therefore remedies outlined in our letter to you dated July 11, 2017, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink that reads 'Kamala Fiske-Downing'.

Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: (651) 201-4112 Fax: (651) 215-9697
Email: kamala.fiske-downing@state.mn.us

cc: Licensing and Certification File

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL
PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

ID: ZTMI
Facility ID: 00302

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245572 2. STATE VENDOR OR MEDICAID NO. (L2) 075487000	3. NAME AND ADDRESS OF FACILITY (L3) COLONIAL MANOR NURSING HOME (L4) 403 COLONIAL AVENUE (L5) LAKEFIELD, MN (L6) 56150	4. TYPE OF ACTION: <u> 2 </u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint																			
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9) 6. DATE OF SURVEY 06/29/2017 (L34) 8. ACCREDITATION STATUS: <u> </u> (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other	7. PROVIDER/SUPPLIER CATEGORY <u> 02 </u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE	FISCAL YEAR ENDING DATE: (L35) 12/31																			
11. LTC PERIOD OF CERTIFICATION From (a) : To (b) : 12. Total Facility Beds 37 (L18) 13. Total Certified Beds 37 (L17)	10. THE FACILITY IS CERTIFIED AS: X A. In Compliance With <u> </u> And/Or Approved Waivers Of The Following Requirements: <u> </u> Program Requirements <u> </u> 2. Technical Personnel <u> </u> 6. Scope of Services Limit Compliance Based On: <u> </u> 1. Acceptable POC <u> </u> 3. 24 Hour RN <u> </u> 7. Medical Director <u> </u> 4. 7-Day RN (Rural SNF) <u> </u> 8. Patient Room Size <u> </u> 5. Life Safety Code <u> </u> 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: * Code: A* (L12)																				
14. LTC CERTIFIED BED BREAKDOWN <table style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 15%;">18 SNF</td> <td style="width: 15%;">18/19 SNF</td> <td style="width: 15%;">19 SNF</td> <td style="width: 15%;">ICF</td> <td style="width: 15%;">IID</td> <td style="width: 15%;"></td> </tr> <tr> <td></td> <td style="text-align: center;">37</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>(L37)</td> <td>(L38)</td> <td>(L39)</td> <td>(L42)</td> <td>(L43)</td> <td></td> </tr> </table>		18 SNF	18/19 SNF	19 SNF	ICF	IID			37					(L37)	(L38)	(L39)	(L42)	(L43)		15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): (L15)	
18 SNF	18/19 SNF	19 SNF	ICF	IID																	
	37																				
(L37)	(L38)	(L39)	(L42)	(L43)																	
16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):																					
17. SURVEYOR SIGNATURE <u>Susan Kalis, HFE NE II</u> Date : <u>06/29/2017</u> (L19)		18. STATE SURVEY AGENCY APPROVAL <u>Kate JohnsTon, Program Specialist</u> 08/14/2017 (L20)																			
PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY																					
19. DETERMINATION OF ELIGIBILITY <u> </u> 1. Facility is Eligible to Participate <u> </u> 2. Facility is not Eligible (L21)		20. COMPLIANCE WITH CIVIL RIGHTS ACT: 21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : <u> </u>																			
22. ORIGINAL DATE OF PARTICIPATION 05/01/1991 (L24)		23. LTC AGREEMENT BEGINNING DATE (L41) 24. LTC AGREEMENT ENDING DATE (L25)																			
25. LTC EXTENSION DATE: (L27)		27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: (L44) B. Rescind Suspension Date: (L45)																			
28. TERMINATION DATE:		29. INTERMEDIARY/CARRIER NO. 00322 (L28) (L31)																			
31. RO RECEIPT OF CMS-1539 (L32)		30. REMARKS Posted 08/14/2017 Co. DETERMINATION APPROVAL																			
32. DETERMINATION OF APPROVAL DATE (L33)																					



PROTECTING, MAINTAINING AND IMPROVING THE HEALTH OF ALL MINNESOTANS

Electronically delivered
July 11, 2017

Ms. Patrice Goette, Administrator
Colonial Manor Nursing Home
403 Colonial Avenue
Lakefield, MN 56150

RE: Project Number S5572027

Dear Ms. Goette:

On June 29, 2017, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constitute no actual harm with potential for more than minimal harm that is not immediate jeopardy (Level F), as evidenced by the attached CMS-2567 whereby corrections are required. A copy of the Statement of Deficiencies (CMS-2567) is enclosed.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

This letter provides important information regarding your response to these deficiencies and addresses the following issues:

Opportunity to Correct - the facility is allowed an opportunity to correct identified deficiencies before remedies are imposed;

Electronic Plan of Correction - when a plan of correction will be due and the information to be contained in that document;

Remedies - the type of remedies that will be imposed with the authorization of the Centers for Medicare and Medicaid Services (CMS) if substantial compliance is not attained at the time of a revisit;

Potential Consequences - the consequences of not attaining substantial compliance 3 and 6 months after the survey date; and

Informal Dispute Resolution - your right to request an informal reconsideration to dispute the attached deficiencies.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by a "F" tag), i.e., the plan of correction should be directed to:

Kathryn Serie, Unit Supervisor
Mankato Survey Team
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
1400 East Lyon Street, Suite 102
Marshall, Minnesota 56258-2504
Email: kathryn.serie@state.mn.us
Phone: (507) 476-4233
Fax: (507) 344-2723

OPPORTUNITY TO CORRECT - DATE OF CORRECTION - REMEDIES

As of January 14, 2000, CMS policy requires that facilities will not be given an opportunity to correct before remedies will be imposed when actual harm was cited at the last standard or intervening survey and also cited at the current survey. Your facility does not meet this criterion. Therefore, if your facility has not achieved substantial compliance by August 8, 2017, the Department of Health will impose the following remedy:

- State Monitoring. (42 CFR 488.422)

In addition, the Department of Health is recommending to the CMS Region V Office that if your facility has not achieved substantial compliance by August 8, 2017 the following remedy will be imposed:

- Per instance civil money penalty. (42 CFR 488.430 through 488.444)

ELECTRONIC PLAN OF CORRECTION (ePoC)

An ePoC for the deficiencies must be submitted within **ten calendar days** of your receipt of this letter. Your ePoC must:

- Address how corrective action will be accomplished for those residents found to have been affected by the deficient practice;
- Address how the facility will identify other residents having the potential to be affected by the same deficient practice;
- Address what measures will be put into place or systemic changes made to ensure that the deficient practice will not recur;
- Indicate how the facility plans to monitor its performance to make sure that solutions are sustained. The facility must develop a plan for ensuring that correction is achieved and sustained. This plan must be implemented, and the corrective action evaluated for its effectiveness. The plan of correction is integrated into the quality assurance system;
- Include dates when corrective action will be completed. The corrective action completion dates must be acceptable to the State. If the plan of correction is unacceptable for any reason, the State will notify the facility. If the plan of correction is acceptable, the State will notify the facility. Facilities should be cautioned that they are ultimately accountable for their own compliance, and that responsibility is not alleviated in cases where notification about the acceptability of their plan of correction is not made timely. The plan of correction will serve as the facility's allegation of compliance; and,
- Submit electronically to acknowledge your receipt of the electronic 2567, your review and your ePoC submission.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Optional denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement.

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. Your signature at the bottom of the first page of the CMS-2567 form will be used as verification of compliance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is

acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, an onsite revisit of your facility may be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification. A Post Certification Revisit (PCR) will occur after the date you identified that compliance was achieved in your plan of correction.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

Original deficiencies not corrected

If your facility has not achieved substantial compliance, we will impose the remedies described above. If the level of noncompliance worsened to a point where a higher category of remedy may be imposed, we will recommend to the CMS Region V Office that those other remedies be imposed.

Original deficiencies not corrected and new deficiencies found during the revisit

If new deficiencies are identified at the time of the revisit, those deficiencies may be disputed through the informal dispute resolution process. However, the remedies specified in this letter will be imposed for original deficiencies not corrected. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed.

Original deficiencies corrected but new deficiencies found during the revisit

If new deficiencies are found at the revisit, the remedies specified in this letter will be imposed. If the deficiencies identified at the revisit require the imposition of a higher category of remedy, we will recommend to the CMS Region V Office that those remedies be imposed. You will be provided the required notice before the imposition of a new remedy or informed if another date will be set for the imposition of these remedies.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by September 29, 2017 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b). This mandatory denial of payments will be based on the failure to comply with deficiencies originally contained in the Statement

Colonial Manor Nursing Home

July 11, 2017

Page 5

of Deficiencies, upon the identification of new deficiencies at the time of the revisit, or if deficiencies have been issued as the result of a complaint visit or other survey conducted after the original statement of deficiencies was issued. This mandatory denial of payment is in addition to any remedies that may still be in effect as of this date.

We will also recommend to the CMS Region V Office and/or the Minnesota Department of Human Services that your provider agreement be terminated by December 29, 2017 (six months after the identification of noncompliance) if your facility does not achieve substantial compliance. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

INFORMAL DISPUTE RESOLUTION

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Fire Safety Supervisor
Health Care Fire Inspections
Minnesota Department of Public Safety
State Fire Marshal Division
445 Minnesota Street, Suite 145
St. Paul, Minnesota 55101-5145

Colonial Manor Nursing Home

July 11, 2017

Page 6

Email: tom.linhoff@state.mn.us

Telephone: (651) 430-3012

Fax: (651) 215-0525

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in cursive script that reads "Kamala Fiske-Downing".

Kamala Fiske-Downing

Minnesota Department of Health

Licensing and Certification Program

Program Assurance Unit

Health Regulation Division

Telephone: (651) 201-4112 Fax: (651) 215-9697

Email: Kamala.Fiske-Downing@state.mn.us

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 08/15/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____	(X3) DATE SURVEY COMPLETED 06/29/2017
--	---	--	---

NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

F 000	<p>INITIAL COMMENTS</p> <p>Colonial Manor, Lakefield, has been found to be in compliance with the requirements of 42 CFR Part 483, Subpart B, and Requirements for Long Term Care Facilities.</p> <p>The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, it is required that you acknowledge receipt of the electronic documents.</p>	F 000		
-------	---	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 07/12/2017
---	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES


F5572026

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/05/2017
--	---	---	---

NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division. At the time of this survey, Colonial Manor Nursing Home was found not to be in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care Occupancies.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota Street, Suite 145 St. Paul, MN 55101-5145, or</p>	K 000		
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE Electronically Signed	TITLE	(X6) DATE 07/20/2017
--	-------	--------------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) †	(X5) COMPLETION DATE
K 000	<p>Continued From page 1</p> <p>By email to: Marian.Whitney@state.mn.us <mailto:Marian.Whitney@state.mn.us> and Angela.Kappenman@state.mn.us <mailto:Angela.Kappenman@state.mn.us></p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency. <p>Colonial Manor Nursing Home was constructed as follows: The original building was constructed in 1969, is one-story in height, has a partial basement, is fully fire sprinkler protected and was determined to be of Type II(111) construction; The 1st Addition was constructed in 1979, is one-story in height, has no basement, is fully fire sprinkler protected and was determined to be of Type II(111) construction; The 2nd Addition was constructed in 1999, is one-story in height, has no basement, is fully fire sprinkler protected and was determined to be of Type II(111) construction.</p> <p>The facility has a fire alarm system with smoke detection in the corridors and spaces open to the corridors which is monitored for automatic fire department notification. The facility has a</p>	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 capacity of 37 beds and had a census of 33 at time of the survey.	K 000		
K 321 SS=E	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: NFPA 101 Hazardous Areas - Enclosure Hazardous Areas - Enclosure 2012 EXISTING Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4-hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS . 19.3.2.1 Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) This STANDARD is not met as evidenced by:	K 321		7/17/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME		STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 321	<p>Continued From page 3</p> <p>Based on observation and interview, the Facility failed to maintain hazardous areas are protected by a fire barrier having 1-hour fire resistance rating. This deficiency could effect 33 of the 33 residents.</p> <p>Hazardous Areas - Enclosure 2012 EXISTING Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4-hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1</p> <p>Area Automatic Sprinkler Seperation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons) f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K3220)</p> <p>FINDINGS INCLUDE:</p>	K 321	<p>Door closures were installed and operational on the basement storage door, the file room door and the maintenance office door on 7/19/2017 by the Director Maintenance. Monitoring to prevent a reoccurrence will be the responsibility of the Director of Maintenance.</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 321	Continued From page 4 On facility tour between 9:00 AM and 1:00 PM on 07/05/2017, the following issues were observed within Hazardous Areas on the lower level: 1.) Maintenance Shop Door needs a door closer installed. 2.) Storage Room Door needs a door closer installed. 3.) File Room Door needs a door closer installed. This deficient practice was verified by the Facility Maintenance Director.	K 321			
K 345 SS=F	NFPA 101 Fire Alarm System - Testing and Maintenance Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This STANDARD is not met as evidenced by: Based on documentation review and interview, the Facility failed to test and maintain the Fire Alarm System in accordance with NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. The deficient practice could affect 33 out of 33 residents. Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying	K 345	Simplex Grinnell was at the facility on 7/19/2017 to review the smoke detector system and to schedule a date for the Smoke Alarm Sensitivity Test, which will be completed by 7/31/2017. The Director of Maintenance will document when the test is completed, retain appropriate report and will note when the next test is due to ensure future compliance is met.	7/31/17	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 345	Continued From page 5 with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.7.5, 9.7.7, 9.7.8, and NFPA 25. FINDINGS INCLUDE: On facility tour between 9:00 AM and 1:00 PM on 07/05/2017, documentation reviewed revealed that a smoke detector sensitivity test report could not be located. This deficient practice was verified by the Facility Maintenance Director.	K 345		
K 918 SS=E	NFPA 101 Electrical Systems - Essential Electric System Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by	K 918		7/19/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	<p>Continued From page 6</p> <p>competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked and readily identifiable. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>This STANDARD is not met as evidenced by: Based on documentation review and interview, the Facility failed to provide complete written records of Generator maintenance and testing are maintained and readily available. This deficient practice could affect 33 of 33 residents.</p> <p>Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual</p>	K 918	<p>Annual Backup Generator Maintenance was performed on 7/19/2017 by Onsite Energy. Documentation and report of visit and maintenance completed on generator will be retained by the Director of Maintenance and will be responsible to coordinate future annual visits for continued compliance.</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 918	Continued From page 7 transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked and readily identifiable. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70) FINDINGS INCLUDE: On facility tour between 9:00 AM and 1:00 PM on 07/05/2017, during documentation review, the annual generator maintenance report could not be located. This deficient practice was verified by the Facility Maintenance Director.	K 918		
K 920 SS=E	NFPA 101 Electrical Equipment - Power Cords and Extens Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assembles that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal	K 920		7/28/17

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 920	Continued From page 8 electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 This STANDARD is not met as evidenced by: Based on observation and interview, the Facility failed to comply with 10.2.4 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5. This deficient practice could affect 33 of the 33 residents. Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a	K 920	Hohenstein Electric evaluated the outlet situation in the file room on 7/17/2017 and will install a new outlet(s) by 7/28/2017. The Director of Maintenance is responsible for this installation to be done timely and to monitor for any further use of extension cords and appropriate wiring throughout the facility.	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 07/25/2017
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245572	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 07/05/2017
NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME			STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 920	Continued From page 9 substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 FINDINGS INCLUDE: On facility tour between 9:00 AM and 1:00 PM on 07/05/2017, a extension cord and portable GFCI was observed being used as a source of fixed wiring in the File Room on the newly installed hot water system. This deficient practice was verified by the Facility Maintenance Director.	K 920			



Protecting, Maintaining and Improving the Health of Minnesotans

Electronically delivered
July 11, 2017

Ms. Patrice Goette, Administrator
Colonial Manor Nursing Home
403 Colonial Avenue
Lakefield, MN 56150

Re: Project Number S5572027

Dear Ms. Goette:

The above facility survey was completed on June 29, 2017 for the purpose of assessing compliance with Minnesota Department of Health Nursing Home Rules. At the time of the survey, the survey team from the Minnesota Department of Health, Health Regulation Division, noted no violations of these rules promulgated under Minnesota Stat. section 144.653 and/or Minnesota Stat. Section 144A.10.

Electronically posted is the Minnesota Department of Health order form stating that no violations were noted at the time of this survey. The Minnesota Department of Health is documenting the State Licensing Correction Orders using federal software. Please disregard the heading of the fourth column which states, "Provider's Plan of Correction." This applies to Federal deficiencies only. There is no requirement to submit a Plan of Correction.

Please note it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Please feel free to call me with any questions.

Sincerely,

A handwritten signature in black ink that reads "Kamala Fiske-Downing". The signature is written in a cursive style.

Kamala Fiske-Downing
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: (651) 201-4112 Fax: (651) 215-9697
Email: Kamala.Fiske-Downing@state.mn.us

Minnesota Department of Health

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 00302	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED 06/29/2017
--	--	---	---

NAME OF PROVIDER OR SUPPLIER COLONIAL MANOR NURSING HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 403 COLONIAL AVENUE LAKEFIELD, MN 56150
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
2 000	<p>Initial Comments</p> <p>*****ATTENTION*****</p> <p>NH LICENSING CORRECTION ORDER</p> <p>In accordance with Minnesota Statute, section 144A.10, this correction order has been issued pursuant to a survey. If, upon reinspection, it is found that the deficiency or deficiencies cited herein are not corrected, a fine for each violation not corrected shall be assessed in accordance with a schedule of fines promulgated by rule of the Minnesota Department of Health.</p> <p>Determination of whether a violation has been corrected requires compliance with all requirements of the rule provided at the tag number and MN Rule number indicated below. When a rule contains several items, failure to comply with any of the items will be considered lack of compliance. Lack of compliance upon re-inspection with any item of multi-part rule will result in the assessment of a fine even if the item that was violated during the initial inspection was corrected.</p> <p>You may request a hearing on any assessments that may result from non-compliance with these orders provided that a written request is made to the Department within 15 days of receipt of a notice of assessment for non-compliance.</p> <p>INITIAL COMMENTS: On 6/27, 6/28 and 6/29/17 surveyors of the Minnesota Department of Health staff, visited the above provider and no licensing violations were issued.</p> <p>"No licensing violations"</p>	2 000		

Minnesota Department of Health
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Electronically Signed

TITLE

(X6) DATE
07/12/17