



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically Delivered
July 5, 2022

Administrator
Meadows On Fairview
25565 Fairview Avenue
Wyoming, MN 55092

RE: CCN: 245622
Cycle Start Date: March 17, 2022

Dear Administrator:

On April 22, 2022 and June 17, 2022, the Minnesota Department of Health and Public Safety completed a revisit to verify that your facility had achieved and maintained compliance. Based on our review, we have determined that your facility has achieved substantial compliance; therefore no remedies will be imposed.

Feel free to contact me if you have questions.

A handwritten signature in black ink, appearing to read 'Melissa Poepping'.

Melissa Poepping, Compliance Analyst
Federal Enforcement | Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
Saint Paul, Minnesota 55164-0970
Phone: 651-201-4117
Email: melissa.poepping@state.mn.us



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
July 5, 2022

CMS Certification Number (CCN): 245622

Administrator
Meadows On Fairview
25565 Fairview Avenue
Wyoming, MN 55092

Dear Administrator:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective June 16, 2022 the above facility is certified for:

14 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 14 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status. If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and/or Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Melissa Poepping'.

Melissa Poepping, Compliance Analyst
Federal Enforcement | Health Regulation Division
Minnesota Department of Health
P.O. Box 64900
Saint Paul, Minnesota 55164-0970
Phone: 651-201-4117
Email: melissa.poepping@state.mn.us



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
April 5, 2022

Administrator
Meadows On Fairview
25565 Fairview Avenue
Wyoming, MN 55092

RE: CCN: 245622
Cycle Start Date: March 17, 2022

Dear Administrator:

On March 17, 2022, a survey was completed at your facility by the Minnesota Departments of Health and Public Safety, to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

ELECTRONIC PLAN OF CORRECTION (ePoC)

Within ten (10) calendar days after your receipt of this notice, you must submit an acceptable ePOC for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

Meadows On Fairview

April 5, 2022

Page 2

The state agency may, in lieu of an onsite revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Denial of payment for new Medicare and Medicaid admissions (42 CFR 488.417);
- Civil money penalty (42 CFR 488.430 through 488.444).
- Termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by an "F" and/or an E tag), i.e., the plan of correction should be directed to:

Sarah Grebenc, Unit Supervisor
Metro A District Office
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
85 East Seventh Place, Suite 220
P.O. Box 64900
Saint Paul, Minnesota 55164-0900
Email: sarah.grebenc@state.mn.us
Office: (651) 238-8786 Mobile (651)238-8786

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or

Meadows On Fairview

April 5, 2022

Page 3

Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by June 17, 2022 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by September 17, 2022 (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

INFORMAL DISPUTE RESOLUTION (IDR) / INDEPENDENT INFORMAL DISPUTE RESOLUTION (IIDR)

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: https://mdhprovidercontent.web.health.state.mn.us/lrc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: https://www.health.state.mn.us/facilities/regulation/infobulletins/ib04_8.html

Please note that the failure to complete the informal dispute resolution process will not delay the

Meadows On Fairview

April 5, 2022

Page 4

dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

William Abderhalden, Fire Safety Supervisor
Deputy State Fire Marshal
Health Care/Corrections Supervisor – Interim
Minnesota Department of Public Safety
445 Minnesota Street, Suite 145
St. Paul, MN 55101-5145
Cell: (507) 361-6204
Email: william.abderhalden@state.mn.us
Fax: (651) 215-0525

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Melissa Poepping". The signature is fluid and cursive, with a large initial "M" and a long, sweeping underline.

Melissa Poepping, Health Program Representative Senior
Program Assurance | Licensing and Certification
Minnesota Department of Health
P.O. Box 64900
Saint Paul, Minnesota 55164-0970
Phone: 651-201-4117
Email: melissa.poepping@state.mn.us

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/17/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments On 3/14/22 to 3/17/22, a survey for compliance with Appendix Z, Emergency Preparedness Requirements, §483.73(b)(6) was conducted during a standard recertification survey. The facility was not in compliance. The facility's plan of correction (POC) will serve as your allegation of compliance upon the Department's acceptance. Because you are enrolled in ePOC, your signature is not required at the bottom of the first page of the CMS-2567 form. Upon receipt of an acceptable electronic POC, an onsite revisit of your facility may be conducted to validate substantial compliance with the regulation has been attained.	E 000			
E 041 SS=C	Hospital CAH and LTC Emergency Power CFR(s): 483.73(e) §482.15(e) Condition for Participation: (e) Emergency and standby power systems. The hospital must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section and in the policies and procedures plan set forth in paragraphs (b)(1)(i) and (ii) of this section. §483.73(e), §485.625(e) (e) Emergency and standby power systems. The [LTC facility and the CAH] must implement emergency and standby power systems based on the emergency plan set forth in paragraph (a) of this section. §482.15(e)(1), §483.73(e)(1), §485.625(e)(1) Emergency generator location. The generator	E 041		4/19/22	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

04/15/2022

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/17/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 041	<p>Continued From page 1</p> <p>must be located in accordance with the location requirements found in the Health Care Facilities Code (NFPA 99 and Tentative Interim Amendments TIA 12-2, TIA 12-3, TIA 12-4, TIA 12-5, and TIA 12-6), Life Safety Code (NFPA 101 and Tentative Interim Amendments TIA 12-1, TIA 12-2, TIA 12-3, and TIA 12-4), and NFPA 110, when a new structure is built or when an existing structure or building is renovated.</p> <p>482.15(e)(2), §483.73(e)(2), §485.625(e)(2) Emergency generator inspection and testing. The [hospital, CAH and LTC facility] must implement the emergency power system inspection, testing, and [maintenance] requirements found in the Health Care Facilities Code, NFPA 110, and Life Safety Code.</p> <p>482.15(e)(3), §483.73(e)(3), §485.625(e)(3) Emergency generator fuel. [Hospitals, CAHs and LTC facilities] that maintain an onsite fuel source to power emergency generators must have a plan for how it will keep emergency power systems operational during the emergency, unless it evacuates.</p> <p>*[For hospitals at §482.15(h), LTC at §483.73(g), and CAHs §485.625(g):] The standards incorporated by reference in this section are approved for incorporation by reference by the Director of the Office of the Federal Register in accordance with 5 U.S.C. 552(a) and 1 CFR part 51. You may obtain the material from the sources listed below. You may inspect a copy at the CMS Information Resource Center, 7500 Security Boulevard, Baltimore, MD or at the National Archives and Records Administration (NARA). For information on the</p>	E 041			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/17/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 041	Continued From page 2 availability of this material at NARA, call 202-741-6030, or go to: http://www.archives.gov/federal_register/code_of_federal_regulations/ibr_locations.html . If any changes in this edition of the Code are incorporated by reference, CMS will publish a document in the Federal Register to announce the changes. (1) National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169, www.nfpa.org, 1.617.770.3000. (i) NFPA 99, Health Care Facilities Code, 2012 edition, issued August 11, 2011. (ii) Technical interim amendment (TIA) 12-2 to NFPA 99, issued August 11, 2011. (iii) TIA 12-3 to NFPA 99, issued August 9, 2012. (iv) TIA 12-4 to NFPA 99, issued March 7, 2013. (v) TIA 12-5 to NFPA 99, issued August 1, 2013. (vi) TIA 12-6 to NFPA 99, issued March 3, 2014. (vii) NFPA 101, Life Safety Code, 2012 edition, issued August 11, 2011. (viii) TIA 12-1 to NFPA 101, issued August 11, 2011. (ix) TIA 12-2 to NFPA 101, issued October 30, 2012. (x) TIA 12-3 to NFPA 101, issued October 22, 2013. (xi) TIA 12-4 to NFPA 101, issued October 22, 2013. (xiii) NFPA 110, Standard for Emergency and Standby Power Systems, 2010 edition, including TIAs to chapter 7, issued August 6, 2009.. This REQUIREMENT is not met as evidenced by: As a result of the Life Safety Code survey on 3/15/22, which was based on a review of available documentation and staff interview, the facility failed to test and inspect the generator per	E 041	Immediate Corrective Action: Rented generator is no longer in community.		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 03/17/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 041	Continued From page 3 NFPA 101 (2012 edition), Life Safety Code, section 9.1.3.1, NFPA 99 (2012 edition), Health Care Facilities Code, section 6.4.4.1.1.4, and NFPA 110 (2010 edition), Standard for Emergency and Standby Power Systems, section 8.4.1 through 8.4.2. These deficient findings could have a widespread impact on the residents within the facility. Findings include: On 3/15/2022, at 9:55 a.m., it was revealed by a review of available documentation of the emergency generator maintenance and testing was not completed weekly on the rented generator from 6/29/2021 to 8/31/2021. An interview with the Director of Environmental Services verified this deficient finding at the time of discovery	E 041	Corrective Action for All Residents: Rented generator is no longer in community. Date of Completion: 4/19/22 Education for Maintenance Director that generators are inspected weekly completed on 4/19/22 How Community will Prevent Reoccurrence: Weekly auditing of generators will be conducted by Maintenance Director for three months and audits brought to QAPI meetings to ensure compliance. Person Responsible: Director of Environmental Services		
F 000	INITIAL COMMENTS On 3/14/22, 3/15/22, 3/16/22 and 3/17/22, a standard recertification survey was conducted at your facility. Your facility was found to be IN compliance with the requirements of 42 CFR 483, Subpart B, Requirements for Long Term Care Facilities. The facility is enrolled in ePOC and therefore a signature is not required at the bottom of the first page of the CMS-2567 form. Although no plan of correction is required, the facility must acknowledge receipt of the electronic documents.	F 000			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>An annual fire safety recertification survey was conducted by the Minnesota Department of Public Safety, State Fire Marshal Division on 03/15/2022. At the time of this survey, Meadows on Fairview was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99, Health Care Facilities Code.</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 FORM WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K-TAGS) TO:</p> <p>IF PARTICIPATING IN THE E-POC PROCESS, A PAPER COPY OF THE PLAN OF CORRECTION IS NOT REQUIRED.</p>	K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

04/15/2022

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	<p>Continued From page 1</p> <p>Healthcare Fire Inspections State Fire Marshal Division 445 Minnesota St., Suite 145 St. Paul, MN 55101-5145, OR</p> <p>By email to: FM.HC.Inspections@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A detailed description of the corrective action taken or planned to correct the deficiency. 2. Address the measures that will be put in place to ensure the deficiency does not reoccur. 3. Indicate how the facility plans to monitor future performance to ensure solutions are sustained. 4. Identify who is responsible for the corrective actions and monitoring of compliance. 5. The actual or proposed date for completion of the remedy. <p>Meadows on Fairview is one wing of an assisted living facility that was constructed in 2004 and converted to a nursing home in 2014. The building construction type has been determined to be Type V(111)). It is properly separated from the original building constructed in 2004 by 2-hour fire-resistive construction, with 1.5 hour rated doors.</p> <p>The building is fully sprinklered throughout; the facility has a fire alarm system with smoke</p>	K 000			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 detection in the corridors and spaces open to the corridors that is monitored for automatic fire department notification.	K 000			
K 345 SS=F	<p>The facility has a capacity of 14 beds and had a census of 14 at the time of the survey.</p> <p>The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: Fire Alarm System - Testing and Maintenance CFR(s): NFPA 101</p> <p>Fire Alarm System - Testing and Maintenance A fire alarm system is tested and maintained in accordance with an approved program complying with the requirements of NFPA 70, National Electric Code, and NFPA 72, National Fire Alarm and Signaling Code. Records of system acceptance, maintenance and testing are readily available. 9.6.1.3, 9.6.1.5, NFPA 70, NFPA 72 This REQUIREMENT is not met as evidenced by: Based on a review of the available documentation and staff interview, the facility failed to inspect the fire alarm system per NFPA 101 (2012 edition), Life Safety Code, section 9.6.1.5 and NFPA 72 (2010 edition), The National Fire Alarm and Signaling Code, section 14.3.1. This deficient finding could have a widespread impact on the residents within the facility.</p> <p>Findings include: On 03/15/2022 at 9:00 AM, it was revealed by a review of available documentation that the semi-annual fire alarm testing documentation was not available at the time of the survey.</p>	K 345	<p>Immediate Corrective Action to Correct Deficiency:</p> <p>Scheduled fire alarm testing to be done every six months.</p> <p>Updated contract with fire alarm monitoring company for fire alarm testing every six months.</p> <p>Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22</p>	6/16/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 345	Continued From page 3 An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 345	How Facility Plans to Monitor Future Performance: Semi-Annual Audits. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 6/16/22		
K 353 SS=D	Sprinkler System - Maintenance and Testing CFR(s): NFPA 101 Sprinkler System - Maintenance and Testing Automatic sprinkler and standpipe systems are inspected, tested, and maintained in accordance with NFPA 25, Standard for the Inspection, Testing, and Maintaining of Water-based Fire Protection Systems. Records of system design, maintenance, inspection and testing are maintained in a secure location and readily available. a) Date sprinkler system last checked _____ b) Who provided system test _____ c) Water system supply source _____ Provide in REMARKS information on coverage for any non-required or partial automatic sprinkler system. 9.7.5, 9.7.7, 9.7.8, and NFPA 25 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain the sprinkler system per NFPA 101 (2012 edition), Life Safety Code, section 9.7.5, and NFPA 25 (2011 edition), Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection	K 353	Immediate Corrective Action to Correct Deficiency: Scheduled fire alarm monitoring company to replace sprinkler head in clean utility	6/16/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 353	Continued From page 4 Systems, section 5.2.1.1.1. This deficient finding could have an isolated impact on the residents within the facility. Findings include: On 03/15/2022 at 12:00 PM, it was revealed in the clean utility room that there was a sprinkler head that had been painted. An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 353	room. Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22 How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 6/16/22		
K 355 SS=D	Portable Fire Extinguishers CFR(s): NFPA 101 Portable Fire Extinguishers Portable fire extinguishers are selected, installed, inspected, and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. 18.3.5.12, 19.3.5.12, NFPA 10 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to maintain access to portable fire extinguishers per NFPA 101 (2012 edition), Life Safety Code, section 9.7.4.1, and NFPA 10 (2010 edition), Standard for Portable Fire Extinguishers, section 7.3.1.1.1. This deficient finding could have an isolated impact on the residents within the facility. Findings include:	K 355	Immediate Corrective Action to Correct Deficiency: Fire extinguisher was replaced. Fire extinguisher inspection schedule was reviewed. Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22	4/14/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 355	Continued From page 5 On 03/15/2022 at 1:00 PM, observation revealed that the fire extinguisher in the beauty shop was last inspected in April 2017. An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 355	How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 4/14/22		
K 363 SS=E	Corridor - Doors CFR(s): NFPA 101 Corridor - Doors Doors protecting corridor openings in other than required enclosures of vertical openings, exits, or hazardous areas resist the passage of smoke and are made of 1 3/4 inch solid-bonded core wood or other material capable of resisting fire for at least 20 minutes. Doors in fully sprinklered smoke compartments are only required to resist the passage of smoke. Corridor doors and doors to rooms containing flammable or combustible materials have positive latching hardware. Roller latches are prohibited by CMS regulation. These requirements do not apply to auxiliary spaces that do not contain flammable or combustible material. Clearance between bottom of door and floor covering is not exceeding 1 inch. Powered doors complying with 7.2.1.9 are permissible if provided with a device capable of keeping the door closed when a force of 5 lbf is applied. There is no impediment to the closing of the doors. Hold open devices that release when the door is pushed or pulled are permitted. Nonrated protective plates of unlimited height are permitted. Dutch doors meeting 19.3.6.3.6 are permitted. Door frames	K 363		6/16/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 363	<p>Continued From page 6</p> <p>shall be labeled and made of steel or other materials in compliance with 8.3, unless the smoke compartment is sprinklered. Fixed fire window assemblies are allowed per 8.3. In sprinklered compartments there are no restrictions in area or fire resistance of glass or frames in window assemblies.</p> <p>19.3.6.3, 42 CFR Parts 403, 418, 460, 482, 483, and 485</p> <p>Show in REMARKS details of doors such as fire protection ratings, automatics closing devices, etc.</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on observation and staff interview, the facility failed to maintain corridor doors per NFPA 101 (2012 edition), Life Safety Code, sections 19.3.6.3.1 and 19.3.6.3.10. These deficient findings could have a patterned impact on the residents within the facility.</p> <p>Findings include:</p> <p>1) On 03/15/2022 at 11:05 AM, it was revealed by observation that Patient Room 5 had a bent door frame from the corridor side with a gap allowing light to be seen from inside the room.</p> <p>2) On 03/15/2022 at 12:30 PM, it was revealed by observation that the Beauty Shop door was held open by an unapproved door stop.</p> <p>An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.</p>	K 363	<p>Immediate Corrective Action to Correct Deficiency:</p> <p>Scheduled mag lock to be installed on Beauty Shop door.</p> <p>Scheduled door replacement for Patient Room 5.</p> <p>Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22</p> <p>How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed.</p> <p>Person Responsible: Director of Environmental Services</p> <p>Date of Completion: 6/16/22</p>		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 511 K 511 SS=F	Continued From page 7 Utilities - Gas and Electric CFR(s): NFPA 101 Utilities - Gas and Electric Equipment using gas or related gas piping complies with NFPA 54, National Fuel Gas Code, electrical wiring and equipment complies with NFPA 70, National Electric Code. Existing installations can continue in service provided no hazard to life. 18.5.1.1, 19.5.1.1, 9.1.1, 9.1.2 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview, the facility failed to secure electrical panels per NFPA 99 (2012 edition), Health Care Facilities Code, section 6.3.2.2.1.3 and failed to maintain the Gas and Utility System per NFPA 101 (2012 edition), Life Safety Code section 9.2.2 and NFPA 54 (2012 edition), National Fuel Gas Code, sections 9.2.2 and 10.3.2.2. These deficient findings could have a widespread impact on the residents within the facility. Findings include: 1) On 03/15/2022 at 10:15 AM, it was revealed by observation that the electrical panel located in the link was not locked. 2) On 03/15/2022, between 10:30 AM and 1:30 PM, it was revealed by observation that the electrical panels in the patient rooms were not locked.	K 511 K 511	Immediate Corrective Action to Correct Deficiency: Lock was placed on electrical panel located in the link. Locks were placed in electrical panels in all patient rooms. Combustible materials was removed in the small furnace room located by the health services office. Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22 How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI	4/14/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 511	Continued From page 8 3) On 03/15/2022 at 11:46 AM, it was revealed that in a small furnace room, there was combustible storage within 1 foot of the gas furnace located by the health services office. An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 511	meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 4/14/22		
K 712 SS=F	Fire Drills CFR(s): NFPA 101 Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 19.7.1.4 through 19.7.1.7 This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to conduct fire drills per NFPA 101 (2012 edition), Life Safety Code, section 19.7.1.6. This deficient finding could have a widespread impact on the residents within the facility. Findings include: On 03/15/2022 at 9:25 AM, it was revealed by a review of available documentation the following fire drills could not be verified for completion of the drills during these times:	K 712	Immediate Corrective Action to Correct Deficiency: Changed fire drill form to include assisted living and TCU drills independent of one another. Changed fire drill form to include signatures of staff present. Changed fire drill schedule to include all shifts.	4/14/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 712	Continued From page 9 1) Second and Third Shifts of the First Quarter of 2022 2) Third Shift of the Second Quarter of 2021 3) Second and Third shift of the Third Quarter of 2021 4) Second and Third Shift of Fourth Quarter of 2021 An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 712	Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22 How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 4/14/22		
K 761 SS=F	Maintenance, Inspection & Testing - Doors CFR(s): NFPA 101 Maintenance, Inspection & Testing - Doors Fire doors assemblies are inspected and tested annually in accordance with NFPA 80, Standard for Fire Doors and Other Opening Protectives. Non-rated doors, including corridor doors to patient rooms and smoke barrier doors, are routinely inspected as part of the facility maintenance program. Individuals performing the door inspections and testing possess knowledge, training or experience that demonstrates ability. Written records of inspection and testing are maintained and are available for review. 19.7.6, 8.3.3.1 (LSC) 5.2, 5.2.3 (2010 NFPA 80) This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to conduct inspections of all fire-rated doors required per	K 761	Immediate Corrective Action to Correct Deficiency:	4/14/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 761	Continued From page 10 NFPA 101 (2012 edition), Life Safety Code, sections 7.2.1.15.2 and 7.2.1.15.4, and NFPA 80 (2010 edition), Standard for Fire Doors and Other Opening Protectives, section 5.2.4.2. This deficient finding could have a widespread impact on the residents within the facility. Findings include: On 03/15/2022 at 09:30 AM, it was revealed by a review of available documentation that the annual fire-rated doors were not conducted, and appropriate documentation was not available at the time of the survey. An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 761	Documentation completed by Director of Environmental Services. Measures in Place to Ensure Deficiency Doesn't Reoccur: Training completed on 4/14/22 How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 4/14/22		
K 901 SS=F	Fundamentals - Building System Categories CFR(s): NFPA 101 Fundamentals - Building System Categories Building systems are designed to meet Category 1 through 4 requirements as detailed in NFPA 99. Categories are determined by a formal and documented risk assessment procedure performed by qualified personnel. Chapter 4 (NFPA 99) This REQUIREMENT is not met as evidenced by: Based on a review of available documentation and staff interview, the facility failed to conduct the building systems are designed to meet Category 1 through 4 requirements as detailed in	K 901	Immediate Corrective Action to Correct Deficiency: Review and complete NFPA 99 Facility	6/15/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 901	Continued From page 11 NFPA 99 (2012 Edition), Health Care Facilities Code, Chapter 4. This deficient finding could have a widespread impact on the residents within the facility. Findings include: On 03/15/2022 at 09:45 AM, it was revealed by a review of available documentation that the facility did not have a complete NFPA 99 Facility Risk Assessment. Chapters 10 and 11 were not completed at the time of the survey. An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.	K 901	Risk Assessment – Chapters 10 and 11. Measures in Place to Ensure Deficiency Doesn't Reoccur: Training scheduled for May. How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Administrator Date of Completion: 6/15/22		
K 918 SS=F	Electrical Systems - Essential Electric System CFR(s): NFPA 101 Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of	K 918		4/14/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	<p>Continued From page 12</p> <p>stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked, readily identifiable, and separate from normal power circuits. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations.</p> <p>6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on a review of available documentation and staff interview, the facility failed to test and inspect the generator per NFPA 101 (2012 edition), Life Safety Code, section 9.1.3.1, NFPA 99 (2012 edition), Health Care Facilities Code, section 6.4.4.1.1.4, and NFPA 110 (2010 edition), Standard for Emergency and Standby Power Systems, section 8.4.1 through 8.4.2. These deficient findings could have a widespread impact on the residents within the facility.</p> <p>Findings include:</p> <p>On 3/15/2022 at 09:55 AM, it was revealed by a review of available documentation of the emergency generator that weekly inspections were not completed on the rented generator from 06/29/2021 to 08/31/2021.</p> <p>An interview with the Director of Environmental Services verified this deficient finding at the time of discovery.</p>	K 918	<p>Immediate Corrective Action to Correct Deficiency:</p> <p>Rented generator is no longer in community.</p> <p>Any future rented generators will require vendor to perform weekly generator testing in contract.</p> <p>Measures in Place to Ensure Deficiency Doesn't Reoccur: Training Completed 4/14/22</p> <p>How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed.</p> <p>Person Responsible: Director of</p>		

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	Continued From page 13	K 918	Environmental Services		
K 920 SS=E	<p>Electrical Equipment - Power Cords and Extens CFR(s): NFPA 101</p> <p>Electrical Equipment - Power Cords and Extension Cords Power strips in a patient care vicinity are only used for components of movable patient-care-related electrical equipment (PCREE) assemblies that have been assembled by qualified personnel and meet the conditions of 10.2.3.6. Power strips in the patient care vicinity may not be used for non-PCREE (e.g., personal electronics), except in long-term care resident rooms that do not use PCREE. Power strips for PCREE meet UL 1363A or UL 60601-1. Power strips for non-PCREE in the patient care rooms (outside of vicinity) meet UL 1363. In non-patient care rooms, power strips meet other UL standards. All power strips are used with general precautions. Extension cords are not used as a substitute for fixed wiring of a structure. Extension cords used temporarily are removed immediately upon completion of the purpose for which it was installed and meets the conditions of 10.2.4. 10.2.3.6 (NFPA 99), 10.2.4 (NFPA 99), 400-8 (NFPA 70), 590.3(D) (NFPA 70), TIA 12-5 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview the facility failed to ensure that multiple power strips are used per NFPA 99 (2012 edition), Health Care Facilities Code, sections 10.2.4.2.1 and 10.2.3.6, and UL 1363. These deficient findings could have a patterned impact on the residents within the</p>	K 920	<p>Date of Completion: 4/14/22</p> <p>Immediate Corrective Action to Correct Deficiency: Microwave was immediately plugged directly into the wall outlet and power strip</p>	4/14/22	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245622	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MEADOWS FAIRVIEW B. WING _____		(X3) DATE SURVEY COMPLETED 03/15/2022
NAME OF PROVIDER OR SUPPLIER MEADOWS ON FAIRVIEW			STREET ADDRESS, CITY, STATE, ZIP CODE 25565 FAIRVIEW AVENUE WYOMING, MN 55092		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 920	Continued From page 14 facility. Findings include: 1. On 03/15/2022 at 11:24 AM, observation revealed that a microwave was plugged into a power strip in the therapy office. 2. On 03/15/2022 at 11:24 AM, observation revealed that an extension cord was used to plug in the radio in the beauty shop. An interview with the Director of Environmental Services verified these deficient findings at the time of discovery.	K 920	removed. Extension cord was immediately removed from beauty shop. Measures in Place to Ensure Deficiency Doesn't Reoccur: Training Completed 4/14/22 How Facility Plans to Monitor Future Performance: Monthly Audits for Three Months. Audits will be reviewed at QAPI meeting to determine if further audits are needed. Person Responsible: Director of Environmental Services Date of Completion: 4/14/22		