

# Prairie Island Nuclear Generating Plant December 2025

## INDEPENDENT SPENT FUEL STORAGE INSTALLATION

### Introduction

This report provides data on radiation levels inside the Xcel Energy, Inc. Independent Spent Fuel Storage Installation (ISFSI) at the Prairie Island Nuclear Generating Plant (PINGP) for December 2025. The data contained in this report were gathered in accordance with agreements between Xcel Energy, Inc., and the Minnesota Department of Health (MDH).

At the end of December 2025, 55 casks were storing spent fuel inside the Independent Spent Fuel Storage Installation. The last cask to be moved to the Independent Spent Fuel Storage Installation was placed on June 12, 2025.

### Radiation Monitoring

MDH monitored radiation levels around the ISFSI from January 1995 to July 2015 using Pressurized Ionization Chambers (PICs). The PICs were located on the north and south end of the ISFSI. The PICs were replaced with new monitors that use a dual Geiger-Mueller (GM) tube system (a high range and low range GM tube). The new monitors are located in the same locations as the PICs. The new monitors were connected on September 30, 2015, and began logging data on October 20, 2015. The monitors average radiation level data over a 15-minute period and report that average value. This report contains the daily high and low of those readings as well as the average of those readings for each monitor.

### Analysis and Comments

Monitor 1 readings ranged from 0.117 mR/hr to 0.187 mR/hr. Monitor 2 lost contact February 2, 2024, and is being evaluated for replacement.

Additional monitoring data on radioactivity levels in other media (air, for example) are available in the annual Minnesota Department of Health "Environmental Radiation Data Report."

For more information, go to: [Environmental Monitoring](https://www.health.state.mn.us/communities/environment/radiation/monitor/index.html)  
(<https://www.health.state.mn.us/communities/environment/radiation/monitor/index.html>)

Minnesota Department of Health  
Radioactive Materials Unit  
[health.ram@state.mn.us](mailto:health.ram@state.mn.us)  
[www.health.state.mn.us](http://www.health.state.mn.us)

1/02/2026

*To obtain this information in a different format, call: 651-201-4400.*

**Table 1: December 2025 Data Report for Monitor 1**

Date	Maximum Reading (mR/hr)	Minimum Reading (mR/hr)	Average Reading (mR/hr)
12/1/2025	0.151	0.130	0.137
12/2/2025	0.163	0.127	0.137
12/3/2025	0.159	0.129	0.137
12/4/2025	0.157	0.126	0.136
12/5/2025	0.147	0.130	0.137
12/6/2025	0.150	0.130	0.136
12/7/2025	0.183	0.128	0.139
12/8/2025	0.152	0.128	0.139
12/9/2025	0.154	0.130	0.138
12/10/2025	0.187	0.120	0.133
12/11/2025	0.146	0.117	0.127
12/12/2025	0.161	0.119	0.128
12/13/2025	0.154	0.119	0.129
12/14/2025	0.169	0.120	0.130
12/15/2025	0.171	0.119	0.128
12/16/2025	0.156	0.119	0.131
12/17/2025	0.143	0.124	0.131
12/18/2025	0.146	0.127	0.134
12/19/2025	0.172	0.126	0.135
12/20/2025	0.160	0.124	0.134
12/21/2025	0.147	0.125	0.133
12/22/2025	0.145	0.124	0.133
12/23/2025	0.143	0.127	0.134
12/24/2025	0.145	0.127	0.134
12/25/2025	0.143	0.125	0.133
12/26/2025	0.147	0.121	0.134
12/27/2025	0.146	0.126	0.135
12/28/2025	0.148	0.128	0.137
12/29/2025	0.141	0.125	0.134
12/30/2025	0.143	0.126	0.135
12/31/2025	0.143	0.127	0.135