

**History of Health Risk Limits Rules, by Chemical, 1993 to present**

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
83-32-9	Acenaphthene	Acute									ND*
83-32-9	Acenaphthene	Short Term									ND*
83-32-9	Acenaphthene	Subchronic									200*
83-32-9	Acenaphthene	Chronic	400								100*
83-32-9	Acenaphthene	Cancer									NA*
103-90-2	Acetaminophen	Acute								200*	
103-90-2	Acetaminophen	Short Term								200*	
103-90-2	Acetaminophen	Subchronic								200*	
103-90-2	Acetaminophen	Chronic								200*	
103-90-2	Acetaminophen	Cancer								NA*	
34256-82-1	Acetochlor	Acute					40				ND*
34256-82-1	Acetochlor	Short Term					40				30*
34256-82-1	Acetochlor	Subchronic					40				30*
34256-82-1	Acetochlor	Chronic					9				20*
34256-82-1	Acetochlor	Cancer					NA				NA*
187022-11-3	Acetochlor ESA	Acute						ND			ND*
187022-11-3	Acetochlor ESA	Short Term						600			500*
187022-11-3	Acetochlor ESA	Subchronic						600			500*
187022-11-3	Acetochlor ESA	Chronic						300			300*
187022-11-3	Acetochlor ESA	Cancer						NA			NA*
194992-44-4	Acetochlor OXA	Acute						ND			ND*
194992-44-4	Acetochlor OXA	Short Term						200			100*
194992-44-4	Acetochlor OXA	Subchronic						200			100*
194992-44-4	Acetochlor OXA	Chronic						100			90*
194992-44-4	Acetochlor OXA	Cancer						NA			NA*
67-64-1	Acetone	Acute						ND*			
67-64-1	Acetone	Short Term						9,000*			
67-64-1	Acetone	Subchronic						8,000*			
67-64-1	Acetone	Chronic	700					4,000*			
67-64-1	Acetone	Cancer						NA*			
21145-77-7	6-Acetyl-1,1,2,4,4,7 hexamethyltetraline (AHTN)	Acute								ND*	
21145-77-7	6-Acetyl-1,1,2,4,4,7 hexamethyltetraline (AHTN)	Short Term								100*	
21145-77-7	6-Acetyl-1,1,2,4,4,7 hexamethyltetraline (AHTN)	Subchronic								30*	

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
21145-77-7	6-Acetyl-1,1,2,4,4,7 hexamethyltetraline (AHTN)	Chronic							20 *		
21145-77-7	6-Acetyl-1,1,2,4,4,7 hexamethyltetraline (AHTN)	Cancer							NA *		
79-06-1	Acrylamide	Acute									ND *
79-06-1	Acrylamide	Short Term									7 *
79-06-1	Acrylamide	Subchronic									7 *
79-06-1	Acrylamide	Chronic									7 *
79-06-1	Acrylamide	Cancer									0.2 *
15972-60-8	Alachlor	Acute					ND				ND *
15972-60-8	Alachlor	Short Term					200				100 *
15972-60-8	Alachlor	Subchronic					30				60 *
15972-60-8	Alachlor	Chronic		4		2	5				9 *
15972-60-8	Alachlor	Cancer					NA				NA *
116-06-3	Aldicarb	Chronic	1 *								
107-05-1	Allyl Chloride	Chronic		30 *							
120-12-7	Anthracene	Chronic	2,000 *								
7440-36-0	Antimony	Chronic	6 *								
1912-24-9	Atrazine	Chronic	20			3 *					
7440-39-3	Barium	Chronic	2,000 *								
25057-89-0	Bentazon	Acute									400 *
25057-89-0	Bentazon	Short Term									60 *
25057-89-0	Bentazon	Subchronic									50 *
25057-89-0	Bentazon	Chronic									30 *
25057-89-0	Bentazon	Cancer									NA *
71-43-2	Benzene	Acute					10 *				
71-43-2	Benzene	Short Term					10 *				
71-43-2	Benzene	Subchronic					3 *				
71-43-2	Benzene	Chronic					3 *				
71-43-2	Benzene	Cancer	10				2 *				
65-85-0	Benzoic Acid	Chronic	30,000 *								
7440-41-7	Beryllium	Cancer	0.08 *								
92-52-4	1,1-Biphenyl	Chronic	300 *								
111-44-4	Bis(2-chloroethyl) ether	Cancer	0.3 *								
542-88-1	Bis(2-chloromethyl) ether	Cancer	0.002 *								
80-05-7	Bisphenol A	Acute									ND *
80-05-7	Bisphenol A	Short Term									100 *

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
80-05-7	Bisphenol A	Subchronic								20 *	
80-05-7	Bisphenol A	Chronic								20 *	
80-05-7	Bisphenol A	Cancer								NA *	
7440-42-8	Boron	Chronic		600 (Repealed in 2011)							
75-27-4	Bromodichloromethane	Cancer	6 *								
75-25-2	Bromoform	Cancer	40 *								
74-83-9	Bromomethane	Chronic	10 *								
71-36-3	Butanol, 1-	Chronic	700 *								
85-68-7	Butyl benzyl phthalate	Acute								100 *	
85-68-7	Butyl benzyl phthalate	Short Term								100 *	
85-68-7	Butyl benzyl phthalate	Subchronic								100 *	
85-68-7	Butyl benzyl phthalate	Chronic	100							100 *	
85-68-7	Butyl benzyl phthalate	Cancer								NA *	
85-70-1	Butylphthalyl butylglycolate	Chronic	7000 *								
7440-43-9	Cadmium	Acute								5 *	
7440-43-9	Cadmium	Short Term								1 *	
7440-43-9	Cadmium	Subchronic								1 *	
7440-43-9	Cadmium	Chronic	4							0.5 *	
7440-43-9	Cadmium	Cancer								NA *	
298-46-4	Carbamazepine	Acute							40 *		
298-46-4	Carbamazepine	Short Term							40 *		
298-46-4	Carbamazepine	Subchronic							40 *		
298-46-4	Carbamazepine	Chronic							40 *		
298-46-4	Carbamazepine	Cancer							NA *		
75-15-0	Carbon Disulfide	Chronic	700 *								
56-23-5	Carbon tetrachloride	Acute							100 *		
56-23-5	Carbon tetrachloride	Short Term							3 *		
56-23-5	Carbon tetrachloride	Subchronic							3 *		
56-23-5	Carbon tetrachloride	Chronic							3 *		
56-23-5	Carbon tetrachloride	Cancer	3						1 *		
133-90-4	Chloramben	Chronic		100 *							
108-90-7	Chlorobenzene	Chronic	100								
67-66-3	Chloroform	Acute					ND				ND *
67-66-3	Chloroform	Short Term					30				20 *
67-66-3	Chloroform	Subchronic					30				20 *
67-66-3	Chloroform	Chronic					30				20 *

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
67-66-3	Chloroform	Cancer	60				NA				NA *
95-57-8	2-Chlorophenol	Chronic	30 *								
1897-45-6	Chloroethalonil	Cancer		30 *							
16065-83-1	Chromium III	Chronic		20,000 *							
18540-29-9	Chromium VI	Chronic	100 *								
210880-92-5, 205510-53-8	Clothianidin	Acute									ND *
210880-92-5, 205510-53-8	Clothianidin	Short Term									200 *
210880-92-5, 205510-53-8	Clothianidin	Subchronic									200 *
210880-92-5, 205510-53-8	Clothianidin	Chronic									200 *
210880-92-5, 205510-53-8	Clothianidin	Cancer									NA *
98-82-8	Cumene	Chronic	300 *								
21725-46-2	Cyanazine	Acute					2				3 *
21725-46-2	Cyanazine	Short Term					2				3 *
21725-46-2	Cyanazine	Subchronic					2				3 *
21725-46-2	Cyanazine	Chronic					1				1 *
21725-46-2	Cyanazine	Cancer					NA				NA
57-12-5	Cyanide, free	Chronic	100 *								
117-81-7	Di(2-ethylhexyl)phthalate	Acute									20 *
117-81-7	Di(2-ethylhexyl)phthalate	Short Term									20 *
117-81-7	Di(2-ethylhexyl)phthalate	Subchronic									20 *
117-81-7	Di(2-ethylhexyl)phthalate	Chronic				6					20 *
117-81-7	Di(2-ethylhexyl)phthalate	Cancer									7 *
124-48-1	Dibromochloromethane	Chronic	10 *								
106-93-4	1,2-Dibromoethane	Cancer	0.004 *								
84-74-2	Dibutyl phthalate	Acute									20 *
84-74-2	Dibutyl phthalate	Short Term									20 *
84-74-2	Dibutyl phthalate	Subchronic									20 *
84-74-2	Dibutyl phthalate	Chronic	700								20 *
84-74-2	Dibutyl phthalate	Cancer									NA *
1918-00-9	Dicamba	Chronic	200 *								
95-50-1	1,2-Dichlorobenzene	Chronic	600 *								
106-46-7	1,4-Dichlorobenzene	Cancer		10 *							

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
91-94-1	3,3'-Dichlorobenzidine	Cancer	0.8 *								
75-71-8	Dichlorodifluoromethane	Acute						ND *			
75-71-8	Dichlorodifluoromethane	Short Term						ND *			
75-71-8	Dichlorodifluoromethane	Subchronic						ND *			
75-71-8	Dichlorodifluoromethane	Chronic	1,000					700 *			
75-71-8	Dichlorodifluoromethane	Cancer						NA *			
72-54-8	p,p'-Dichlorodiphenyldichloroethane (DDD)	Cancer	1 *								
72-55-9	p,p'-Dichlorodiphenyldichloroethylene (DDE)	Cancer	1 *								
50-29-3	p,p'-Dichlorodiphenyltrichloroethane (DDT)	Cancer	1 *								
107-06-2	1,2-Dichloroethane (EDC)	Acute							ND *		
107-06-2	1,2-Dichloroethane (EDC)	Short Term							200 *		
107-06-2	1,2-Dichloroethane (EDC)	Subchronic							200 *		
107-06-2	1,2-Dichloroethane (EDC)	Chronic							60 *		
107-06-2	1,2-Dichloroethane (EDC)	Cancer	4						1 *		
75-34-3	Dichloroethane, 1,1-	Chronic		70 (Repealed)							
75-35-4	1,1-Dichloroethylene	Acute						ND *			
75-35-4	1,1-Dichloroethylene	Short Term						ND *			
75-35-4	1,1-Dichloroethylene	Subchronic						200 *			
75-35-4	1,1-Dichloroethylene	Chronic	6					200 *			
75-35-4	1,1-Dichloroethylene	Cancer						NA *			
156-59-2	cis-1,2-Dichloroethylene	Acute					ND				ND *
156-59-2	cis-1,2-Dichloroethylene	Short Term					70				20 *
156-59-2	cis-1,2-Dichloroethylene	Subchronic					70				10 *
156-59-2	cis-1,2-Dichloroethylene	Chronic	70				50				6 *
156-59-2	cis-1,2-Dichloroethylene	Cancer					NA				NA *
156-60-5	trans-1,2-Dichloroethylene	Acute							ND *		
156-60-5	trans-1,2-Dichloroethylene	Short Term							ND *		
156-60-5	trans-1,2-Dichloroethylene	Subchronic							200 *		
156-60-5	trans-1,2-Dichloroethylene	Chronic	100						40 *		
156-60-5	trans-1,2-Dichloroethylene	Cancer							NA *		
75-09-2	Dichloromethane	Chronic	50			5 *					
120-83-2	2,4-Dichlorophenol	Chronic	20								
94-75-7	2,4-Dichlorophenoxyacetic acid (2,4-D)	Acute									ND *
94-75-7	2,4-Dichlorophenoxyacetic acid (2,4-D)	Short Term									30 *

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
94-75-7	2,4-Dichlorophenoxyacetic acid (2,4-D)	Subchronic									30 *
94-75-7	2,4-Dichlorophenoxyacetic acid (2,4-D)	Chronic	70								30 *
94-75-7	2,4-Dichlorophenoxyacetic acid (2,4-D)	Cancer									ND *
78-87-5	1,2-Dichloropropane	Cancer		5 *							
542-75-6	1,3-Dichloropropene	Cancer		2 *							
60-57-1	Dieldrin	Acute					0.2				ND *
60-57-1	Dieldrin	Short Term					0.2				0.2 *
60-57-1	Dieldrin	Subchronic					0.2				0.2 *
60-57-1	Dieldrin	Chronic					0.2				0.2 *
60-57-1	Dieldrin	Cancer					0.006				0.006 *
84-66-2	Diethyl phthalate	Chronic	6,000 *								
134-62-3	N,N-Diethyl-meta-toluamide (DEET)	Acute									ND *
134-62-3	N,N-Diethyl-meta-toluamide (DEET)	Short Term									200 *
134-62-3	N,N-Diethyl-meta-toluamide (DEET)	Subchronic									200 *
134-62-3	N,N-Diethyl-meta-toluamide (DEET)	Chronic									200 *
134-62-3	N,N-Diethyl-meta-toluamide (DEET)	Cancer									NA *
87674-68-8	Dimethenamid	Acute									ND *
87674-68-8	Dimethenamid	Short Term									600 *
87674-68-8	Dimethenamid	Subchronic									600 *
87674-68-8	Dimethenamid	Chronic									300 *
87674-68-8	Dimethenamid	Cancer									NA *
163515-14-8	Dimethenamid-p	Acute									ND *
163515-14-8	Dimethenamid-p	Short Term									600 *
163515-14-8	Dimethenamid-p	Subchronic									600 *
163515-14-8	Dimethenamid-p	Chronic									300 *
163515-14-8	Dimethenamid-p	Cancer									NA *
131-11-3	Dimethyl phthalate	Chronic		70,000 *							
105-67-9	2,4-Dimethylphenol	Chronic	100 *								
51-28-5	2,4-Dinitrophenol	Chronic	10 *								
88-85-7	Dinoseb	Acute									ND *
88-85-7	Dinoseb	Short Term									8 *
88-85-7	Dinoseb	Subchronic									8 *
88-85-7	Dinoseb	Chronic									8 *
88-85-7	Dinoseb	Cancer									NA *
123-91-1	1,4-Dioxane	Acute								ND *	
123-91-1	1,4-Dioxane	Short Term								ND *	
123-91-1	1,4-Dioxane	Subchronic								300 *	

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
123-91-1	1,4-Dioxane	Chronic							100 *		
123-91-1	1,4-Dioxane	Cancer							1 *		
298-04-4	Disulfoton	Chronic		0.3 *							
759-94-4	S-Ethyl dipropylthiocarbamate (EPTC)	Acute									300 *
759-94-4	S-Ethyl dipropylthiocarbamate (EPTC)	Short Term									300 *
759-94-4	S-Ethyl dipropylthiocarbamate (EPTC)	Subchronic									90 *
759-94-4	S-Ethyl dipropylthiocarbamate (EPTC)	Chronic	200								40 *
759-94-4	S-Ethyl dipropylthiocarbamate (EPTC)	Cancer									NA *
100-41-4	Ethylbenzene	Acute						ND *			
100-41-4	Ethylbenzene	Short Term						50 *			
100-41-4	Ethylbenzene	Subchronic						50 *			
100-41-4	Ethylbenzene	Chronic	700					50 *			
100-41-4	Ethylbenzene	Cancer						NA *			
107-21-1	Ethylene glycol	Acute						4,000 *			
107-21-1	Ethylene glycol	Short Term						4,000 *			
107-21-1	Ethylene glycol	Subchronic						2,000 *			
107-21-1	Ethylene glycol	Chronic	10,000					2,000 *			
107-21-1	Ethylene glycol	Cancer						NA *			
206-44-0	Fluoranthene	Acute									ND *
206-44-0	Fluoranthene	Short Term									ND *
206-44-0	Fluoranthene	Subchronic									200 *
206-44-0	Fluoranthene	Chronic	300								70 *
206-44-0	Fluoranthene	Cancer									NA *
86-73-7	Fluorene	Chronic	300 *								
50-00-0	Formaldehyde	Chronic		1,000 *							
76-44-8	Heptachlor	Cancer	0.08 *								
1024-57-3	Heptachlor epoxide	Cancer	0.04 *								
118-74-1	Hexachlorobenzene	Cancer	0.2 *								
87-68-3	Hexachlorobutadiene	Chronic	1 *								
110-54-3	n-Hexane	Chronic		400 *							
78-59-1	Isophorone	Chronic	100 *								
330-55-2	Linuron	Chronic	1 *								
7439-96-5	Manganese	Chronic	100 *								
67-56-1	Methanol	Chronic		3,000 *							
94-74-6	2-Methyl-4-Chlorophenoxyacetic acid	Chronic	3 *								
78-93-3	Methyl ethyl ketone	Chronic		4,000 *							
108-10-1	Methyl isobutyl ketone	Chronic		300 *							

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
95-48-7	2-Methylphenol	Chronic	30 *								
108-39-4	3-Methylphenol	Chronic	30 *								
106-44-5	4-Methylphenol	Chronic		3 *							
51218-45-2	Metolachlor	Acute						400 *			
51218-45-2	Metolachlor	Short Term						400 *			
51218-45-2	Metolachlor	Subchronic						300 *			
51218-45-2	Metolachlor	Chronic	100					300 *			
51218-45-2	Metolachlor	Cancer						NA *			
171118-09-5	Metolachlor ESA	Acute						ND *			
171118-09-5	Metolachlor ESA	Short Term						ND *			
171118-09-5	Metolachlor ESA	Subchronic						4,000 *			
171118-09-5	Metolachlor ESA	Chronic						800 *			
171118-09-5	Metolachlor ESA	Cancer						NA *			
152019-73-3	Metolachlor OXA	Acute						ND *			
152019-73-3	Metolachlor OXA	Short Term						3,000 *			
152019-73-3	Metolachlor OXA	Subchronic						3,000 *			
152019-73-3	Metolachlor OXA	Chronic						800 *			
152019-73-3	Metolachlor OXA	Cancer						NA *			
21087-64-9	Metribuzin	Acute								30 *	
21087-64-9	Metribuzin	Short Term								10 *	
21087-64-9	Metribuzin	Subchronic								10 *	
21087-64-9	Metribuzin	Chronic	200							10 *	
21087-64-9	Metribuzin	Cancer								NA *	
91-20-3	Naphthalene	Acute								70 *	
91-20-3	Naphthalene	Short Term								70 *	
91-20-3	Naphthalene	Subchronic								70 *	
91-20-3	Naphthalene	Chronic		300						70 *	
91-20-3	Naphthalene	Cancer								NA *	
7440-02-0	Nickel	Chronic	100 *								
14797-55-8	Nitrate (as N)	Acute	10,000			10,000 *					
86-30-6	N-Nitrosodiphenylamine	Cancer	70 *								
87-86-5	Pentachlorophenol	Acute								7 *	
87-86-5	Pentachlorophenol	Short Term								7 *	
87-86-5	Pentachlorophenol	Subchronic								7 *	
87-86-5	Pentachlorophenol	Chronic	3			1				7 *	
87-86-5	Pentachlorophenol	Cancer								0.3 *	
375-73-5	Perfluorobutane sulfonate (PFBS)	Acute						ND *			



(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
375-73-5	Perfluorobutane sulfonate (PFBS)	Short Term						ND *			
375-73-5	Perfluorobutane sulfonate (PFBS)	Subchronic						9 *			
375-73-5	Perfluorobutane sulfonate (PFBS)	Chronic						7 *			
375-73-5	Perfluorobutane sulfonate (PFBS)	Cancer						NA *			
375-22-4	Perfluorobutyrate (PFBA)	Acute						ND			ND *
375-22-4	Perfluorobutyrate (PFBA)	Short Term						7			7 *
375-22-4	Perfluorobutyrate (PFBA)	Subchronic						7			7 *
375-22-4	Perfluorobutyrate (PFBA)	Chronic						7			7 *
375-22-4	Perfluorobutyrate (PFBA)	Cancer						NA			NA *
1763-23-1; 29081-56-9; 70225-14-8; 2795-39-3; 29457-72-5	Perfluorooctane sulfonate (acid) (PFOS)	Acute						ND *			
1763-23-1; 29081-56-9; 70225-14-8; 2795-39-3; 29457-72-5	Perfluorooctane sulfonate (acid) (PFOS)	Short Term						ND *			
1763-23-1; 29081-56-9; 70225-14-8; 2795-39-3; 29457-72-5	Perfluorooctane sulfonate (acid) (PFOS)	Subchronic						ND *			
1763-23-1; 29081-56-9; 70225-14-8; 2795-39-3; 29457-72-5	Perfluorooctane sulfonate (acid) (PFOS)	Chronic			0.5		0.3 *				
1763-23-1; 29081-56-9; 70225-14-8; 2795-39-3; 29457-72-5	Perfluorooctane sulfonate (acid) (PFOS)	Cancer						NA *			
335-67-1; 335-66-0; 3825-26-1; 2395-00-8;	Perfluorooctanoic acid (PFOA)	Acute						ND			NA *
335-93-3; 335-95-5 335-67-1; 335-66-0; 3825-26-1; 2395-00-8;	Perfluorooctanoic acid (PFOA)	Short Term						ND			0.035 *
335-93-3; 335-95-5 335-67-1; 335-66-0; 3825-26-1; 2395-00-8;	Perfluorooctanoic acid (PFOA)	Subchronic						ND			0.035 *
335-93-3; 335-95-5	Perfluorooctanoic acid (PFOA)	Chronic			0.3		0.3				0.035*

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
335-67-1; 335-66-0; 3825-26-1; 2395-00-8; 335-93-3; 335-95-5	Perfluorooctanoic acid (PFOA)	Cancer					NA				NA
108-95-2	Phenol	Chronic	4,000 *								
1918-02-1	Picloram	Chronic	500 *								
1336-36-3	Polychlorinated biphenyls	Cancer		0.04 *							
1610-18-0	Prometon	Chronic	100 *								
1918-16-7	Propachlor	Chronic	90 *								
93-72-1	2(2,4,5-trichlorophenoxy)Propionic acid	Chronic	50			50 *					
129-00-0	Pyrene	Acute									ND *
129-00-0	Pyrene	Short Term									ND *
129-00-0	Pyrene	Subchronic									90 *
129-00-0	Pyrene	Chronic	200								50 *
129-00-0	Pyrene	Cancer									NA *
7782-49-2	Selenium	Chronic	30 *								
7440-22-4	Silver	Chronic	30 *								
122-34-9	Simazine	Chronic		30		4 *					
87392-12-9	s-Metolachlor	Acute						400 *			
87392-12-9	s-Metolachlor	Short Term						400 *			
87392-12-9	s-Metolachlor	Subchronic						300 *			
87392-12-9	s-Metolachlor	Chronic						300 *			
87392-12-9	s-Metolachlor	Cancer						NA *			
57-68-1	Sulfamethazine	Acute									ND *
57-68-1	Sulfamethazine	Short Term									100 *
57-68-1	Sulfamethazine	Subchronic									100 *
57-68-1	Sulfamethazine	Chronic									100 *
57-68-1	Sulfamethazine	Cancer									NA *
1981-58-41	Sulfamethzine, sodium salt	Acute									ND *
1981-58-41	Sulfamethzine, sodium salt	Short Term									100 *
1981-58-41	Sulfamethzine, sodium salt	Subchronic									100 *
1981-58-41	Sulfamethzine, sodium salt	Chronic									100 *
1981-58-41	Sulfamethzine, sodium salt	Cancer									NA *
630-20-6	1,1,1,2-Tetrachloroethane	Chronic	70 *								
79-34-5	1,1,1,2-Tetrachloroethane	Cancer		2 *							
127-18-4	Tetrachloroethylene	Cancer		7		5*					
109-99-9	Tetrahydrofuran	Acute									ND *
109-99-9	Tetrahydrofuran	Short Term									600 *

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
109-99-9	Tetrahydrofuran	Subchronic									600 *
109-99-9	Tetrahydrofuran	Chronic									600 *
109-99-9	Tetrahydrofuran	Cancer									ND *
7440-28-0	Thallium	Chronic		0.6 *							
153719-23-4	Thiamethoxam	Acute									ND *
153719-23-4	Thiamethoxam	Short Term									400 *
153719-23-4	Thiamethoxam	Subchronic									200 *
153719-23-4	Thiamethoxam	Chronic									200 *
153719-23-4	Thiamethoxam	Cancer									NA *
7440-31-5	Tin	Chronic		4000 *							
108-88-3	Toluene	Acute						ND *			
108-88-3	Toluene	Short Term						200 *			
108-88-3	Toluene	Subchronic						200 *			
108-88-3	Toluene	Chronic	1000					200 *			
108-88-3	Toluene	Cancer						NA *			
8001-35-2	Toxaphene	Cancer	0.3							ND *	
120-82-1	1,2,4-Trichlorobenzene	Acute							100 *		
120-82-1	1,2,4-Trichlorobenzene	Short Term							100 *		
120-82-1	1,2,4-Trichlorobenzene	Subchronic							100 *		
120-82-1	1,2,4-Trichlorobenzene	Chronic							4 *		
120-82-1	1,2,4-Trichlorobenzene	Cancer							NA *		
71-55-6	1,1,1-Trichloroethane	Acute					ND				ND *
71-55-6	1,1,1-Trichloroethane	Short Term					ND				ND *
71-55-6	1,1,1-Trichloroethane	Subchronic					20,000				9,000 *
71-55-6	1,1,1-Trichloroethane	Chronic		600			9,000				5,000 *
71-55-6	1,1,1-Trichloroethane	Cancer					NA				NA*
79-00-5	1,1,2-Trichloroethane	Chronic		3 *							
79-01-6	Trichloroethylene	Acute								ND *	
79-01-6	Trichloroethylene	Short Term								0.4 *	
79-01-6	Trichloroethylene	Subchronic								0.4 *	
79-01-6	Trichloroethylene	Chronic								0.4 *	
79-01-6	Trichloroethylene	Cancer		30		5				2 *	
75-69-4	Trichlorofluoromethane	Chronic	2000 *								
88-06-2	2,4,6-Trichlorophenol	Cancer	30 *								
93-76-5	2,4,5-Trichlorophenoxyacetic acid	Chronic	70 *								
96-18-4	1,2,3-Trichloropropane	Acute								7 *	
96-18-4	1,2,3-Trichloropropane	Short Term								7 *	

(Note: This table contains only HRLs adopted into rule. Other more recent Health-Based Guidance might exist for a contaminant.

[Find current recommended water guidance on the Human Health-Based Water Guidance Table \(http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html\)](http://www.health.state.mn.us/divs/eh/risk/guidance/gw/table.html)

**Health Risk Limits value and the year adopted into rule.**

**The current value appears with an asterisk (\*) and previous value is superceded, unless otherwise noted. Values are in µg/L.**

CAS_Number	Primary Chemical Name	Duration	1993	1994	2007	HRLMCL	2009	2011	2013	2015	2018
96-18-4	1,2,3-Trichloropropane	Subchronic							7 *		
96-18-4	1,2,3-Trichloropropane	Chronic	40						7 *		
96-18-4	1,2,3-Trichloropropane	Cancer							0.003 *		
3380-34-5	Triclosan	Acute									ND *
3380-34-5	Triclosan	Short Term									50 *
3380-34-5	Triclosan	Subchronic									50 *
3380-34-5	Triclosan	Chronic									50 *
3380-34-5	Triclosan	Cancer									NA *
76-13-1	1,1,2-Trichloro-1,2,2-trifluoroethane	Chronic	200,000 *								
108-67-8	1,3,5-Trimethylbenzene	Acute					ND *				
108-67-8	1,3,5-Trimethylbenzene	Short Term					100 *				
108-67-8	1,3,5-Trimethylbenzene	Subchronic					100 *				
108-67-8	1,3,5-Trimethylbenzene	Chronic					100 *				
108-67-8	1,3,5-Trimethylbenzene	Cancer					NA *				
99-35-4	1,3,5-Trinitrobenzene	Chronic	0.3 *								
115-96-8	Tris(2-chloroethyl) phosphate (TCEP)	Acute							ND *		
115-96-8	Tris(2-chloroethyl) phosphate (TCEP)	Short Term							300 *		
115-96-8	Tris(2-chloroethyl) phosphate (TCEP)	Subchronic							200 *		
115-96-8	Tris(2-chloroethyl) phosphate (TCEP)	Chronic							200 *		
115-96-8	Tris(2-chloroethyl) phosphate (TCEP)	Cancer							5 *		
7440-62-2	Vanadium	Chronic		50 *							
75-01-4	Vinyl chloride	Acute					ND				ND *
75-01-4	Vinyl chloride	Short Term					ND				ND *
75-01-4	Vinyl chloride	Subchronic					80				90 *
75-01-4	Vinyl chloride	Chronic					10				10 *
75-01-4	Vinyl chloride	Cancer		0.2			0.2				0.2 *
1330-20-7	Xylenes	Acute						800 *			
1330-20-7	Xylenes	Short Term						300 *			
1330-20-7	Xylenes	Subchronic						300 *			
1330-20-7	Xylenes	Chronic		10000				300 *			
1330-20-7	Xylenes	Cancer						NA *			
7440-66-6	Zinc	Chronic		2000 *							

\* Current Value

NA = Not applicable, ND = Not Derived