

1, 4-Dioxane

SAMPLE COLLECTION PROCEDURE

Reference Method EPA 522 - Modified

**Read instructions carefully.
Samples may be rejected if ALL instructions are not followed.**

- **Sample bottle/preservative:**
 - 125-mL plastic bottle, Unpreserved (labeled with 1,4-Dioxane)
- **Shipping:**
 - Ship as soon as possible. The sample must arrive at the laboratory within 28 days.
- **Sampling locations:**
 - Sample at the first sample tap following treatment (treated water).
- **Prior to collection:**
 - At least 48 hours before sampling, remove ice packs from the sampling kit and freeze them.

Sample collection procedure:

1. Attach the pre-printed label to the bottle. If you do not have a pre-printed label, write the following information, using a ballpoint or permanent pen, on the generic bottle label: PWSID, PWS Name, and Location ID.
2. Remove any attachments from the sample tap.
3. Turn on the cold water tap and run for 4 to 5 minutes, or until the water temperature has stabilized, whichever is longer.
 - a. If there is only one faucet handle, make sure it is in the cold water position.
4. Reduce the flow of the water so the stream is steady and the width of a pencil.
5. Remove bottle cap and hold in hand. Do not touch the underside of the cap or the inside of the bottle.
6. Fill bottle to the shoulder. **DO NOT** overfill the container.
7. Screw the cap back on the bottle. Make sure the cap is on securely. Turn the bottle upside down to make sure the water does not leak.
8. Replace any attachments that were removed from the faucet or sample tap.
9. Upon completion of sampling, immediately (within 15 minutes) place sample in cooler with cooling material. Samples must remain chilled with cooling material until they have arrived at the laboratory.

Complete Chain-of-Custody form using indelible ink:

1. Name of the sample collector.

2. Date and Time collected (include a.m. or p.m.).
3. Field Number (MDH only, if applicable).
4. Put your signature on the "Relinquished By" line, including date and time. The date and time are when the sample is put in the return mailer and sealed. If samples pass hands prior to packaging, both parties must sign, date, and time. The first party would put down the date and time of the transfer, and the second party would put down the date and time the sample is packaged.

Deliver samples to the laboratory:

1. All sample containers must have cooling material present without evidence of sample freezing.
2. Sample temperature requirements depend on when the lab receives the sample:
 - a. Received 0 - 24 hours after collection: frozen or partially frozen (i.e. containing some solids) cooling material must be present. The temperature of the cooling material must be less than the temperature of the sample(s).
 - b. Received more than 24 hours after collection: frozen or partially frozen cooling material must be present. The temperature of the samples must be between 0.0 and 6.0° C.
3. Dropping off samples in person:
 - a. Frozen or partially frozen cooling material must be present. Laboratory staff must confirm the state of the cooling material. The temperature of the cooling material must be less than the temperature of the sample(s). Temperature requirements listed above must be followed.
 - b. Physically hand cooler/container containing samples and cooling material to laboratory sample receiving staff. Do not leave sample containers at the sample dock unattended.
4. Shipping samples:
 - a. Make sure the completed Chain-of-Custody is in the shipping container.
 - b. Add enough fresh, frozen cooling material to the mailing container to maintain appropriate sample temperature as indicated above, with no evidence of freezing.
 - c. Ship to the Public Health Laboratory using the applicable address. Because of the temperature requirement, it is recommended to ship using **guaranteed** overnight shipping.

Courier Service (Spee-Dee, UPS, FedEx, etc.)

Minnesota Department of Health
Public Health Laboratory
Environmental Sample Receiving
601 Robert Street North
Saint Paul, MN 55155-2531

U.S. Postal Service – 1st Class

Minnesota Department of Health
Public Health Laboratory
Environmental Sample Receiving
P.O. Box 64899
Saint Paul, MN 55164-0899

If you have questions, call 651-201-4700, or email health.drinkingwater@state.mn.us

Minnesota Department of Health Drinking Water
Protection
651-201-4700
health.drinkingwater@state.mn.us

www.health.state.mn.us

July 2020

To obtain this information in a different format, call
651-201-4700.