

MEDICARE/MEDICAID CERTIFICATION AND TRANSMITTAL

ID: E9S2

PART I - TO BE COMPLETED BY THE STATE SURVEY AGENCY

Facility ID: 00974

1. MEDICARE/MEDICAID PROVIDER NO. (L1) 245307 2.STATE VENDOR OR MEDICAID NO. (L2) 458430000	3. NAME AND ADDRESS OF FACILITY (L3) CORNERSTONE NSG & REHAB CENTER (L4) 416 SEVENTH STREET NORTHEAST (L5) BAGLEY, MN (L6) 56621	4. TYPE OF ACTION: <u>7</u> (L8) 1. Initial 2. Recertification 3. Termination 4. CHOW 5. Validation 6. Complaint 7. On-Site Visit 9. Other 8. Full Survey After Complaint										
5. EFFECTIVE DATE CHANGE OF OWNERSHIP (L9) 01/01/2008 6. DATE OF SURVEY 01/15/2019 (L34) 8. ACCREDITATION STATUS: _____ (L10) 0 Unaccredited 1 TJC 2 AOA 3 Other	7. PROVIDER/SUPPLIER CATEGORY <u>02</u> (L7) 01 Hospital 05 HHA 09 ESRD 13 PTIP 22 CLIA 02 SNF/NF/Dual 06 PRTF 10 NF 14 CORF 03 SNF/NF/Distinct 07 X-Ray 11 ICF/IID 15 ASC 04 SNF 08 OPT/SP 12 RHC 16 HOSPICE	FISCAL YEAR ENDING DATE: _____ (L35) 09/30										
11. LTC PERIOD OF CERTIFICATION From (a) : _____ To (b) : _____ 12.Total Facility Beds 47 (L18) 13.Total Certified Beds 47 (L17)	10.THE FACILITY IS CERTIFIED AS: X A. In Compliance With <u>And/Or Approved Waivers Of The Following Requirements:</u> Program Requirements Compliance Based On: _____ _____ 1. Acceptable POC _____ 2. Technical Personnel _____ 6. Scope of Services Limit _____ 3. 24 Hour RN _____ 7. Medical Director _____ 4. 7-Day RN (Rural SNF) _____ 8. Patient Room Size _____ 5. Life Safety Code _____ 9. Beds/Room B. Not in Compliance with Program Requirements and/or Applied Waivers: _____ * Code: A (L12)											
14. LTC CERTIFIED BED BREAKDOWN <table style="width:100%; border: none;"> <tr> <td style="text-align: center;">18 SNF</td> <td style="text-align: center;">18/19 SNF</td> <td style="text-align: center;">19 SNF</td> <td style="text-align: center;">ICF</td> <td style="text-align: center;">IID</td> </tr> <tr> <td style="text-align: center;">(L37)</td> <td style="text-align: center;">(L38)</td> <td style="text-align: center;">(L39)</td> <td style="text-align: center;">(L42)</td> <td style="text-align: center;">(L43)</td> </tr> </table>	18 SNF	18/19 SNF	19 SNF	ICF	IID	(L37)	(L38)	(L39)	(L42)	(L43)	15. FACILITY MEETS 1861 (e) (1) or 1861 (j) (1): _____ (L15)	
18 SNF	18/19 SNF	19 SNF	ICF	IID								
(L37)	(L38)	(L39)	(L42)	(L43)								

16. STATE SURVEY AGENCY REMARKS (IF APPLICABLE SHOW LTC CANCELLATION DATE):

17. SURVEYOR SIGNATURE <u>Lyla Burkman, Unit Supervisor</u> Date : 01/29/2019 (L19)	18. STATE SURVEY AGENCY APPROVAL <u>Joanne Simon, Enforcement Specialist</u> Date: 01/29/2019 (L20)
--	--

PART II - TO BE COMPLETED BY HCFA REGIONAL OFFICE OR SINGLE STATE AGENCY

19. DETERMINATION OF ELIGIBILITY <input checked="" type="checkbox"/> 1. Facility is Eligible to Participate <input type="checkbox"/> 2. Facility is not Eligible (L21)	20. COMPLIANCE WITH CIVIL RIGHTS ACT: _____	21. 1. Statement of Financial Solvency (HCFA-2572) 2. Ownership/Control Interest Disclosure Stmt (HCFA-1513) 3. Both of the Above : _____
22. ORIGINAL DATE OF PARTICIPATION 03/01/1986 (L24)	23. LTC AGREEMENT BEGINNING DATE (L41)	24. LTC AGREEMENT ENDING DATE (L25)
25. LTC EXTENSION DATE: _____ (L27)	27. ALTERNATIVE SANCTIONS A. Suspension of Admissions: _____ (L44) B. Rescind Suspension Date: _____ (L45)	
26. TERMINATION ACTION: _____ (L30) <u>VOLUNTARY</u> 00 01-Merger, Closure 02-Dissatisfaction W/ Reimbursement 03-Risk of Involuntary Termination 04-Other Reason for Withdrawal <u>INVOLUNTARY</u> 05-Fail to Meet Health/Safety 06-Fail to Meet Agreement <u>OTHER</u> 07-Provider Status Change 00-Active	28. TERMINATION DATE: 29. INTERMEDIARY/CARRIER NO. 03001 (L28) (L31)	
31. RO RECEIPT OF CMS-1539 (L32)	32. DETERMINATION OF APPROVAL DATE 01/29/2019 (L33)	
DETERMINATION APPROVAL		



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered
January 28, 2019

Administrator
Cornerstone Nsg & Rehab Center
416 Seventh Street Northeast
Bagley, MN 56621

RE: Project Number S5307031

Dear Administrator:

On January 2, 2019, we informed you that we would recommend enforcement remedies based on the deficiencies cited by this Department for, a standard survey, completed on December 19, 2018. This survey found the most serious deficiencies to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F) whereby corrections were required.

On January 15, 2019, the Minnesota Department of Health, completed a Post Certification Revisit (PCR) by review of your plan of correction and on January 25, 2019 the Minnesota Department of Public Safety completed a PCR to verify that your facility had achieved and maintained compliance with federal certification deficiencies issued pursuant to a standard survey, completed on December 19, 2018. We presumed, based on your plan of correction, that your facility had corrected these deficiencies as of January 25, 2019. Based on our PCR, we have determined that your facility has corrected the deficiencies issued pursuant to our standard survey, completed on December 19, 2018, effective January 25, 2019 and therefore remedies outlined in our letter to you dated January 2, 2019, will not be imposed.

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Sincerely,

A handwritten signature in black ink, appearing to read 'Joanne Simon', with a horizontal line extending to the right.

Joanne Simon, Enforcement Specialist
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: 651-201-4161 Fax: 651-215-9697
Email: joanne.simon@state.mn.us

cc: Licensing and Certification File

Electronically delivered

January 28, 2019

CMS Certification Number (CCN): 245307

Administrator
Cornerstone Nsg & Rehab Center
416 Seventh Street Northeast
Bagley, MN 56621

Dear Administrator:

The Minnesota Department of Health assists the Centers for Medicare and Medicaid Services (CMS) by surveying skilled nursing facilities and nursing facilities to determine whether they meet the requirements for participation. To participate as a skilled nursing facility in the Medicare program or as a nursing facility in the Medicaid program, a provider must be in substantial compliance with each of the requirements established by the Secretary of Health and Human Services found in 42 CFR part 483, Subpart B.

Based upon your facility being in substantial compliance, we are recommending to CMS that your facility be recertified for participation in the Medicare and Medicaid program.

Effective January 25, 2019 the above facility is certified for:

47 Skilled Nursing Facility/Nursing Facility Beds

Your facility's Medicare approved area consists of all 47 skilled nursing facility beds.

You should advise our office of any changes in staffing, services, or organization, which might affect your certification status.

If, at the time of your next survey, we find your facility to not be in substantial compliance your Medicare and/or Medicaid provider agreement may be subject to non-renewal or termination.

Please contact me if you have any questions.

Sincerely,



Joanne Simon, Enforcement Specialist
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: 651-201-4161 Fax: 651-215-9697
Email: joanne.simon@state.mn.us

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/09/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
E 000	Initial Comments	E 000			
F 000	INITIAL COMMENTS	F 000			
F 637 SS=D	<p>Comprehensive Assessment After Significant Chg CFR(s): 483.20(b)(2)(ii)</p> <p>§483.20(b)(2)(ii) Within 14 days after the facility determines, or should have determined, that there has been a significant change in the resident's physical or mental condition. (For purpose of this section, a "significant change" means a major decline or improvement in the resident's status that will not normally resolve itself without further intervention by staff or by</p>	F 637		1/10/19	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Electronically Signed

01/08/2019

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 637	<p>Continued From page 1</p> <p>implementing standard disease-related clinical interventions, that has an impact on more than one area of the resident's health status, and requires interdisciplinary review or revision of the care plan, or both.)</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on interview and document review, the facility failed to complete a Significant Change in Status Assessment (SCSA) when two or more areas of change in resident status were noted on the Minimum Data Set (MDS) for 1 of 2 residents (R292) reviewed for pressure ulcers.</p> <p>Findings include:</p> <p>R292's annual Minimum Data Set (MDS) dated 9/2/18, identified R292 was cognitively intact and had diagnoses which included Multiple sclerosis (a progressive potentially disabling disease of the brain and spinal cord), paraplegia (impairment of the lower extremities) and neurogenic bladder (bladder dysfunction due to nervous system disorder). The MDS also indicated R292 was always incontinent of urine with no appliances used, and had no unhealed pressure ulcers.</p> <p>R292's quarterly MDS dated 11/23/18, identified R292 had moderate cognitive impairment, had an indwelling catheter and was always incontinent of urine. R292's MDS further identified she had one unhealed stage 3 pressure ulcer.</p> <p>Review of the above assessments identified a decline in cognition from cognitively intact to moderately impaired and a change from always incontinent with the use of no appliances, to always incontinent of urine and the use of an indwelling catheter. In addition R292's</p>	F 637	<p>R292 MDS (Minimum Data Set) dated 9/2/18 and 11/23/18 were reviewed and a Significant Change in Status Assessment was completed on R292 with an ARD of 12/21/18.</p> <p>MDS Tracking Sheets have been reviewed for all current residents in the facility for the last quarter with no Significant Changes noted, with the exception of those 6 residents who had a Significant Change in Status Assessment determined to be completed.</p> <p>MDS Coordinators were re-educated 1/8/19 on the criteria for OBRA assessments per the RAI Manual criteria, with focus on Significant Change in Status Assessments. All residents MDS criteria will continue to be coded and tracked on MDS tracking sheets as well as compared to previous MDS for significant change in status. Staff will continue to monitor charts, monitor resident alerts and messages as well as communicate with floor staff on any resident changes. If a significant change is suspected, monitoring will be completed by the MDS Coordinator to determine if the criteria for a Significant Change in Status Assessment is necessary.</p> <p>The MDS Coordinator or designee shall complete audits using MDS tracking sheets and review of past and current</p>		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/09/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING _____ B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
F 637	<p>Continued From page 2</p> <p>assessments indicated a change from no unhealed pressure ulcers to an unhealed stage three pressure ulcer.</p> <p>On 12/19/18, at 9:00 a.m. MDS coordinator (MDSC)-A stated her usual practice was to complete a SCSA if two or more changes occurred for the resident. MDSC-A reviewed the annual MDS of 9/2/18, and quarterly MDS of 11/23/18, and indicated R292's cognition fluctuated from cognitively intact to moderate cognitive impairment therefore would not consider this a change. MDSC-A indicated she was aware of the urinary catheter placement and confirmed this was one change from the annual MDS of 9/2/18. In addition, MDSC-A stated she had assumed that the pressure ulcer had been identified on the previous annual MDS of 9/2/18, and completed by the previous MDS coordinator as the tracking form the facility used for MDS changes identified R292 had a wound at the time of both the annual and quarterly assessment. MDSC-A confirmed she should have completed a SCSA due to the two changes identified for R292 which included the use of an indwelling catheter and the stage 3 pressure ulcer.</p> <p>On 12/19/18, at 10:48 a.m. the director of nursing (DON) reviewed R292's annual and quarterly MDS and confirmed a SCSA should have been completed at the time of the quarterly assessment. The DON indicated the facility did not have a policy or procedure for completing the SCSA for residents, rather they followed the Resident Assessment Instrument (RAI) Manuel.</p>	F 637	OBRA Assessments for 3 months, which shall include all residents, to ensure RAI criteria is being followed for Significant Change in Status Assessments. All findings shall be reported to the Quality Assurance Performance Improvement (QAPI) committee for further review, recommendations and monitoring.		



Protecting, Maintaining and Improving the Health of All Minnesotans

Electronically delivered

January 2, 2019

Administrator
Cornerstone Nsg & Rehab Center
416 Seventh Street Northeast
Bagley, MN 56621

RE: Project Number S5307031

Dear Administrator:

On December 19, 2018, a standard survey was completed at your facility by the Minnesota Departments of Health and Public Safety, to determine if your facility was in compliance with Federal participation requirements for skilled nursing facilities and/or nursing facilities participating in the Medicare and/or Medicaid programs.

This survey found the most serious deficiencies in your facility to be widespread deficiencies that constituted no actual harm with potential for more than minimal harm that was not immediate jeopardy (Level F), as evidenced by the electronically attached CMS-2567 whereby corrections are required.

OPPORTUNITY TO CORRECT - DATE OF CORRECTION

The date by which the deficiencies must be corrected to avoid imposition of remedies is January 28, 2019.

ELECTRONIC PLAN OF CORRECTION (ePoC)

Within **ten (10) calendar days** after your receipt of this notice, you must submit an acceptable plan of correction (ePOC) for the deficiencies cited. An acceptable ePOC will serve as your allegation of compliance. Upon receipt of an acceptable ePOC, we will authorize a revisit to your facility to determine if substantial compliance has been achieved.

To be acceptable, a provider's ePOC must include the following:

- How corrective action will be accomplished for those residents found to have been affected by the deficient practice.
- How the facility will identify other residents having the potential to be affected by the same deficient practice.
- What measures will be put into place, or systemic changes made, to ensure that the deficient practice will not recur.
- How the facility will monitor its corrective actions to ensure that the deficient practice is being corrected and will not recur.
- The date that each deficiency will be corrected.
- An electronic acknowledgement signature and date by an official facility representative.

The state agency may, in lieu of a revisit, determine correction and compliance by accepting the facility's ePoC if the ePoC is reasonable, addresses the problem and provides evidence that the corrective action has occurred.

If an acceptable ePoC is not received within 10 calendar days from the receipt of this letter, we will recommend to the CMS Region V Office that one or more of the following remedies be imposed:

- Discretionary denial of payment for new Medicare and Medicaid admissions (42 CFR 88.417 (a));
- Per day civil money penalty (42 CFR 488.430 through 488.444).

Failure to submit an acceptable ePoC could also result in the termination of your facility's Medicare and/or Medicaid agreement (488.456(b)).

DEPARTMENT CONTACT

Questions regarding this letter and all documents submitted as a response to the resident care deficiencies (those preceded by an "F" tag) and emergency preparedness deficiencies (those preceded by an "E" tag), i.e., the plan of correction should be directed to:

Lyla Burkman, Unit Supervisor
Bemidji Survey Team
Licensing and Certification Program
Health Regulation Division
Minnesota Department of Health
705 5th Street Northwest, Suite A
Bemidji, Minnesota 56601-2933
Email: lyla.burkman@state.mn.us
Phone: (218) 308-2104
Fax: (218) 308-2122

PRESUMPTION OF COMPLIANCE - CREDIBLE ALLEGATION OF COMPLIANCE

The facility's ePoC will serve as your allegation of compliance upon the Department's acceptance. In order for your allegation of compliance to be acceptable to the Department, the ePoC must meet the criteria listed in the plan of correction section above. You will be notified by the Minnesota Department of Health, Licensing and Certification Program staff and/or the Department of Public Safety, State Fire Marshal Division staff, if your ePoC for the respective deficiencies (if any) is acceptable.

VERIFICATION OF SUBSTANTIAL COMPLIANCE

Upon receipt of an acceptable ePoC, a Post Certification Revisit (PCR), of your facility will be conducted to validate that substantial compliance with the regulations has been attained in accordance with your verification.

If substantial compliance has been achieved, certification of your facility in the Medicare and/or Medicaid program(s) will be continued and remedies will not be imposed. Compliance is certified as of the latest correction date on the approved ePoC, unless it is determined that either correction actually occurred between the latest correction date on the ePoC and the date of the first revisit, or correction occurred sooner than the latest correction date on the ePoC.

FAILURE TO ACHIEVE SUBSTANTIAL COMPLIANCE BY THE THIRD OR SIXTH MONTH AFTER THE LAST DAY OF THE SURVEY

If substantial compliance with the regulations is not verified by March 19, 2019 (three months after the identification of noncompliance), the CMS Region V Office must deny payment for new admissions as mandated by the Social Security Act (the Act) at Sections 1819(h)(2)(D) and 1919(h)(2)(C) and Federal regulations at 42 CFR Section 488.417(b).

In addition, if substantial compliance with the regulations is not verified by June 19, 2019 (six months after the identification of noncompliance) your provider agreement will be terminated. This action is mandated by the Social Security Act at Sections 1819(h)(2)(C) and 1919(h)(3)(D) and Federal regulations at 42 CFR Sections 488.412 and 488.456.

Please note that this notice does not constitute formal notice of imposition of alternative remedies or termination of your provider agreement. Should the Centers for Medicare & Medicaid Services determine that termination or any other remedy is warranted, it will provide you with a separate formal notification of that determination.

INFORMAL DISPUTE RESOLUTION (IDR) / INDEPENDENT INFORMAL DISPUTE RESOLUTION (IIDR)

In accordance with 42 CFR 488.331, you have one opportunity to question cited deficiencies through an informal dispute resolution process. You are required to send your written request, along with the specific deficiencies being disputed, and an explanation of why you are disputing those deficiencies, to:

Nursing Home Informal Dispute Process
Minnesota Department of Health
Health Regulation Division
P.O. Box 64900
St. Paul, Minnesota 55164-0900

This request must be sent within the same ten days you have for submitting an ePoC for the cited deficiencies. All requests for an IDR or IIDR of federal deficiencies must be submitted via the web at: http://www.health.state.mn.us/divs/fpc/profinfo/ltc/ltc_idr.cfm

You must notify MDH at this website of your request for an IDR or IIDR within the 10 calendar day period allotted for submitting an acceptable electronic plan of correction. A copy of the Department's informal dispute resolution policies are posted on the MDH Information Bulletin website at: <http://www.health.state.mn.us/divs/fpc/profinfo/infobul.htm>

Cornerstone Nsg & Rehab Center

January 2, 2019

Page 4

Please note that the failure to complete the informal dispute resolution process will not delay the dates specified for compliance or the imposition of remedies.

Questions regarding all documents submitted as a response to the Life Safety Code deficiencies (those preceded by a "K" tag), i.e., the plan of correction, request for waivers, should be directed to:

Mr. Tom Linhoff, Fire Safety Supervisor
Health Care Fire Inspections
Minnesota Department of Public Safety
State Fire Marshal Division
445 Minnesota Street, Suite 145
St. Paul, Minnesota 55101-5145
Email: tom.linhoff@state.mn.us
Telephone: (651) 430-3012
Fax: (651) 215-0525

Please note, it is your responsibility to share the information contained in this letter and the results of this visit with the President of your facility's Governing Body.

Feel free to contact me if you have questions.

Sincerely,



Joanne Simon, Enforcement Specialist
Minnesota Department of Health
Licensing and Certification Program
Program Assurance Unit
Health Regulation Division
Telephone: 651-201-4161 Fax: 651-215-9697
Email: joanne.simon@state.mn.us

cc: Licensing and Certification File

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

F5307029

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety. At the time of this survey, Cornerstone Nursing and Rehab Center was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99 Health Care Facilities Code</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota Street, Suite 145 St. Paul, MN 55101</p>	K 000		

EPOC

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE
Electronically Signed

TITLE

(X6) DATE
01/09/2019

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 Or by e-mail to: FM.HC.Inspections@state.mn.us THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION: 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency The facility was inspected as two separate buildings due to the construction types and the entire facility is considered existing as of November 1, 2016 The Cornerstone Nursing and Rehab Center was built in 1968, is a 1-story building, with a partial basement and was determined to be of a Type II (222) construction. A 1 story building without basement addition was added in 2015 and was determined to be of Type V(111) construction. In 2016 an addition was added to the end of the west wing and was determined to be of a Type V (111) construction and is separated by a 2 hour fire barrier and the 1968 building was totally remodeled. The facility is completely sprinkler protected with an automatic sprinkler system installed in accordance with NFPA 13 Standard for the Installation of Sprinkler Systems. The facility has a fire alarm system with corridor smoke detection	K 000			

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 2 with additional automatic smoke detection in all common use spaces installed in accordance with NFPA 72 "The National Fire Alarm Code". The facility has a capacity of 47 beds and had a census of 46 at the time of the survey.	K 000		
K 321 SS=D	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: Hazardous Areas - Enclosure CFR(s): NFPA 101 Hazardous Areas - Enclosure Hazardous areas are protected by a fire barrier having 1-hour fire resistance rating (with 3/4 hour fire rated doors) or an automatic fire extinguishing system in accordance with 8.7.1 or 19.3.5.9. When the approved automatic fire extinguishing system option is used, the areas shall be separated from other spaces by smoke resisting partitions and doors in accordance with 8.4. Doors shall be self-closing or automatic-closing and permitted to have nonrated or field-applied protective plates that do not exceed 48 inches from the bottom of the door. Describe the floor and zone locations of hazardous areas that are deficient in REMARKS. 19.3.2.1, 19.3.5.9 Area Automatic Sprinkler Separation N/A a. Boiler and Fuel-Fired Heater Rooms b. Laundries (larger than 100 square feet) c. Repair, Maintenance, and Paint Shops d. Soiled Linen Rooms (exceeding 64 gallons) e. Trash Collection Rooms (exceeding 64 gallons)	K 321		1/9/19

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 321	Continued From page 3 f. Combustible Storage Rooms/Spaces (over 50 square feet) g. Laboratories (if classified as Severe Hazard - see K322) This REQUIREMENT is not met as evidenced by: Based on observation and staff interview the facility to maintain a hazardous storage room in accordance with the 2012 Life Safety Code (NFPA 101) section 19.3.2.1.3. This deficient condition could allow smoke or fire to enter the corridor making it untenable and affect the quick and efficient exiting for an undetermined amount of staff and visitors. Findings include: On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed a wall penetration by a heating duct that was not properly fire stopped in a one hour storage room in the basement. This deficient condition was confirmed by the Environmental Service Director.	K 321	The wall penetration near the heating duct in the basement storage room was sealed to ensure appropriate protection by a 1-hour fire resistance rated fire barrier by the Environmental Services Supervisor. The Environmental Services Supervisor shall be responsible for monitoring of any other potential wall penetrations and proper protection any time changes are made to the facility's physical structure.		
K 324 SS=D	Cooking Facilities CFR(s): NFPA 101 Cooking Facilities Cooking equipment is protected in accordance with NFPA 96, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations, unless: * residential cooking equipment (i.e., small appliances such as microwaves, hot plates, toasters) are used for food warming or limited cooking in accordance with 18.3.2.5.2, 19.3.2.5.2 * cooking facilities open to the corridor in smoke	K 324		1/16/19	

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 324	Continued From page 4 compartments with 30 or fewer patients comply with the conditions under 18.3.2.5.3, 19.3.2.5.3, or * cooking facilities in smoke compartments with 30 or fewer patients comply with conditions under 18.3.2.5.4, 19.3.2.5.4. Cooking facilities protected according to NFPA 96 per 9.2.3 are not required to be enclosed as hazardous areas, but shall not be open to the corridor. 18.3.2.5.1 through 18.3.2.5.4, 19.3.2.5.1 through 19.3.2.5.5, 9.2.3, TIA 12-2 This REQUIREMENT is not met as evidenced by: Based on observation and staff interview the facility failed to install the protection devices of the cooking equipment as stated in the Life Safety Code (NFPA 101) 2012 edition section 9.2.3 & NFPA 96 section 10.5.1. This deficient practice could allow for the spread of fire if staff could not reach the device, affecting an undetermined amount of staff and visitors. Findings include: On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed the ANSUL pull station was located closer than 10 feet from the cooking appliance. This deficient condition was confirmed by the Environmental Service Director.	K 324	The ANSUL pull station in the main kitchen shall be relocated and appropriate placed, by Blackduck Fire & Safety, to ensure there is greater than 10 feet distance from the cooking appliance to ensure ease of reach for staff. The Environmental Services Supervisor shall be responsible for monitoring the system by ensuring it is maintained and inspected every 6 months.		
K 351 SS=F	Sprinkler System - Installation CFR(s): NFPA 101	K 351		1/25/19	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 351	<p>Continued From page 5</p> <p>Spinkler System - Installation 2012 EXISTING Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems. In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers. In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems. 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) This REQUIREMENT is not met as evidenced by: Based on observation and staff interview the facility failed to install The sprinkler system in accordance with the 2012 edition of the Life Safety Code (NFPA 101) sections 19.3.5.1, 9.7.1.1 and the 2010 edition of NFPA 13, The Standard for the Installation of Sprinkler Systems. This deficient practice could affect of 9 of 47 residents and an undetermined amount of staff and visitors.</p> <p>Findings include:</p> <p>On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed the main fire sprinkler riser was repaired incorrectly, it did not have a double check valve installed between the city input and connection to the system and</p>	K 351	<p>A double check valve shall be installed on the main fire sprinkler riser between the city input and the connection to the system by Johnson Controls (SimplexGrinnell). The TCU wing currently has a shut off valve on the TCU wing valve assembly. The Environmental Services Supervisor shall be responsible for monitoring compliance and safety when changes are made to the facility fire sprinkler system by maintaining annual sprinkler inspections are completed.</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____	(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 351	Continued From page 6 did not have a shut off valve for the horizontal branch for the TCU wing. This deficient condition was confirmed by the Environmental Service Director.	K 351		
K 918 SS=F	Electrical Systems - Essential Electric Syste CFR(s): NFPA 101 Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked, readily identifiable, and separate from normal power circuits. Minimizing the possibility of damage of the emergency power	K 918		1/25/19

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 918	<p>Continued From page 7</p> <p>source is a design consideration for new installations. 6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>This REQUIREMENT is not met as evidenced by: Based on observations and staff interview the facility failed to provide emergency features in accordance with the 2012 edition of the Life Safety Code (NFPA 101) section 9.1.3.1 and the 2010 edition of NFPA 110 section 5.6.5.6, the Standard for Emergency and Standby Power Systems. This deficient practice could affect the safety of an undetermined amount of staff if the generator failed to shut down during an emergency.</p> <p>Findings include:</p> <p>On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed there was no emergency stop for the generator on the outside of the enclosure.</p> <p>This deficient condition was confirmed by the Environmental Service Director.</p>	K 918	<p>An emergency shut off switch has been ordered and shall be installed on the outside of the enclosure of the facility generator by an electrical contractor. The Environmental Services Supervisor shall monitor proper maintenance and testing of the generator weekly, monthly, and annually to ensure compliance and safety in the event of an emergency.</p>		

Fh307029

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____	(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>FIRE SAFETY</p> <p>THE FACILITY'S POC WILL SERVE AS YOUR ALLEGATION OF COMPLIANCE UPON THE DEPARTMENT'S ACCEPTANCE. YOUR SIGNATURE AT THE BOTTOM OF THE FIRST PAGE OF THE CMS-2567 WILL BE USED AS VERIFICATION OF COMPLIANCE.</p> <p>UPON RECEIPT OF AN ACCEPTABLE POC, AN ONSITE REVISIT OF YOUR FACILITY MAY BE CONDUCTED TO VALIDATE THAT SUBSTANTIAL COMPLIANCE WITH THE REGULATIONS HAS BEEN ATTAINED IN ACCORDANCE WITH YOUR VERIFICATION.</p> <p>A Life Safety Code Survey was conducted by the Minnesota Department of Public Safety. At the time of this survey, Cornerstone Nursing and Rehab Center was found not in compliance with the requirements for participation in Medicare/Medicaid at 42 CFR, Subpart 483.70(a), Life Safety from Fire, and the 2012 edition of National Fire Protection Association (NFPA) Standard 101, Life Safety Code (LSC), Chapter 19 Existing Health Care and the 2012 edition of NFPA 99 Health Care Facilities Code</p> <p>PLEASE RETURN THE PLAN OF CORRECTION FOR THE FIRE SAFETY DEFICIENCIES (K TAGS) TO:</p> <p>Health Care Fire Inspections State Fire Marshal Division 445 Minnesota Street, Suite 145 St. Paul, MN 55101</p>	K 000		

EPOC

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE: **Electronically Signed** TITLE: _____ (X6) DATE: **01/09/2019**

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>Continued From page 1 Or by e-mail to: FM.HC.Inspections@state.mn.us</p> <p>THE PLAN OF CORRECTION FOR EACH DEFICIENCY MUST INCLUDE ALL OF THE FOLLOWING INFORMATION:</p> <ol style="list-style-type: none"> 1. A description of what has been, or will be, done to correct the deficiency. 2. The actual, or proposed, completion date. 3. The name and/or title of the person responsible for correction and monitoring to prevent a reoccurrence of the deficiency <p>The facility was inspected as two separate buildings due to the construction types and the entire facility is considered existing as of November 1, 2016</p> <p>The Cornerstone Nursing and Rehab Center was built in 1968, is a 1-story building, with a partial basement and was determined to be of a Type II (222) construction. A 1 story building without basement addition was added in 2015 and was determined to be of Type V(111) construction. In 2016 an addition was added to the end of the west wing and was determined to be of a Type V (111) construction and is separated by a 2 hour fire barrier and the 1968 building was totally remodeled.</p> <p>The facility is completely sprinkler protected with an automatic sprinkler system installed in accordance with NFPA 13 Standard for the Installation of Sprinkler Systems. The facility has a fire alarm system with corridor smoke detection</p>	K 000		

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 2 with additional automatic smoke detection in all common use spaces installed in accordance with NFPA 72 "The National Fire Alarm Code". The facility has a capacity of 47 beds and had a census of 46 at the time of the survey.	K 000			
K 222 SS=E	The requirement at 42 CFR, Subpart 483.70(a) is NOT MET as evidenced by: Egress Doors CFR(s): NFPA 101 Egress Doors Doors in a required means of egress shall not be equipped with a latch or a lock that requires the use of a tool or key from the egress side unless using one of the following special locking arrangements: CLINICAL NEEDS OR SECURITY THREAT LOCKING Where special locking arrangements for the clinical security needs of the patient are used, only one locking device shall be permitted on each door and provisions shall be made for the rapid removal of occupants by: remote control of locks; keying of all locks or keys carried by staff at all times; or other such reliable means available to the staff at all times. 18.2.2.2.5.1, 18.2.2.2.6, 19.2.2.2.5.1, 19.2.2.2.6 SPECIAL NEEDS LOCKING ARRANGEMENTS Where special locking arrangements for the safety needs of the patient are used, all of the Clinical or Security Locking requirements are being met. In addition, the locks must be electrical locks that fail safely so as to release upon loss of power to the device; the building is protected by a supervised automatic sprinkler	K 222		1/4/19	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____	(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 222	<p>Continued From page 3</p> <p>system and the locked space is protected by a complete smoke detection system (or is constantly monitored at an attended location within the locked space); and both the sprinkler and detection systems are arranged to unlock the doors upon activation. 18.2.2.2.5.2, 19.2.2.2.5.2, TIA 12-4</p> <p>DELAYED-EGRESS LOCKING ARRANGEMENTS Approved, listed delayed-egress locking systems installed in accordance with 7.2.1.6.1 shall be permitted on door assemblies serving low and ordinary hazard contents in buildings protected throughout by an approved, supervised automatic fire detection system or an approved, supervised automatic sprinkler system. 18.2.2.2.4, 19.2.2.2.4</p> <p>ACCESS-CONTROLLED EGRESS LOCKING ARRANGEMENTS Access-Controlled Egress Door assemblies installed in accordance with 7.2.1.6.2 shall be permitted. 18.2.2.2.4, 19.2.2.2.4</p> <p>ELEVATOR LOBBY EXIT ACCESS LOCKING ARRANGEMENTS Elevator lobby exit access door locking in accordance with 7.2.1.6.3 shall be permitted on door assemblies in buildings protected throughout by an approved, supervised automatic fire detection system and an approved, supervised automatic sprinkler system. 18.2.2.2.4, 19.2.2.2.4</p> <p>This REQUIREMENT is not met as evidenced by: Based on observation and staff interview the facility failed to ensure the proper labeling of exit door locking devices per NFPA 101, Life Safety Code, 2012 edition section 7.2.1.6.1 & 19.2.2.2.4. This deficient practice could affect 7 of 47</p>	K 222	<p>The Environmental Services Supervisor properly placed a sign/label on the exit discharge door with the locking device in the memory care. The Environmental Services Supervisor shall be responsible</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 222	Continued From page 4 residents and an undetermined amount of staff and visitors. Findings include: On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed the exit discharge in the memory care has a delayed egress on the door that was not properly labeled. This deficient condition was confirmed by the Environmental Service Director.	K 222	for monitoring all egress doors by completing monthly door security inspections for compliance and safety.	
K 351 SS=F	Sprinkler System - Installation CFR(s): NFPA 101 Spinkler System - Installation 2012 EXISTING Nursing homes, and hospitals where required by construction type, are protected throughout by an approved automatic sprinkler system in accordance with NFPA 13, Standard for the Installation of Sprinkler Systems. In Type I and II construction, alternative protection measures are permitted to be substituted for sprinkler protection in specific areas where state or local regulations prohibit sprinklers. In hospitals, sprinklers are not required in clothes closets of patient sleeping rooms where the area of the closet does not exceed 6 square feet and sprinkler coverage covers the closet footprint as required by NFPA 13, Standard for Installation of Sprinkler Systems. 19.3.5.1, 19.3.5.2, 19.3.5.3, 19.3.5.4, 19.3.5.5, 19.4.2, 19.3.5.10, 9.7, 9.7.1.1(1) This REQUIREMENT is not met as evidenced by: Based on observation and staff interview the facility failed to install The sprinkler system in	K 351	A double check valve shall be installed on the main fire sprinkler riser between the	1/25/19

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____	(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 351	Continued From page 5 accordance with the 2012 edition of the Life Safety Code (NFPA 101) sections 19.3.5.1, 9.7.1.1 and the 2010 edition of NFPA 13, The Standard for the Installation of Sprinkler Systems. This deficient practice could affect of 9 of 47 residents and an undetermined amount of staff and visitors. Findings include: On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed the main fire sprinkler riser was repaired incorrectly, it did not have a double check valve installed between the city input and connection to the system and did not have a shut off valve for the horizontal branch for the TCU wing. This deficient condition was confirmed by the Environmental Service Director.	K 351	city input and the connection to the system by Johnson Controls (SimplexGrinnell). The TCU wing currently has a shut off valve on the TCU wing valve assembly. The Environmental Services Supervisor shall be responsible for monitoring compliance and safety when changes are made to the facility fire sprinkler system by maintaining annual sprinkler inspections are completed.	
K 918 SS=F	Electrical Systems - Essential Electric System CFR(s): NFPA 101 Electrical Systems - Essential Electric System Maintenance and Testing The generator or other alternate power source and associated equipment is capable of supplying service within 10 seconds. If the 10-second criterion is not met during the monthly test, a process shall be provided to annually confirm this capability for the life safety and critical branches. Maintenance and testing of the generator and transfer switches are performed in accordance with NFPA 110. Generator sets are inspected weekly, exercised under load 30 minutes 12 times a year in 20-40 day intervals, and exercised once every 36 months for 4 continuous hours. Scheduled test	K 918		1/25/19

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____	(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER			STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621	
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 918	<p>Continued From page 6</p> <p>under load conditions include a complete simulated cold start and automatic or manual transfer of all EES loads, and are conducted by competent personnel. Maintenance and testing of stored energy power sources (Type 3 EES) are in accordance with NFPA 111. Main and feeder circuit breakers are inspected annually, and a program for periodically exercising the components is established according to manufacturer requirements. Written records of maintenance and testing are maintained and readily available. EES electrical panels and circuits are marked, readily identifiable, and separate from normal power circuits. Minimizing the possibility of damage of the emergency power source is a design consideration for new installations.</p> <p>6.4.4, 6.5.4, 6.6.4 (NFPA 99), NFPA 110, NFPA 111, 700.10 (NFPA 70)</p> <p>This REQUIREMENT is not met as evidenced by:</p> <p>Based on observations and staff interview the facility failed to provide emergency features in accordance with the 2012 edition of the Life Safety Code (NFPA 101) section 9.1.3.1 and the 2010 edition of NFPA 110 section 5.6.5.6, the Standard for Emergency and Standby Power Systems. This deficient practice could affect the safety of an undetermined amount of staff if the generator failed to shut down during an emergency.</p> <p>Findings include:</p> <p>On the facility tour between 9:00 am to 12:30 pm on 12/19/2018 observations revealed there was no emergency stop for the generator on the outside of the enclosure.</p>	K 918	<p>An emergency shut off switch has been ordered and shall be installed on the outside of the enclosure of the facility generator by an electrical contractor. The Environmental Services Supervisor shall monitor proper maintenance and testing of the generator weekly, monthly, and annually to ensure compliance and safety in the event of an emergency.</p>	

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 01/11/2019
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 245307	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - 2015 ADDITION B. WING _____		(X3) DATE SURVEY COMPLETED 12/19/2018
NAME OF PROVIDER OR SUPPLIER CORNERSTONE NSG & REHAB CENTER		STREET ADDRESS, CITY, STATE, ZIP CODE 416 SEVENTH STREET NORTHEAST BAGLEY, MN 56621		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 918	Continued From page 7 This deficient condition was confirmed by the Environmental Service Director.	K 918		